


# Progress of the Water Transfer from the Underground Reservoirs

Tokyo Electric Power Company



\*1 The transferred amount was confirmed by the water gauge installed at the H2 area tank.

\*2 Remaining water is transferred utilizing a temporary line during daytime.

\*3 Around 12:15 PM on June 5, water transfer was suspended since the water leakage was found at G6 tank.