

Nuclides Analysis Result of the Sub-drain of Unit 1 at Fukushima Daiichi NPS

(Unit: Bq/L)

	Unit 1	
	No.1 ^{*1}	No.2
Date of sampling	Aug 5, 2013	Aug 5, 2013
Time of sampling	8:08 AM	8:11 AM
Cs-134 (Approx. 2 years)	150	ND(14)
Cs-137 (Approx.30 years)	390	20
The other γ		
All β	290	25
H-3 (Approx. 12 years)	110,000	3,200

*1 Sampling location where analysis of cesium, etc. is performed as "Unit 1 Sub-drain". (Data of cesium at No.1 was announced on August 6).

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.