


Changes in the amount of water transferred from groundwater drains to reactor and turbine buildings and in the amount of groundwater and rainwater flowing into the buildings



Amount of water transferred from groundwater drains to reactor and turbine buildings (From November 3 to November 9, 2016/ 24 hours per day)

Date	Temporary storage tanks				(Reference) improved wells and well points				(Reference) Amount of water transferred to turbine buildings [(α)+(β)]
	A	B	C	Total*2 (α)	Between Units 1-2	Between Units 2-3	Between Units 3-4	Total*2 (β)	
Nov. 3	40	2	0	42	54	5	0	59	101
Nov. 4	39	31	0	70	44	7	0	51	121
Nov. 5	38	0	0	38	45	0	0	45	83
Nov. 6	37	0	0	37	49	0	0	49	86
Nov. 7	37	8	0	45	39	4	0	42	87
Nov. 8	36	0	0	36	45	0	0	45	81
Nov. 9	36	0	0	36	48	0	0	48	84

* ①Amount of groundwater and rainwater flowing into reactor and turbine buildings: 168m³/day, ②Amount of water transferred from groundwater drains to reactor and turbine buildings: 92m³/day, ③(Total of ① and ②): 260m³/day, Rainfall: 0.0mm/week

*1 Water gauges in reactor and turbine buildings were calibrated.

*2 There are cases where there is a difference between the sum of each number on the table above and the "total" because the "total" is the sum of numbers with one digit after the decimal point.