Reference March 9, 2017 Tokyo Electric Power Company Holdings, Inc.

Unit 1 Primary Containment Vessel (PCV) Investigation at Fukushima Daiichi Nuclear Power Station

IRID TEPCO

Tokyo Electric Power Company Holdings, Inc.

1. Work steps for Unit 1 PCV investigation





STEP3. Deposit sampling and re-installation of a thermometer and water gauge



A deposit sampling unit will be installed and deposits inside PCV will be sampled using a pump.

*Deposit: floating materials within the retained water and their precipitate

Water sucking hose

2. Step 2: Overview of PCV investigation using a self-propelled device $(1/4)_{T=2CO}$

Presence of fuel debris will be estimated from the comparison and evaluation of measurement results.

- Presence of fuel debris will be estimated from the comparison of radiation doses and distances subtracted from the background data.
- It is necessary to compare and evaluate digital images and radiation data because radiation levels can increase locally around the pipes connected to the reactor. <u>Evaluation results will be provided later</u> after organizing the data.



Background (Cesium adhered to pedestal floor)

Distance from pedestal floor [cm]



Measurement items: digital images and radiation doses

Measurement points	Estimation
D0	Spreading of fuel debris from drain sump
BG	Background levels against D0-D3 measurements
D1, D2	Spreading of fuel debris from opening
D3	Possibility of fuel debris reaching to PCV shell

Investigation plan

Day 1: D0 \Rightarrow Day 2: BG \Rightarrow Day 3: D2, D3 \Rightarrow Day 4 : D1

2. Step 2: Overview of PCV investigation using a self-propelled device (2/4)

- Investigation with a self-propelled device will be conducted without influencing the surrounding environment with leakage of air from PCV. A boundary will be created by installing a sealed box with a self-propelled device to a guiding pipe and then inserting the device into the PCV.
- To check the air leakage, <u>dust concentrations will be monitored with a dust sampler</u> <u>during the investigation</u>.



Boundary created for PCV investigation with a self-propelled device

2. Step 2: Overview of PCV investigation using a self-propelled device 3/4) TEPCO

Apout Toomm



Storage space for a camera and dosimeter

When capturing digital images and measuring radiation doses



When traveling on 1st floor metal grating inside PCV

Traveling direction

of a guiding pipe φ100mm

nner diameter





Dosimeter measurement range: $1 \times 10^{-1} \sim 1 \times 10^4$ Gy/h Underwater camera: 350,000 pixel Radiation resistance: 1000Gy

When inserted into a guiding pipe

Sensor unit integrating a camera and dosimeter

φ95mm

2. Step 2: Overview of PCV investigation using a self-propelled device $(4/4)_{T=2}^{+}$

Challenge and response based on the investigation results in April 2015

Unit 1 PCV investigation (conducted in April 2015)	Challenge	Things reflected to this investigation
The device got stuck in the grating ditch and could not move any more.	Information about the conditions of the floor was not enough.	 Laser guides will be installed in front of the device to improve the spatial ability as well as to enable the device to travel while checking obstacles and openings.
Camera screen could not be checked any more because it was affected by radiation.	Measures against radioactive degradation were not enough.	 When the investigation is not conducted, the monitoring camera will be retrieved into the guiding pipe.

Other challenge and response

Challenge	Things reflected to this investigation	
There are many structures within the retained water, such as scaffolds and pipes, which can pose obstacles to the device.	The measurement unit will be hung down and pulled up carefully.	
Visibility within the retained water could be poor because it was observed in the previous investigation (B1) that floating deposits flew up in the retained water.	The measurement unit will be hung down carefully no to let floating deposits fly up.	
When floating deposits in the retained water adhere to the measurement unit, radiation doses may not be measured accurately.	The measurement unit will be hung down carefully no to touch the bottom of the basement floor	

To prioritize the acquisition of site data, such as conditions of the pedestal opening of the basement floor and radiation doses, for the eventual removal of fuel debris, it will be determined whether to retrieve the device depending on the situation.

3. Step 3: Overview of deposit sampling (1/3)

- It was observed that floating deposits flew up within the PCV retained water when a permanent monitoring instrument was reinstalled after the previous investigation (April 2015).
- Sampling of the deposits at the bottom of PCV will be conducted to identify them and determine how to remove and treat them because they can pose obstacles to the future investigation and fuel debris removal.
- The sampled deposits will be analyzed with the simple X-ray fluorescence in a glove box to find the component.

*When the amount of the sampled deposits is large and radiation level is too high to deal with, a part of the deposits will be returned into the PCV.



Location of a permanent monitoring instrument reinstalled

TEPCO

3. Step 3: Overview of deposit sampling (2/3)

- Deposits near the X-100B penetration will be sampled with the retained water after a boundary is created by attaching a sealed box with a deposit sampling unit to a guiding pipe, so that the surrounding environment will not be affected with air leakage from the PCV.
- To check the leakage, <u>dust concentrations will be monitored with a dust sampler during the investigation</u>.
- After the sampling, a thermometer and dosimeter will be reinstalled inside the PCV.



ΤΞΡϹΟ





Drum for a hose and deposit sampling unit



Sampling bottle

Deposit sampling unit

4. Schedule (tentative)

Work steps	Year of 2017			
	February	March	April	
Preparation	Training Preparation	η 		
Removal of a thermometer and dosimeter		3/2 (conducted)		
Replacement of a guiding pipe		1/6~ (unde	rway)	
PCV investigation				
Deposit sampling				
Reinstallation of a thermometer and dosimeter]	

Today

10

- Relatively high radiation may be measured due to the proximity to fuel debris expected to exist at the bottom of PCV.
- In the case of measuring radiation levels more than several hundreds of Sievert per hour in the PCV, the levels will be reduced by the shielding of PCV concrete walls and steels.
- A boundary will be created during the investigation not to let the air from the PCV leak to the outside.
- Real-time data of monitoring posts and dust monitors along the site boundary are available on the website.

http://www.tepco.co.jp/en/nu/fukushima-np/f1/index-e.html

http://www.tepco.co.jp/en/nu/fukushima-np/f1/dustmonitor/index-e.html



6. Monitoring of the plant parameters

- In the case of measuring radiation levels more than several hundreds of Sievert per hour in the PCV, it does not mean that a new event has occurred but rather the area that has not been investigated since the March 2011 accident was investigated for the first time.
- Plant parameters are monitored all the time during the investigation.
 Temperature data inside the PCV are available on the website.

disators might not be functioning properly beyond the normal in for usage affected by the earthquake and subsequent events Fukushima Daiichi Nuclear Power Station Unit 1 Parameters of Temperature Fulls arbitrar Dallohi Number Prover Station Plant Parameter or non-search even with the term have a new search is even as or prevention in plants using all the available ration from indicators and also focusing on trends, taking uncertaint for the prevention. 100.0 As of 11:00 on March 9 2017 VESSEL BOTTOM HEAD(TE-263-69L1) + VESSEL BOTTOM HEAD(TE-263-69L2) Status of water injection to the reactor FDW line 1,5m/h (S line 1,5m/h (as of 11:00, 3/9) FDW line 1,8ml/h CS line 1,4ml/h les of 11:00.3/9 FDW line 1.5m/h CS line 2.5m/h (as of 11:00, 3/9 90.0 VESSEL ABOVE SKIRT JOINT(TE-263-69H1) VESSEL BOTTOM HEAD (TE-283-69L1):14.4°C VESSEL ABOVE SKIRT JOINT (TE-283-69H1):14.3°C VESSEL DOWNCOMMER (TE-283-69G2):14.2°C (as of 11:00,3/9) VESSEL BOTTOM HEAD (TE-2-3-89(.1):18.0°C VESSEL BOTTOM ABOVE SKIRT JOT (TE-2-3-89(.1):18.1°C (TE-2-3-89(.1):18.1°C VESSEL WALL ABOVE BOTTOM HEAD (TE-2-3-89(.1):18.6°C (TE-2-3-89(.1):18.6°C (as of 11:00.3/9.) VESSEL ABOVE SKIRT JOINT(TE-263-69H3) VESSEL WALL, ABOVE BOTTOM HEAD (TE-2-3-69H3) : 18,1°C RPV TEMPERATURE (TE-2-3-69H) : 17,8°C (as of 11:00, 3/9) femperature at the bottom of 80.0 ×VESSEL DOWNCOMMER(TE-263-69G2) × VESSEL DOWNCOMMER(TE-263-69G3) PETURN AR DRYWELL COOLER (TE-16-114B) : 186°C SUPPLY AR D/W COOLER HVH2-16B (TE-146#1) : 184°C (as of 1100, 3/9) RETURN AR DRYWELL COOLEF (TE-16-114A) :178°C SUPPLY AR D/W COOLER (TE-16-114F#1) :162°C (as of 11:00, 3/9) HVH-12A RETURN AIR (TE-1625A) : 14,7°C HVH-12A SUPPLY AIR HVH-12A RETURN AIR(TE-1625A) 70.0 Femperature in PCV HVH-12B RETURN AIR(TE-1625B) • HVH-12C RET 4,77kPag (as of 11:00, 3/9 0.24kPag las of 11:00.3/9 60.0 HVH-12D RET RPV:13,57Nml/h PCV:-Nml/h (as of 11,00,3/9 RPV:16,61Nml/h PCV:-Nml/h las of 11:00,3/9 Image *4 <u>*4</u> <u>*4</u> HVH-12E RET 50.0 د 15,47Nm/h (as of 11100, 3/9) HVH-12A SUI 20,63Nrl/h (as of 11:00, 3/9) HVH-12B SUI System A : 0.04vol9 System B : 0.05vol9 (as of 11:00, 3/9 System A : 0,06vol9 System B : 0,09vol9 las of 11:00, 3/9 40.0 HVH-12C SUP System A System A : Joreiem A : Indicated value 1.00E-03 detection limit 5.50E-04 Bo/ont System B : + HVH-12D SUPPLY AIR(TE-1625J) Indicated value ND detection limit 2,5E-01 System B : Indicated value ND detection limit 1.7E-01 **Radioactive** Ba/erf Ba/orf detection limit System B : PCV (Xe 135) #2 30.0 HVH-12E SUPPLY AIR(TE-1625K) Indicated value 9:60E-04 detection limit 4:90E-04 Ba/ord (as of 11:00, 3/9) indicated value ND detection limit 2.6E-01 (as of 11:00, 3/9) Indicated value ND detection limit 1.5E-01 Ba/art detection limit 1.8 (as of 11/00, 3/9 PCV Temperature(TE-1625T3) the spent fuel (as of 11:00, 3/9 24,0°C (as of 11:00, 3/9 26,5% 13.5°C (as of 11:00, 3/9 PCV Temperature(TE-1625T6) las of 11:00, 3/9 20.0 pool FPC skimmer 1.79m surge tank level (as of 11:00.3/9 3.46m (as of 11:00, 3/9 35.93×100mm (as of 11:00, 3/9 1,91m (as of 11:00, 3/9 ※ The measurement values of PCV temperature information stourt measurements] (TE-1625T3, TE-1625T6) have been 10.0 The longers concentration in the FOV gas control estem is provided. The longers concentration in the FOV gas control estem is provided. They may advance we statused according to the transmission in TOT is recorded. The redisconduly density Kari 35 in the FOV gas control extern is provided, through gas indicated in under supervised. missing since March 2, 2017 because they were excluded from the monitoring thermometer under the implementation plan 0.0 3/3 3/4 3/53/6 3/7 3/8 3/9 3/10

http://www.tepco.co.jp/en/nu/fukushima-np/f1/pla/index-e.html