

Results of the accumulated water analysis

June 25, 2011
Tokyo Electric Power Company

Treatment instrument	Water Desalination Instrument (RO)
----------------------	--------------------------------------

	Before treatment	After treatment (1)
Sample	Inlet water of the desalination instrument	Outlet water of the desalination instrument
Time and Date of sample collection	03:30 pm June 24, 2011	03:40 pm June 24, 2011
Place of sampling	samling line at the outlet of the the RO wastewater tank	samling line at the outlet of the the RO treatment tank

	Before treatment	After treatment
Nuclide	Density of the sampling (ppm)	Density of the sampling (ppm)
Density of chloride	13000	49

. E - means . x 10⁻