

September 2, 2011
Tokyo Electric Power Company

Sampling Result of Water in the Liner Drain of the Spent Fuel Pool
of the Fukushima Daiichi Nuclear Power Plant Unit 4

Sampling	pH	Cl (Chloride ion)	Hydrazine	Cesium 137	Cesium 134	Iodine 131
date/time	-	ppm	ppm	Bq/L	Bq/L	Bq/L
9/1 13:24	8.7	1,500	ND	2.2×10^4	1.6×10^4	ND