

Measurement Results of Sub-Drain Pit Water Level at Centralized Radiation Waste Treatment Facility

| Date | No112 (Northeast of Process Main Building) | | No125 (West of Incineration Workshop Building) | | No133 (West of On-Site Bunker Building) | | No150 (East of Miscellaneous Solid Waste Volume Reduction Treatment Building) | | No151 (North of Miscellaneous Solid Waste Volume Reduction Treatment Building) | | No152 (West of Miscellaneous Solid Waste Volume Reduction Treatment Building) | | No153 (South of Miscellaneous Solid Waste Volume Reduction Treatment Building) | |
|------|--|------|--|------|---|------|--|------|---|-------|--|------|---|-------|
| | Depth from GL | OP + | Depth from GL | OP + | Depth from GL | OP + | Depth from GL | OP + | Depth from GL | OP + | Depth from GL | OP + | Depth from GL | OP + |
| 7/1 | 3110 | 6890 | 2660 | 7340 | 7040 | 2960 | 430 | 9570 | 330 | 9670 | 390 | 9610 | 330 | 9670 |
| 7/2 | 3110 | 6890 | 2590 | 7410 | 7040 | 2960 | 430 | 9570 | 340 | 9660 | 400 | 9600 | 340 | 9660 |
| 7/3 | 3120 | 6880 | 2610 | 7390 | 7040 | 2960 | 450 | 9550 | 350 | 9650 | 410 | 9590 | 340 | 9660 |
| 7/4 | 3080 | 6920 | 2600 | 7400 | 7070 | 2930 | 440 | 9560 | 330 | 9670 | 390 | 9610 | 330 | 9670 |
| 7/5 | 3080 | 6920 | 2610 | 7390 | 7070 | 2930 | 420 | 9580 | 320 | 9680 | 370 | 9630 | 310 | 9690 |
| 7/6 | 3080 | 6920 | 2630 | 7370 | 7070 | 2930 | 440 | 9560 | 340 | 9660 | 400 | 9600 | 330 | 9670 |
| 7/7 | 3080 | 6920 | 2620 | 7380 | 7080 | 2920 | 450 | 9550 | 340 | 9660 | 400 | 9600 | 340 | 9660 |
| 7/8 | 3070 | 6930 | 2640 | 7360 | 7010 | 2990 | 470 | 9530 | 380 | 9620 | 440 | 9560 | 370 | 9630 |
| 7/9 | 3070 | 6930 | 2660 | 7340 | 7000 | 3000 | 490 | 9510 | 380 | 9620 | 440 | 9560 | 380 | 9620 |
| 7/10 | 3080 | 6920 | 2650 | 7350 | 6970 | 3030 | 500 | 9500 | 400 | 9600 | 460 | 9540 | 400 | 9600 |
| 7/11 | 3070 | 6930 | 2660 | 7340 | 6990 | 3010 | 500 | 9500 | 400 | 9600 | 460 | 9540 | 400 | 9600 |
| 7/12 | 3080 | 6920 | 2650 | 7350 | 7030 | 2970 | 500 | 9500 | 380 | 9620 | 440 | 9560 | 380 | 9620 |
| 7/13 | 3070 | 6930 | 2640 | 7360 | 7020 | 2980 | 500 | 9500 | 380 | 9620 | 440 | 9560 | 380 | 9620 |
| 7/14 | 3080 | 6920 | 2640 | 7360 | 7030 | 2970 | 490 | 9510 | 380 | 9620 | 440 | 9560 | 380 | 9620 |
| 7/15 | 3060 | 6940 | 2640 | 7360 | 7050 | 2950 | 480 | 9520 | 380 | 9620 | 440 | 9560 | 380 | 9620 |
| 7/16 | 3080 | 6920 | 2630 | 7370 | 7050 | 2950 | 480 | 9520 | 380 | 9620 | 440 | 9560 | 370 | 9630 |
| 7/17 | 3080 | 6920 | 2630 | 7370 | 7100 | 2900 | 480 | 9520 | 370 | 9630 | 430 | 9570 | 370 | 9630 |
| 7/18 | 3060 | 6940 | 2630 | 7370 | 7040 | 2960 | 480 | 9520 | 370 | 9630 | 430 | 9570 | 370 | 9630 |
| 7/19 | 3040 | 6960 | 2610 | 7390 | 7100 | 2900 | 470 | 9530 | 360 | 9640 | 420 | 9580 | 350 | 9650 |
| 7/20 | 2900 | 7100 | 2120 | 7880 | 7250 | 2750 | 250 | 9750 | 140 | 9860 | 200 | 9800 | 130 | 9870 |
| 7/21 | 2680 | 7320 | 1640 | 8360 | 7410 | 2590 | 100 | 9900 | 0 | 10000 | 60 | 9940 | 0 | 10000 |
| 7/22 | 2660 | 7340 | 1950 | 8050 | 7450 | 2550 | 200 | 9800 | 140 | 9860 | 80 | 9920 | 70 | 9930 |
| 7/23 | 2670 | 7330 | 2050 | 7950 | 7440 | 2560 | 200 | 9800 | 160 | 9840 | 100 | 9900 | 100 | 9900 |
| 7/24 | 2680 | 7320 | 2130 | 7870 | 7420 | 2580 | 230 | 9770 | 200 | 9800 | 140 | 9860 | 120 | 9880 |
| 7/25 | 2680 | 7320 | 2190 | 7810 | 7280 | 2720 | 300 | 9700 | 260 | 9740 | 200 | 9800 | 190 | 9810 |
| 7/26 | 2650 | 7350 | 2240 | 7760 | 7300 | 2700 | 300 | 9700 | 210 | 9790 | 270 | 9730 | 200 | 9800 |
| 7/27 | 2650 | 7350 | 2270 | 7730 | 7300 | 2700 | 300 | 9700 | 220 | 9780 | 280 | 9720 | 200 | 9800 |
| 7/28 | 2670 | 7330 | 2290 | 7710 | 7310 | 2690 | 310 | 9690 | 260 | 9740 | 200 | 9800 | 190 | 9810 |
| 7/29 | 2680 | 7320 | 2240 | 7760 | 7340 | 2660 | 250 | 9750 | 120 | 9880 | 190 | 9810 | 110 | 9890 |
| 7/30 | 2680 | 7320 | 2220 | 7780 | 7330 | 2670 | 250 | 9750 | 160 | 9840 | 230 | 9770 | 150 | 9850 |
| 7/31 | 2690 | 7310 | 1860 | 8140 | 7350 | 2650 | 200 | 9800 | 170 | 9830 | 110 | 9890 | 100 | 9900 |

Note ·GL(ground level) of the Centralized Radiation Waste Treatment Facility is OP + 1.0 m.

Measurement Results of Sub-Drain Pit Water Level at Centralized Radiation Waste Treatment Facility

| Date | No112 (Northeast of Process Main Building) | | No125 (West of Incineration Workshop Building) | | No133 (West of On-Site Bunker Building) | | No150 (East of Miscellaneous Solid Waste Volume Reduction Treatment Building) | | No151 (North of Miscellaneous Solid Waste Volume Reduction Treatment Building) | | No152 (West of Miscellaneous Solid Waste Volume Reduction Treatment Building) | | No153 (South of Miscellaneous Solid Waste Volume Reduction Treatment Building) | |
|------|---|------|---|------|--|------|--|------|---|-------|--|------|---|-------|
| | Depth from GL | OP + | Depth from GL | OP + | Depth from GL | OP + | Depth from GL | OP + | Depth from GL | OP + | Depth from GL | OP + | Depth from GL | OP + |
| 8/1 | 2690 | 7310 | 2060 | 7940 | 7260 | 2740 | 260 | 9740 | 170 | 9830 | 240 | 9760 | 170 | 9830 |
| 8/2 | 2700 | 7300 | 2160 | 7840 | 7280 | 2720 | 260 | 9740 | 200 | 9800 | 260 | 9740 | 190 | 9810 |
| 8/3 | 2700 | 7300 | 2220 | 7780 | 7280 | 2720 | 300 | 9700 | 210 | 9790 | 270 | 9730 | 200 | 9800 |
| 8/4 | 2700 | 7300 | 2260 | 7740 | 7280 | 2720 | 300 | 9700 | 190 | 9810 | 260 | 9740 | 190 | 9810 |
| 8/5 | 2700 | 7300 | 2280 | 7720 | 7280 | 2720 | 300 | 9700 | 190 | 9810 | 260 | 9740 | 180 | 9820 |
| 8/6 | 2710 | 7290 | 2300 | 7700 | 7280 | 2720 | 300 | 9700 | 200 | 9800 | 270 | 9730 | 190 | 9810 |
| 8/7 | 2710 | 7290 | 2320 | 7680 | 7280 | 2720 | 300 | 9700 | 210 | 9790 | 270 | 9730 | 200 | 9800 |
| 8/8 | 2700 | 7300 | 2330 | 7670 | 7280 | 2720 | 300 | 9700 | 200 | 9800 | 270 | 9730 | 200 | 9800 |
| 8/9 | 2700 | 7300 | 2340 | 7660 | 7280 | 2720 | 300 | 9700 | 200 | 9800 | 260 | 9740 | 190 | 9810 |
| 8/10 | 2700 | 7300 | 2340 | 7660 | 7290 | 2710 | 300 | 9700 | 190 | 9810 | 260 | 9740 | 180 | 9820 |
| 8/11 | 2700 | 7300 | 2350 | 7650 | 7290 | 2710 | 300 | 9700 | 190 | 9810 | 250 | 9750 | 180 | 9820 |
| 8/12 | 2700 | 7300 | 2360 | 7640 | 7130 | 2870 | 370 | 9630 | 280 | 9720 | 340 | 9660 | 270 | 9730 |
| 8/13 | 2710 | 7290 | 2400 | 7600 | 7180 | 2820 | 360 | 9640 | 280 | 9720 | 350 | 9650 | 270 | 9730 |
| 8/14 | 2700 | 7300 | 2410 | 7590 | 7210 | 2790 | 380 | 9620 | 280 | 9720 | 340 | 9660 | 270 | 9730 |
| 8/15 | 2700 | 7300 | 2410 | 7590 | 7230 | 2770 | 380 | 9620 | 270 | 9730 | 330 | 9670 | 260 | 9740 |
| 8/16 | 2700 | 7300 | 2410 | 7590 | 7240 | 2760 | 380 | 9620 | 260 | 9740 | 320 | 9680 | 250 | 9750 |
| 8/17 | 2710 | 7290 | 2420 | 7580 | 7250 | 2750 | 400 | 9600 | 260 | 9740 | 320 | 9680 | 250 | 9750 |
| 8/18 | 2710 | 7290 | 2420 | 7580 | 7260 | 2740 | 400 | 9600 | 250 | 9750 | 320 | 9680 | 240 | 9760 |
| 8/19 | 2710 | 7290 | 2160 | 7840 | 7320 | 2680 | 200 | 9800 | 70 | 9930 | 130 | 9870 | 60 | 9940 |
| 8/20 | 2730 | 7270 | 2080 | 7920 | 7280 | 2720 | 250 | 9750 | 160 | 9840 | 230 | 9770 | 150 | 9850 |
| 8/21 | 2740 | 7260 | 1980 | 8020 | 7390 | 2610 | 150 | 9850 | 0 | 10000 | 70 | 9930 | -10 | 10010 |
| 8/22 | 2690 | 7310 | 1640 | 8360 | 7470 | 2530 | 150 | 9850 | 30 | 9970 | 100 | 9900 | 20 | 9980 |
| 8/23 | 2670 | 7330 | 1880 | 8120 | 7490 | 2510 | 200 | 9800 | 100 | 9900 | 160 | 9840 | 90 | 9910 |
| 8/24 | 2670 | 7330 | 2010 | 7990 | 7480 | 2520 | 200 | 9800 | 130 | 9870 | 190 | 9810 | 120 | 9880 |
| 8/25 | 2650 | 7350 | 2060 | 7940 | 7480 | 2520 | 230 | 9770 | 100 | 9900 | 170 | 9830 | 90 | 9910 |
| 8/26 | 2650 | 7350 | 2090 | 7910 | 7470 | 2530 | 230 | 9770 | 130 | 9870 | 200 | 9800 | 120 | 9880 |
| 8/27 | 2650 | 7350 | 2120 | 7880 | 7470 | 2530 | 230 | 9770 | 140 | 9860 | 200 | 9800 | 130 | 9870 |
| 8/28 | 2650 | 7350 | 2150 | 7850 | 7470 | 2530 | 250 | 9750 | 150 | 9850 | 220 | 9780 | 140 | 9860 |
| 8/29 | 2650 | 7350 | 2170 | 7830 | 7470 | 2530 | 250 | 9750 | 160 | 9840 | 220 | 9780 | 150 | 9850 |
| 8/30 | 2650 | 7350 | 2180 | 7820 | 7470 | 2530 | 260 | 9740 | 150 | 9850 | 220 | 9780 | 140 | 9860 |
| 8/31 | 2640 | 7360 | 2200 | 7800 | 7470 | 2530 | 260 | 9740 | 140 | 9860 | 210 | 9790 | 130 | 9870 |

Note ·GL(ground level) of the Centralized Radiation Waste Treatment Facility is O P + 1 0 m.

Measurement Results of Sub-Drain Pit Water Level at Centralized Radiation Waste Treatment Facility

| Date | No112 (Northeast of Process Main Building) | | No125 (West of Incineration Workshop Building) | | No133 (West of On-Site Bunker Building) | | No150 (East of Miscellaneous Solid Waste Volume Reduction Treatment Building) | | No151 (North of Miscellaneous Solid Waste Volume Reduction Treatment Building) | | No152 (West of Miscellaneous Solid Waste Volume Reduction Treatment Building) | | No153 (South of Miscellaneous Solid Waste Volume Reduction Treatment Building) | |
|------|---|------|---|------|--|------|--|------|---|-------|--|------|---|-------|
| | Depth from GL | OP + | Depth from GL | OP + | Depth from GL | OP + | Depth from GL | OP + | Depth from GL | OP + | Depth from GL | OP + | Depth from GL | OP + |
| 9/1 | 2640 | 7360 | 2210 | 7790 | 2530 | 7470 | 250 | 9750 | 110 | 9890 | 180 | 9820 | 100 | 9900 |
| 9/2 | 2600 | 7400 | 1940 | 8060 | 2450 | 7550 | 150 | 9850 | -10 | 10010 | 50 | 9950 | -20 | 10020 |
| 9/3 | 2600 | 7400 | 1870 | 8130 | 2410 | 7590 | 150 | 9850 | 20 | 9980 | 80 | 9920 | 0 | 10000 |
| 9/4 | 2550 | 7450 | 1830 | 8170 | 2390 | 7610 | 140 | 9860 | 40 | 9960 | 100 | 9900 | 20 | 9980 |
| 9/5 | 2550 | 7450 | 1930 | 8070 | 2390 | 7610 | 140 | 9860 | 50 | 9950 | 110 | 9890 | 40 | 9960 |
| 9/6 | 2530 | 7470 | 2010 | 7990 | 2410 | 7590 | 150 | 9850 | 80 | 9920 | 140 | 9860 | 70 | 9930 |
| 9/7 | 2530 | 7470 | 2070 | 7930 | 2440 | 7560 | 200 | 9800 | 100 | 9900 | 170 | 9830 | 90 | 9910 |
| 9/8 | 2530 | 7470 | 2130 | 7870 | 2460 | 7540 | 230 | 9770 | 130 | 9870 | 190 | 9810 | 120 | 9880 |
| 9/9 | 2530 | 7470 | 2160 | 7840 | 2450 | 7550 | 230 | 9770 | 130 | 9870 | 200 | 9800 | 120 | 9880 |
| 9/10 | 2510 | 7490 | 2180 | 7820 | 2450 | 7550 | 270 | 9730 | 130 | 9870 | 200 | 9800 | 120 | 9880 |
| 9/11 | 2510 | 7490 | 2200 | 7800 | 2450 | 7550 | 250 | 9750 | 140 | 9860 | 200 | 9800 | 130 | 9870 |
| 9/12 | 2510 | 7490 | 2200 | 7800 | 2440 | 7560 | 250 | 9750 | 120 | 9880 | 190 | 9810 | 110 | 9890 |
| 9/13 | 2510 | 7490 | 2210 | 7790 | 2430 | 7570 | 250 | 9750 | 120 | 9880 | 190 | 9810 | 110 | 9890 |
| 9/14 | 2550 | 7450 | 2220 | 7780 | 2430 | 7570 | 250 | 9750 | 130 | 9870 | 190 | 9810 | 120 | 9880 |
| 9/15 | 2540 | 7460 | 2230 | 7770 | 2420 | 7580 | 250 | 9750 | 130 | 9870 | 190 | 9810 | 120 | 9880 |
| 9/16 | 2550 | 7450 | 2230 | 7770 | 2430 | 7570 | 250 | 9750 | 140 | 9860 | 200 | 9800 | 130 | 9870 |

Note · GL(ground level) of the Centralized Radiation Waste Treatment Facility is O P + 1 0 m.

Measurement Results of Sub-Drain Pit Water Level at Main Building of Unit 1 ~ 6

(Unit: mm)

| Unit | Number | Date of Sampling | | Date of Sampling | | Date of Sampling | | Date of Sampling | | Date of Sampling | |
|--------|---------|------------------|-------|------------------|-------|------------------|-------|------------------|-------|------------------|-------|
| | | June 3 | | June 10 | | June 17 | | June 24 | | June 29 | |
| | | Depth from GL | OP + | Depth from GL | OP + | Depth from GL | OP + | Depth from GL | OP + | Depth from GL | OP + |
| Unit 1 | No. 1 | 5390 | 4,610 | 5,540 | 4,460 | 5,790 | 4,210 | 5,350 | 4,650 | 5,230 | 4,770 |
| Unit 2 | No. 2 7 | 5880 | 4,120 | 5,810 | 4,190 | 5,850 | 4,150 | 4,850 | 5,150 | 5,400 | 4,600 |
| Unit 3 | No. 3 2 | 3250 | 6,750 | 6,400 | 3,600 | 6,430 | 3,570 | 5,290 | 4,710 | 5,920 | 4,080 |
| Unit 4 | No. 5 6 | 5800 | 4,200 | 5,710 | 4,290 | 5,580 | 4,420 | 5,290 | 4,710 | 5,270 | 4,730 |
| Unit 5 | No. 7 1 | 7780 | 5,220 | 7,930 | 5,070 | 8,020 | 4,980 | 7,560 | 5,440 | 7,410 | 5,590 |
| Unit 6 | No. 9 5 | 7380 | 5,620 | 7,450 | 5,550 | 7,570 | 5,430 | 6,910 | 6,090 | 6,690 | 6,310 |

Note 1) GL(ground level) of Unit 1 ~ 4 is OP + 10 m.

2) GL(ground level) of Unit 5 and 6 is OP + 13 m.

Measurement Results of Sub-Drain Pit Water Level at Main Building of Unit 1 ~ 6

(Unit : mm)

| Unit | Number | Date of Sampling | | Date of Sampling | | Date of Sampling | | Date of Sampling | | Date of Sampling | |
|--------|----------|------------------|------|------------------|------|------------------|------|------------------|------|------------------|------|
| | | August 1 | | August 8 | | August 15 | | August 22 | | August 29 | |
| | | Depth from GL | OP + | Depth from GL | OP + | Depth from GL | OP + | Depth from GL | OP + | Depth from GL | OP + |
| Unit 1 | No . 1 | 5480 | 4520 | 5690 | 4310 | 5980 | 4020 | 5390 | 4610 | 5790 | 4210 |
| Unit 2 | No . 2 7 | 5450 | 4550 | 5500 | 4500 | 5820 | 4180 | 4890 | 5110 | 5320 | 4680 |
| Unit 3 | No . 3 2 | 5650 | 4350 | 6080 | 3920 | 6210 | 3790 | 5600 | 4400 | 6070 | 3930 |
| Unit 4 | No . 5 6 | 5220 | 4780 | 5250 | 4750 | 5330 | 4670 | 5130 | 4870 | 5050 | 4950 |
| Unit 5 | No . 7 1 | 7320 | 5680 | 7470 | 5530 | 7630 | 5370 | 7590 | 5410 | 7420 | 5580 |
| Unit 6 | No . 9 5 | 6770 | 6230 | 6990 | 6010 | 7260 | 5740 | 7300 | 5700 | 7110 | 5890 |

Note 1) GL(ground level) of Unit 1 ~ 4 is OP + 1 0 m.

2) GL(ground level) of Unit 5 and 6 is OP + 1 3 m.

Measurement Results of Sub-Drain Pit Water Level at Main Building of Unit 1 ~ 6


(Unit: mm)

| Unit | Number | Date of Sampling | | Date of Sampling | | Date of Sampling | |
|--------|----------|------------------|------|------------------|------|------------------|------|
| | | September 2 | | September 9 | | September 16 | |
| | | Depth from GL | OP + | Depth from GL | OP + | Depth from GL | OP + |
| Unit 1 | No . 1 | 5120 | 4880 | 5870 | 4130 | 5930 | 4070 |
| Unit 2 | No . 2 7 | 5160 | 4840 | 5370 | 4630 | 5520 | 4480 |
| Unit 3 | No . 3 2 | 5970 | 4030 | 6130 | 3870 | 6260 | 3740 |
| Unit 4 | No . 5 6 | 5030 | 4970 | 5130 | 4870 | 5120 | 4880 |
| Unit 5 | No . 7 1 | 7490 | 5510 | 7460 | 5540 | 7590 | 5410 |
| Unit 6 | No . 9 5 | 7190 | 5810 | 7200 | 5800 | 7350 | 5650 |


Note 1) GL(ground level) of Unit 1 ~ 4 is OP + 1 0 m.

2) GL(ground level) of Unit 5 and 6 is OP + 1 3 m.


Layout Drawing of Unit 1 ~ 6 of Fukushima Daiichi Nuclear Power Station and Sub-Drain of Centralized Radiation Waste Treatment Facility




Main Building of Unit 1 and 2



Main Building of Unit 3 and 4



Main Building of 5 and 6



Centralized Radiation Waste Treatment Facility