


# Survey results of pipe penetration on 1<sup>st</sup> floor of Unit 1 reactor building of Fukushima Daiichi Nuclear Power Station

October 14, 2011

Tokyo Electric Power Company



## Machine used

2 Packbot robots

## Date and time of entry to the reactor building

October 13, 2011

11:56 am ~ 1:02 pm

## Survey results

Although we confirmed the steam eruption from the pipe penetration on the 1<sup>st</sup> floor during the previous survey (on June 3, 2011), we didn't find any eruption there this time.

### 【Legend】

Red : Radiation dose measured [mSv/h] on Oct 13

Blue : Radiation dose [mSv/h] measured on Jun 3

Green : Temperature [ ], humidity[%]