## Water leakage in Fukushima Daiichi NPS (found on Jan 31)

< Reference > January 31, 2012 Tokyo Electric Power Company

Νo	Time of the occurrence (time of leakage stop, leakage separation)	Leaking place/spot	Leaked amount	water shield	radioactivity concentration (Bq/cm3)	Flow into the ocean	Impact to the system	Airborne Radiation (mSv/h)
	(lookage stepped at the time	evaporative concentration apparatus boiler (A) concentrated water backflow line flange part	filtered water/about 20L (5m × 4m × 1mm)	No	Filtered water	No	No	1
	January 31 , 2012 approx. 14:30 (approx. 14:30 leakage stopped by closing the upstream valve)	No.2 filtered water tank temporary header	filtered water/about 20L (amount of frozen water)	No	Filtered water	No	No	_