

# Water leakage in Fukushima Daiichi Nuclear Power Station (Confirmed on February 2nd)

February 2, 2012  
Tokyo Electric Power Company

No	Date and Time of Occurrence (Date and Time of stop or isolation)	Leaked Place/Point	Amount of Leaked Water	With/Without Dam	Radioactivity Density (Bq/cm <sup>3</sup> )	Flow Out to Ocean	Influence to System	Atmosphere Dose Rate (mSv/h)
	15:30 Feb. 2, 2012 (16:05 isolated)	Flange of discharge piping in water treatment building that purifies filtrate water	0.25L	Without	Filtrate Water	No	No	0.02
	15:30 Feb. 2, 2012 (16:05 isolated)	Drain valve of discharge piping in water treatment building that purifies filtrate water	0.25L	Without	Filtrate Water	No	No	0.02