

## Fukushima Daiichi NPS Unit 2

The temperature of the lower part of the reactor pressure vessel (upper part of the bottom head / upper part of support skirt junction) (Reference)

location		the bottom head			support skirt junction			location		the bottom head			support skirt junction		
mounting angle	0 °	135 °	270 °	0 °	135 °	270 °	mounting angle	0 °	135 °	270 °	0 °	135 °	270 °		
serial number	TE-2-3-69H1	TE-2-3-69H2	TE-2-3-69H3	TE-2-3-69F1	TE-2-3-69F2	TE-2-3-69F3	serial number	TE-2-3-69H1	TE-2-3-69H2	TE-2-3-69H3	TE-2-3-69F1	TE-2-3-69F2	TE-2-3-69F3		
2/1 1:00	50.7	44.5	43.9	50.4	45.8	46.6	2/4 3:00	63.2	45.2	45.0	50.1	47.0	48.1		
2/1 4:00	51.1	44.7	44.0	48.4	45.8	46.6	2/4 4:00	64.1	45.3	45.0	50.1	47.0	48.0		
2/1 7:00	50.9	44.4	43.9	51.0	45.8	46.6	2/4 5:00	64.6	45.3	45.0	49.8	47.1	48.0		
2/1 10:00	52.9	44.5	43.9	48.8	45.8	46.6	2/4 6:00	64.7	45.2	45.1	53.2	47.1	48.0		
2/1 11:00	50.2	44.6	44.0	48.4	45.8	46.7	2/4 7:00	66.8	45.1	45.1	47.6	47.0	48.1		
2/1 12:00	51.0	44.4	43.9	48.3	45.8	46.6	2/4 8:00	64.7	45.3	45.1	49.7	47.1	48.0		
2/1 13:00	51.3	44.4	43.9	50.8	45.7	46.6	2/4 9:00	63.7	45.3	45.1	50.2	47.0	48.1		
2/1 14:00	51.3	44.4	43.9	42.4	45.8	46.6	2/4 10:00	66.5	45.1	45.2	51.8	47.0	48.1		
2/1 15:00	52.8	44.1	43.9	47.9	45.8	46.5	2/4 11:00	66.3	45.2	45.1	52.1	47.0	48.1		
2/1 16:00	51.9	44.5	43.9	48.7	45.8	46.6	2/4 12:00	64.1	45.4	45.1	50.1	47.0	48.2		
2/1 17:00	50.3	44.4	43.9	48.4	45.8	46.7	2/4 13:00	65.2	45.4	45.1	49.7	47.0	48.2		
2/1 18:00	51.4	44.4	43.9	49.1	45.8	46.6	2/4 14:00	65.2	45.5	45.2	49.5	47.1	48.1		
2/1 19:00	51.7	44.5	44.0	51.7	45.8	46.7	2/4 15:00	66.6	45.3	45.2	51.7	47.0	48.0		
2/1 22:00	52.3	44.7	44.0	48.7	45.9	46.7	2/4 16:00	67.2	45.5	45.2	44.1	47.0	48.1		
2/2 1:00	52.2	44.5	44.0	51.3	46.0	46.9	2/4 17:00	64.8	45.7	45.2	46.8	47.1	48.3		
2/2 4:00	53.4	44.6	43.9	49.0	45.9	46.7	2/4 18:00	64.8	45.6	45.2	50.0	47.0	48.2		
2/2 7:00	51.7	44.6	44.1	49.0	46.0	47.0	2/4 19:00	65.2	45.6	45.3	49.6	47.0	48.2		
2/2 10:00	55.0	44.6	44.1	46.4	46.1	46.9	2/4 20:00	65.6	45.6	45.2	49.3	47.0	48.2		
2/2 11:00	52.6	44.8	44.1	49.1	46.1	47.0	2/4 21:00	65.4	45.6	45.2	49.9	47.1	48.2		
2/2 12:00	52.2	44.7	44.2	49.1	46.2	47.1	2/4 22:00	65.8	45.7	45.3	49.7	47.1	48.3		
2/2 13:00	54.0	44.5	44.2	49.1	46.2	47.0	2/4 23:00	66.2	45.6	45.3	49.3	47.1	48.3		
2/2 14:00	54.4	44.4	44.2	51.1	46.2	47.1	2/5 0:00	67.8	45.4	45.2	51.9	47.1	48.4		
2/2 15:00	55.7	44.3	44.2	44.3	46.2	47.0	2/5 1:00	69.2	45.7	45.3	46.4	47.1	48.2		
2/2 16:00	56.4	44.6	44.2	45.5	46.2	47.0	2/5 2:00	66.4	45.9	45.3	45.8	47.1	48.4		
2/2 19:00	56.8	44.8	44.3	48.0	46.4	47.1	2/5 3:00	66.3	45.7	45.3	49.6	47.1	48.4		
2/2 22:00	55.3	44.7	44.3	49.2	46.4	47.2	2/5 4:00	67.1	45.6	45.3	49.3	47.1	48.4		
2/3 1:00	55.3	44.7	44.3	49.2	46.4	47.2	2/5 5:00	67.4	45.6	45.2	49.2	47.1	48.4		
2/3 4:00	56.9	44.7	44.4	49.2	46.5	47.3	2/5 6:00	67.7	45.3	45.2	51.9	47.0	48.3		
2/3 7:00	59.5	44.6	44.4	44.8	46.6	47.3	2/5 7:00	70.4	45.5	45.2	51.4	47.0	48.2		
2/3 10:00	58.6	45.0	44.4	50.0	46.6	47.4	2/5 8:00	68.2	45.7	45.2	46.3	47.0	48.4		
2/3 11:00	58.2	44.8	44.5	50.6	46.6	47.4	2/5 9:00	67.4	45.5	45.1	50.0	47.0	48.3		
2/3 12:00	61.5	44.6	44.6	51.4	46.7	47.6	2/5 10:00	68.8	45.4	45.1	49.6	47.0	48.2		
2/3 13:00	62.7	44.5	44.5	44.8	46.7	47.4	2/5 11:00	69.0	45.6	45.0	45.9	46.9	48.2		
2/3 14:00	61.2	44.7	44.5	51.0	46.8	47.5	2/5 12:00	67.7	45.3	45.0	49.5	46.9	48.0		
2/3 15:00	60.9	44.8	44.5	49.7	46.7	47.5	2/5 13:00	68.7	45.3	45.0	49.2	46.8	47.9		
2/3 16:00	63.5	44.8	44.5	44.9	46.7	47.5	2/5 14:00	68.9	45.2	44.9	48.9	46.8	47.9		
2/3 17:00	61.3	45.0	44.6	50.0	46.7	47.7	2/5 15:00	70.4	45.0	44.8	51.7	46.8	47.9		
2/3 18:00	60.9	44.9	44.6	50.0	46.8	47.7	2/5 16:00	71.7	45.3	44.8	50.9	46.7	47.8		
2/3 19:00	62.9	44.6	44.6	43.8	46.7	47.6	2/5 17:00	69.1	45.3	44.8	45.6	46.7	47.9		
2/3 20:00	61.7	45.0	44.6	50.0	46.8	47.7	2/5 18:00	68.3	45.1	44.7	46.0	46.6	47.9		
2/3 21:00	61.2	44.9	44.7	49.8	46.8	47.7	2/5 19:00	69.8	45.0	44.7	49.0	46.6	47.8		
2/3 22:00	62.1	44.9	44.7	49.8	46.8	47.7	2/5 20:00	70.1	45.0	44.7	48.8	46.6	47.8		
2/3 23:00	62.5	45.0	44.8	52.3	46.9	47.9	2/5 21:00	71.0	44.8	44.6	50.0	46.5	47.7		
2/4 0:00	63.2	44.8	44.8	52.3	47.0	47.9	2/5 22:00	72.6	45.0	44.6	50.9	46.5	47.7		
2/4 1:00	65.2	44.9	44.9	44.4	47.0	47.8	2/5 23:00	70.6	45.0	44.6	44.4	46.4	47.7		
2/4 2:00	64.1	45.3	45.0	46.1	47.0	48.0	2/6 0:00	70.0	44.9	44.5	45.2	46.4	47.8		

\*There is a possibility that the numbers are not the same as the relevant parameters to the plant because the data above are the reference.

location mounting angle	the bottom head			support skirt junction			location mounting angle	the bottom head			support skirt junction		
	0 °	135 °	270 °	0 °	135 °	270 °		0 °	135 °	270 °	0 °	135 °	270 °
serial number	TE-2-3-69H1	TE-2-3-69H2	TE-2-3-69H3	TE-2-3-69F1	TE-2-3-69F2	TE-2-3-69F3	serial number	TE-2-3-69H1	TE-2-3-69H2	TE-2-3-69H3	TE-2-3-69F1	TE-2-3-69F2	TE-2-3-69F3
2/6 1:00	70.6	44.8	44.5	48.8	46.4	47.6	2/8 4:00	67.4	39.8	39.8	44.4	41.7	43.1
2/6 2:00	71.1	44.8	44.5	48.7	46.3	47.6	2/8 5:00	67.4	40.3	39.6	47.4	41.6	43.0
2/6 3:00	70.3	44.6	44.4	48.5	46.3	47.5	2/8 6:00	65.0	40.0	39.6	46.3	41.5	43.0
2/6 4:00	73.1	44.8	44.4	51.0	46.3	47.6	2/8 7:00	66.1	39.9	39.6	40.6	41.5	42.8
2/6 5:00	70.6	44.7	44.3	48.5	46.2	47.5	2/8 8:00	66.1	39.8	39.4	44.4	41.3	42.8
2/6 6:00	71.0	44.4	44.2	48.4	46.1	47.5	2/8 9:00	66.2	39.6	39.4	44.3	41.2	42.6
2/6 7:00	73.3	44.6	44.2	50.8	46.1	47.4	2/8 10:00	68.0	39.3	39.2	44.0	41.2	42.5
2/6 8:00	71.2	44.7	44.1	44.1	46.0	47.5	2/8 11:00	66.0	39.5	39.2	41.7	41.1	42.4
2/6 9:00	69.6	44.4	44.1	44.5	46.0	47.3	2/8 12:00	66.1	39.7	39.1	46.3	41.0	42.4
2/6 10:00	70.5	44.3	44.0	48.6	45.9	47.1	2/8 13:00	66.2	39.4	39.0	39.9	40.9	42.3
2/6 11:00	70.6	44.1	43.9	48.2	45.8	47.1	2/8 14:00	66.5	39.3	38.9	40.7	40.9	42.2
2/6 12:00	72.0	43.9	43.8	48.0	45.7	47.0	2/8 15:00	66.3	38.9	38.9	43.8	40.7	42.1
2/6 13:00	70.7	44.1	43.8	48.0	45.7	47.0	2/8 16:00	68.0	38.7	38.8	43.6	40.7	42.1
2/6 14:00	70.7	44.0	43.7	47.9	45.6	46.9	2/8 17:00	66.4	39.4	38.7	46.1	40.6	42.0
2/6 15:00	70.8	43.8	43.6	47.8	45.6	46.8	2/8 18:00	64.1	39.0	38.6	45.7	40.6	42.0
2/6 16:00	71.6	43.9	43.6	50.4	45.5	46.7	2/8 19:00	64.7	39.0	38.6	38.8	40.5	41.9
2/6 17:00	69.5	44.1	43.5	49.2	45.4	46.9	2/8 20:00	65.4	38.9	38.5	41.7	40.4	41.7
2/6 18:00	68.5	43.9	43.5	43.7	45.4	46.7	2/8 21:00	66.3	38.6	38.5	43.5	40.4	41.7
2/6 19:00	69.3	43.8	43.4	48.0	45.3	46.6	2/8 22:00	67.9	38.4	38.5	43.3	40.3	41.6
2/6 20:00	70.1	43.7	43.3	47.6	45.3	46.5	2/8 23:00	70.8	39.0	38.2	43.2	40.3	41.5
2/6 21:00	70.4	43.5	43.3	47.4	45.2	46.6	2/9 0:00	67.5	38.9	38.3	45.6	40.2	41.5
2/6 22:00	71.0	43.4	43.2	47.4	45.2	46.5	2/9 1:00	68.2	38.5	38.2	38.6	40.1	41.5
2/6 23:00	70.0	43.8	43.2	49.5	45.1	46.5	2/9 2:00	68.1	38.5	38.1	39.9	40.1	41.4
2/7 0:00	68.8	43.5	43.2	43.4	45.1	46.5	2/9 3:00	68.0	38.4	38.1	43.3	40.0	41.3
2/7 1:00	70.1	43.5	43.1	46.8	45.0	46.4	2/9 4:00	69.5	38.0	38.0	43.0	39.9	41.2
2/7 2:00	70.4	43.5	43.1	47.5	44.9	46.4	2/9 5:00	70.6	38.5	37.9	43.0	39.9	41.1
2/7 3:00	70.4	43.2	43.0	47.1	44.9	46.3	2/9 6:00	67.6	38.5	37.9	45.3	39.8	41.1
2/7 4:00	72.7	43.2	42.9	49.7	44.8	46.2	2/9 7:00	66.7	38.1	37.8	45.0	39.7	41.0
2/7 5:00	70.4	43.2	42.8	47.3	44.7	46.2	2/9 8:00	66.5	38.0	37.7	39.7	39.7	40.8
2/7 6:00	70.1	43.0	42.7	46.9	44.6	46.0	2/9 9:00	66.1	37.9	37.7	43.3	39.6	40.7
2/7 7:00	71.5	42.7	42.6	46.8	44.4	45.7	2/9 10:00	64.6	37.9	37.6	45.0	39.5	40.7
2/7 8:00	71.4	42.9	42.4	49.1	44.3	45.7	2/9 11:00	69.5	38.2	37.5	42.8	39.4	40.6
2/7 9:00	68.6	42.6	42.3	41.9	44.1	45.6	2/9 12:00	67.1	38.2	37.5	45.0	39.4	40.5
2/7 10:00	69.0	42.4	42.1	43.3	43.9	45.4	2/9 13:00	67.4	37.7	37.4	45.0	39.3	40.5
2/7 11:00	70.1	42.2	42.0	46.8	43.8	45.3	2/9 14:00	67.2	37.7	37.3	38.7	39.3	40.4
2/7 12:00	70.0	41.7	41.9	46.3	43.7	45.2	2/9 15:00	66.7	37.6	37.3	42.9	39.2	40.3
2/7 13:00	71.5	41.8	41.6	46.2	43.5	45.0	2/9 16:00	66.3	37.3	37.4	42.5	39.1	40.3
2/7 14:00	69.1	42.1	41.4	48.5	43.3	44.9	2/9 17:00	67.9	37.2	37.1	42.5	39.1	40.1
2/7 15:00	67.6	41.6	41.3	41.5	43.2	44.7	2/9 18:00	66.8	37.7	37.0	42.6	39.1	40.1
2/7 16:00	68.5	41.4	41.2	42.3	43.1	44.5	2/9 19:00	65.9	37.0	37.1	42.9	39.0	40.1
2/7 17:00	67.7	41.6	41.0	48.1	43.0	44.5	2/9 20:00	67.9	36.9	37.0	42.8	38.8	39.9
2/7 18:00	67.3	41.2	40.9	41.1	42.8	44.3	2/9 21:00	67.9	37.5	36.8	42.6	38.7	39.9
2/7 19:00	67.8	41.0	40.8	42.5	42.7	44.2	2/9 22:00	64.8	37.2	36.8	45.1	38.7	39.8
2/7 20:00	67.3	40.9	40.7	45.7	42.6	44.1	2/9 23:00	65.3	37.0	36.8	43.0	38.6	39.8
2/7 21:00	67.6	40.8	40.6	45.6	42.4	43.9	2/10 0:00	66.1	37.0	36.8	38.7	38.5	39.7
2/7 22:00	69.1	40.4	40.4	45.0	42.4	43.8	2/10 1:00	66.8	36.9	36.7	39.1	38.5	39.6
2/7 23:00	69.4	40.5	40.3	45.0	42.2	43.6	2/10 2:00	68.6	36.5	36.7	41.9	38.4	39.5
2/8 0:00	65.4	40.5	40.2	47.0	42.1	43.6	2/10 3:00	68.7	37.1	36.5	42.0	38.4	39.5
2/8 1:00	66.3	40.4	40.1	41.1	42.0	43.5	2/10 4:00	66.2	36.9	36.5	45.0	38.3	39.4
2/8 2:00	65.8	40.3	40.0	45.0	41.9	43.3	2/10 5:00	66.3	36.6	36.4	44.6	38.2	39.3
2/8 3:00	66.2	39.9	39.9	44.4	41.8	43.3	2/10 6:00	67.0	36.5	36.4	37.9	38.2	39.3

\*There is a possibility that the numbers are not the same as the relevant parameters to the plant because the data above are the reference.

location mounting angle	the bottom head			support skirt junction			location mounting angle	the bottom head			support skirt junction		
	0 °	135 °	270 °	0 °	135 °	270 °		0 °	135 °	270 °	0 °	135 °	270 °
serial number	TE-2-3-69H1	TE-2-3-69H2	TE-2-3-69H3	TE-2-3-69F1	TE-2-3-69F2	TE-2-3-69F3	serial number	TE-2-3-69H1	TE-2-3-69H2	TE-2-3-69H3	TE-2-3-69F1	TE-2-3-69F2	TE-2-3-69F3
2/10 7:00	67.4	36.5	36.3	39.0	38.2	39.2	2/12 9:00	77.1	34.4	34.9	41.8	36.4	37.7
2/10 8:00	66.9	36.1	36.3	42.3	38.1	39.1	2/12 10:00	78.3	35.0	34.7	40.6	36.7	37.7
2/10 9:00	68.9	36.0	36.2	41.9	38.1	39.1	2/12 11:00	74.9	35.1	34.7	40.9	36.6	37.7
2/10 10:00	67.2	36.7	36.1	41.7	38.0	39.0	2/12 12:00	79.1	34.9	34.6	40.6	36.6	37.6
2/10 11:00	68.4	35.9	36.1	42.0	37.9	39.0	2/12 13:00	77.6	34.9	34.6	40.7	36.6	37.6
2/10 12:00	69.9	36.6	36.0	41.3	37.9	38.9	2/12 14:00	78.5	34.5	34.6	42.0	36.5	37.5
2/10 13:00	65.9	36.2	36.1	44.2	37.9	38.9	2/12 15:00	79.2	34.4	34.6	43.4	36.5	37.5
2/10 14:00	67.2	36.2	36.0	44.1	37.9	38.9	2/12 16:00	80.1	34.3	34.5	37.0	36.2	37.4
2/10 15:00	67.3	36.1	36.0	38.5	37.9	38.8	2/12 17:00	81.1	33.8	34.4	36.8	36.1	37.4
2/10 16:00	67.8	35.8	36.0	41.3	37.8	38.8	2/12 18:00	83.9	34.4	34.2	41.3	36.0	37.2
2/10 17:00	70.4	35.8	35.8	41.6	37.8	38.8	2/12 19:00	81.4	34.4	34.1	41.2	35.9	37.1
2/10 18:00	68.6	36.1	35.9	36.9	37.8	38.8	2/12 20:00	80.9	33.9	34.1	40.1	35.8	37.0
2/10 19:00	69.0	36.0	35.9	37.6	37.7	38.7	2/12 21:00	82.8	33.8	34.0	43.6	35.8	36.9
2/10 20:00	69.2	35.6	35.9	41.8	37.7	38.7	2/12 22:00	82.7	33.7	33.9	33.9	35.6	36.8
2/10 21:00	71.1	36.3	35.8	41.5	37.7	38.7	2/12 23:00	79.9	33.3	33.8	36.0	35.6	36.7
2/10 22:00	68.4	36.3	35.8	41.8	37.7	38.7	2/13 0:00	88.9	33.5	33.6	41.2	35.5	36.8
2/10 23:00	67.8	35.9	35.8	44.8	37.6	38.7	2/13 1:00	87.6	33.0	33.6	36.9	35.4	36.8
2/11 0:00	69.3	35.9	35.8	36.8	37.6	38.7	2/13 2:00	84.3	33.3	33.5	40.2	35.3	36.7
2/11 1:00	69.8	35.8	35.8	37.4	37.6	38.7	2/13 3:00	86.7	33.1	33.4	43.5	35.2	36.6
2/11 2:00	69.2	35.5	35.8	41.9	37.6	38.6	2/13 4:00	88.4	33.0	33.4	36.3	35.1	36.5
2/11 3:00	71.3	35.8	35.6	41.8	37.5	38.6	2/13 5:00	89.6	32.5	33.3	34.5	35.0	36.3
2/11 4:00	68.5	36.1	35.6	41	37.5	38.5	2/13 6:00	88.0	32.9	33.2	40.2	35.0	36.2
2/11 5:00	67.4	35.7	35.6	44.7	37.5	38.5	2/13 7:00	88.6	32.8	33.1	44.2	34.9	36.1
2/11 6:00	68.3	35.6	35.6	43.9	37.4	38.5	2/13 8:00	89.2	32.8	33.1	32.5	34.8	36.0
2/11 7:00	68.8	35.6	35.6	37.9	37.4	38.5	2/13 9:00	87.2	32.3	33.1	34.0	34.8	35.9
2/11 8:00	69.2	35.2	35.6	41.3	37.4	38.4	2/13 10:00	91.2	33.1	32.9	40.0	34.7	35.8
2/11 9:00	71.3	35.3	35.4	41.4	37.4	38.4	2/13 11:00	91.8	32.2	32.9	33.9	34.6	35.8
2/11 10:00	70.8	35.9	35.4	41.3	37.4	38.4	2/13 12:00	94.9	32.1	32.8	36.0	34.6	35.7
2/11 11:00	71.2	35.1	35.4	41.4	37.3	38.3	2/13 13:00	93.3	32.8	32.7	40.0	34.5	35.6
2/11 12:00	71.2	35.9	35.4	41.2	37.3	38.3	2/13 14:00	91.3	32.4	32.7	39.2	34.4	35.5
2/11 13:00	68.7	35.5	35.4	41.5	37.3	38.3	2/13 15:00	285.4	30.8	32.7	39.0	34.3	35.5
2/11 14:00	69.4	35.4	35.4	43.5	37.2	38.2	2/13 16:00	260.9	32.0	32.6	41.5	34.1	35.4
2/11 15:00	69.6	35.4	35.3	36.4	37.2	38.2	2/13 17:00	275.9	31.4	32.4	33.3	34.2	35.3
2/11 16:00	68.6	35.5	35.4	37.6	37.2	38.3	2/13 18:00	272.8	31.5	32.3	38.4	34.1	35.2
2/11 17:00	69.5	35.0	35.4	41.3	37.2	38.2	2/13 19:00	268.6	31.3	32.2	41.2	34.0	35.1
2/11 18:00	71.2	35.3	35.3	43.9	37.2	38.2	2/13 20:00	264.8	31.3	32.2	41.3	34.0	35.0
2/11 19:00	71.1	35.3	35.3	36.9	37.2	38.2	2/13 21:00	263.0	31.0	32.2	33.1	33.9	34.9
2/11 20:00	70.9	34.9	35.3	39.1	37.2	38.2	2/13 22:00	260.7	31.4	32.1	37.6	33.8	34.9
2/11 21:00	73.3	34.9	35.2	40.9	37.1	38.1	2/13 23:00	258.7	31.4	32.1	38.1	33.8	34.9
2/11 22:00	72.5	35.6	35.2	41.1	37.1	38.1	2/14 0:00	257.1	31.1	32.0	38.1	33.8	34.8
2/11 23:00	71.2	35.2	35.2	41.0	37.1	38.1	2/14 1:00	257.1	31.1	32.0	41.3	33.7	34.8
2/12 0:00	71.1	35.2	35.2	44.6	37.1	38.1	2/14 2:00	256.9	31.1	31.9	40.5	33.7	34.7
2/12 1:00	69.5	35.3	35.2	35.8	37.0	38.1	2/14 3:00	257.5	30.9	31.9	32.0	33.6	34.7
2/12 2:00	71.9	35.2	35.2	37.1	36.9	38.0	2/14 4:00	254.6	31.3	31.8	38.5	33.6	34.6
2/12 3:00	74.1	34.8	35.1	41.4	36.7	37.9	2/14 5:00	254.6	31.3	31.8	37.1	33.6	34.6
2/12 4:00	75.7	35.4	35.0	41.1	36.6	37.9	2/14 6:00	249.2	30.9	31.8	37.6	33.5	34.6
2/12 5:00	74.0	35.4	35.0	41.3	36.6	37.9	2/14 7:00	248.6	30.9	31.7	39.7	33.5	34.5
2/12 6:00	74.4	34.9	35.0	43.4	36.5	37.8	2/14 8:00	248.8	30.8	31.7	40.8	33.4	34.5
2/12 7:00	76.3	34.8	34.9	43.3	36.4	37.9	2/14 9:00	249.4	30.6	31.7	40.0	33.4	34.5
2/12 8:00	74.5	34.8	34.9	37.3	36.4	37.7	2/14 10:00	250.3	31.2	31.6	33.6	33.4	34.4

\*There is a possibility that the numbers are not the same as the relevant parameters to the plant because the data above are the reference.

location mounting angle	the bottom head			support skirt junction		
	0 °	135 °	270 °	0 °	135 °	270 °
serial number	TE-2-3-69H1	TE-2-3-69H2	TE-2-3-69H3	TE-2-3-69F1	TE-2-3-69F2	TE-2-3-69F3
2/14 11:00	250.1	30.4	31.6	38.2	33.3	34.3
2/14 12:00	251.9	30.5	31.7	31.8	33.4	34.4
2/14 13:00	249.7	31.3	31.6	37.4	33.4	34.4
2/14 14:00	248.3	30.7	31.6	37.5	33.3	34.4
2/14 15:00	248.4	30.7	31.5	36.3	33.2	34.3
2/14 16:00	248.1	30.7	31.5	39.5	33.3	34.3
2/14 17:00	248.0	30.3	31.5	29.7	33.2	34.3
2/14 18:00	247.9	30.7	31.4	36.1	33.2	34.3
2/14 19:00	246.4	30.7	31.4	36.5	33.1	34.2
2/14 20:00	247.1	30.3	31.5	39.2	33.1	34.3
2/14 21:00	251.0	30.4	31.4	30.2	33.1	34.2
2/14 22:00	248.9	31.0	31.4	31.2	33.1	34.2
2/14 23:00	248.3	31.0	31.4	36.8	33.0	34.2
2/15 0:00	247.0	30.6	31.4	36.4	33.0	34.2
2/15 1:00	245.7	30.6	31.4	36.6	33.0	34.1
2/15 2:00	245.0	30.6	31.3	39.5	33.0	34.1
2/15 3:00	243.9	30.4	31.3	35.6	32.9	34.1
2/15 4:00	240.3	30.4	31.3	30.3	32.9	34.0
2/15 5:00	237.4	30.8	31.2	36.6	32.9	34.1
2/15 6:00	230.7	30.4	31.2	36.6	32.9	34.1
2/15 7:00	229.5	30.4	31.3	35.4	32.8	34.0
2/15 8:00	228.9	30.3	31.2	38.8	32.8	34.0
2/15 9:00	234.8	30.0	31.2	39.0	32.7	33.9
2/15 10:00	228.8	30.5	31.1	30.4	32.7	33.9

\*There is a possibility that the numbers are not the same as the relevant parameters to the plant because the data above are the reference.