

Results of Measurement of Dose Equivalent Rate at Fukushima Daini Nuclear Power Station Unit 3

Atmosphere Dose Equivalent Rate  
 Measured Atmosphere Dose Equivalent Rate in D/W, geometric mean value at each floor

(Unit: mSv/h)

	Last Periodical Inspection (Feb. 25, 2010)	Shutdown This Time (Feb. 14, 2012)
OP40m	0.03	0.03
OP37m	0.03	0.06
OP32m	0.05	0.08
OP28m	0.75	0.73
OP22m	0.42	0.31
OP18m	0.11	0.10

