

Fukushima Daiichi NPS Unit 2

The temperature of the lower part of the reactor pressure vessel (upper part of the bottom head/upper part of support skirt junction) (Reference)

location mounting angle serial number	the bottom head						support skirt junction						
	0°		135°		270°		0°		135°		270°		
	TE-2-3-69H1	TE-2-3-69H2	TE-2-3-69H3	TE-2-3-69F1	TE-2-3-69F2	TE-2-3-69F3	TE-2-3-69H1	TE-2-3-69H2	TE-2-3-69H3	TE-2-3-69F1	TE-2-3-69F2	TE-2-3-69F3	
2/1 1:00	50.7	44.5	43.9	50.4	45.8	46.6	2/4 3:00	63.2	45.2	45.0	50.1	47.0	48.1
2/1 4:00	51.1	44.7	44.0	48.4	45.8	46.6	2/4 4:00	64.1	45.3	45.0	50.1	47.0	48.0
2/1 7:00	50.9	44.4	43.9	51.0	45.8	46.6	2/4 5:00	64.6	45.3	45.0	49.8	47.1	48.0
2/1 10:00	52.9	44.5	43.9	48.8	45.8	46.6	2/4 6:00	64.7	45.2	45.1	53.2	47.1	48.0
2/1 11:00	50.2	44.6	44.0	48.4	45.8	46.7	2/4 7:00	66.8	45.1	45.1	47.6	47.0	48.1
2/1 12:00	51.0	44.4	43.9	48.3	45.8	46.6	2/4 8:00	64.7	45.3	45.1	49.7	47.1	48.0
2/1 13:00	51.3	44.4	43.9	50.8	45.7	46.6	2/4 9:00	63.7	45.3	45.1	50.2	47.0	48.1
2/1 14:00	51.3	44.4	43.9	42.4	45.8	46.6	2/4 10:00	66.5	45.1	45.2	51.8	47.0	48.1
2/1 15:00	52.8	44.1	43.9	47.9	45.8	46.5	2/4 11:00	66.3	45.2	45.1	52.1	47.0	48.1
2/1 16:00	51.9	44.5	43.9	48.7	45.8	46.6	2/4 12:00	64.1	45.4	45.1	50.1	47.0	48.2
2/1 17:00	50.3	44.4	43.9	48.4	45.8	46.7	2/4 13:00	65.2	45.4	45.1	49.7	47.0	48.2
2/1 18:00	51.4	44.4	43.9	49.1	45.8	46.6	2/4 14:00	65.2	45.5	45.2	49.5	47.1	48.1
2/1 19:00	51.7	44.5	44.0	51.7	45.8	46.7	2/4 15:00	66.6	45.3	45.2	51.7	47.0	48.0
2/1 22:00	52.3	44.7	44.0	48.7	45.9	46.7	2/4 16:00	67.2	45.5	45.2	44.1	47.0	48.1
2/2 1:00	52.2	44.5	44.0	51.3	46.0	46.9	2/4 17:00	64.8	45.7	45.2	46.8	47.1	48.3
2/2 4:00	53.4	44.6	43.9	49.0	45.9	46.7	2/4 18:00	64.8	45.6	45.2	50.0	47.0	48.2
2/2 7:00	51.7	44.6	44.1	49.0	46.0	47.0	2/4 19:00	65.2	45.6	45.3	49.6	47.0	48.2
2/2 10:00	55.0	44.6	44.1	46.4	46.1	46.9	2/4 20:00	65.6	45.6	45.2	49.3	47.0	48.2
2/2 11:00	52.6	44.8	44.1	49.1	46.1	47.0	2/4 21:00	65.4	45.6	45.2	49.9	47.1	48.2
2/2 12:00	52.2	44.7	44.2	49.1	46.2	47.1	2/4 22:00	65.8	45.7	45.3	49.7	47.1	48.3
2/2 13:00	54.0	44.5	44.2	49.1	46.2	47.0	2/4 23:00	66.2	45.6	45.3	49.3	47.1	48.3
2/2 14:00	54.4	44.4	44.2	51.1	46.2	47.1	2/5 0:00	67.8	45.4	45.2	51.9	47.1	48.4
2/2 15:00	55.7	44.3	44.2	44.3	46.2	47.0	2/5 1:00	69.2	45.7	45.3	46.4	47.1	48.2
2/2 16:00	56.4	44.6	44.2	45.5	46.2	47.0	2/5 2:00	66.4	45.9	45.3	45.8	47.1	48.4
2/2 19:00	56.8	44.8	44.3	48.0	46.4	47.1	2/5 3:00	66.3	45.7	45.3	49.6	47.1	48.4
2/2 22:00	55.3	44.7	44.3	49.2	46.4	47.2	2/5 4:00	67.1	45.6	45.3	49.3	47.1	48.4
2/3 1:00	55.3	44.7	44.3	49.2	46.4	47.2	2/5 5:00	67.4	45.6	45.2	49.2	47.1	48.4
2/3 4:00	56.9	44.7	44.4	49.2	46.5	47.3	2/5 6:00	67.7	45.3	45.2	51.9	47.0	48.3
2/3 7:00	59.5	44.6	44.4	44.8	46.6	47.3	2/5 7:00	70.4	45.5	45.2	51.4	47.0	48.2
2/3 10:00	58.6	45.0	44.4	50.0	46.6	47.4	2/5 8:00	68.2	45.7	45.2	46.3	47.0	48.4
2/3 11:00	58.2	44.8	44.5	50.6	46.6	47.4	2/5 9:00	67.4	45.5	45.1	50.0	47.0	48.3
2/3 12:00	61.5	44.6	44.6	51.4	46.7	47.6	2/5 10:00	68.8	45.4	45.1	49.6	47.0	48.2
2/3 13:00	62.7	44.5	44.5	44.8	46.7	47.4	2/5 11:00	69.0	45.6	45.0	45.9	46.9	48.2
2/3 14:00	61.2	44.7	44.5	51.0	46.8	47.5	2/5 12:00	67.7	45.3	45.0	49.5	46.9	48.0
2/3 15:00	60.9	44.8	44.5	49.7	46.7	47.5	2/5 13:00	68.7	45.3	45.0	49.2	46.8	47.9
2/3 16:00	63.5	44.8	44.5	44.9	46.7	47.5	2/5 14:00	68.9	45.2	44.9	48.9	46.8	47.9
2/3 17:00	61.3	45.0	44.6	50.0	46.7	47.7	2/5 15:00	70.4	45.0	44.8	51.7	46.8	47.9
2/3 18:00	60.9	44.9	44.6	50.0	46.8	47.7	2/5 16:00	71.7	45.3	44.8	50.9	46.7	47.8
2/3 19:00	62.9	44.6	44.6	43.8	46.7	47.6	2/5 17:00	69.1	45.3	44.8	45.6	46.7	47.9
2/3 20:00	61.7	45.0	44.6	50.0	46.8	47.7	2/5 18:00	68.3	45.1	44.7	46.0	46.6	47.9
2/3 21:00	61.2	44.9	44.7	49.8	46.8	47.7	2/5 19:00	69.8	45.0	44.7	49.0	46.6	47.8
2/3 22:00	62.1	44.9	44.7	49.8	46.8	47.7	2/5 20:00	70.1	45.0	44.7	48.8	46.6	47.8
2/3 23:00	62.5	45.0	44.8	52.3	46.9	47.9	2/5 21:00	71.0	44.8	44.6	50.0	46.5	47.7
2/4 0:00	63.2	44.8	44.8	52.3	47.0	47.9	2/5 22:00	72.6	45.0	44.6	50.9	46.5	47.7
2/4 1:00	65.2	44.9	44.9	44.4	47.0	47.8	2/5 23:00	70.6	45.0	44.6	44.4	46.4	47.7
2/4 2:00	64.1	45.3	45.0	46.1	47.0	48.0	2/6 0:00	70.0	44.9	44.5	45.2	46.4	47.8

\*There is a possibility that the numbers are not the same as the relevant parameters to the plant because the data above are the reference.

location mounting angle	the bottom head			support skirt junction			location mounting angle	the bottom head			support skirt junction		
	0°	135°	270°	0°	135°	270°		0°	135°	270°	0°	135°	270°
serial number	TE-2-3-69H1	TE-2-3-69H2	TE-2-3-69H3	TE-2-3-69F1	TE-2-3-69F2	TE-2-3-69F3	serial number	TE-2-3-69H1	TE-2-3-69H2	TE-2-3-69H3	TE-2-3-69F1	TE-2-3-69F2	TE-2-3-69F3
2/6 1:00	70.6	44.8	44.5	48.8	46.4	47.6	2/8 4:00	67.4	39.8	39.8	44.4	41.7	43.1
2/6 2:00	71.1	44.8	44.5	48.7	46.3	47.6	2/8 5:00	67.4	40.3	39.6	47.4	41.6	43.0
2/6 3:00	70.3	44.6	44.4	48.5	46.3	47.5	2/8 6:00	65.0	40.0	39.6	46.3	41.5	43.0
2/6 4:00	73.1	44.8	44.4	51.0	46.3	47.6	2/8 7:00	66.1	39.9	39.6	40.6	41.5	42.8
2/6 5:00	70.6	44.7	44.3	48.5	46.2	47.5	2/8 8:00	66.1	39.8	39.4	44.4	41.3	42.8
2/6 6:00	71.0	44.4	44.2	48.4	46.1	47.5	2/8 9:00	66.2	39.6	39.4	44.3	41.2	42.6
2/6 7:00	73.3	44.6	44.2	50.8	46.1	47.4	2/8 10:00	68.0	39.3	39.2	44.0	41.2	42.5
2/6 8:00	71.2	44.7	44.1	44.1	46.0	47.5	2/8 11:00	66.0	39.5	39.2	41.7	41.1	42.4
2/6 9:00	69.6	44.4	44.1	44.5	46.0	47.3	2/8 12:00	66.1	39.7	39.1	46.3	41.0	42.4
2/6 10:00	70.5	44.3	44.0	48.6	45.9	47.1	2/8 13:00	66.2	39.4	39.0	39.9	40.9	42.3
2/6 11:00	70.6	44.1	43.9	48.2	45.8	47.1	2/8 14:00	66.5	39.3	38.9	40.7	40.9	42.2
2/6 12:00	72.0	43.9	43.8	48.0	45.7	47.0	2/8 15:00	66.3	38.9	38.9	43.8	40.7	42.1
2/6 13:00	70.7	44.1	43.8	48.0	45.7	47.0	2/8 16:00	68.0	38.7	38.8	43.6	40.7	42.1
2/6 14:00	70.7	44.0	43.7	47.9	45.6	46.9	2/8 17:00	66.4	39.4	38.7	46.1	40.6	42.0
2/6 15:00	70.8	43.8	43.6	47.8	45.6	46.8	2/8 18:00	64.1	39.0	38.6	45.7	40.6	42.0
2/6 16:00	71.6	43.9	43.6	50.4	45.5	46.7	2/8 19:00	64.7	39.0	38.6	38.8	40.5	41.9
2/6 17:00	69.5	44.1	43.5	49.2	45.4	46.9	2/8 20:00	65.4	38.9	38.5	41.7	40.4	41.7
2/6 18:00	68.5	43.9	43.5	43.7	45.4	46.7	2/8 21:00	66.3	38.6	38.5	43.5	40.4	41.7
2/6 19:00	69.3	43.8	43.4	48.0	45.3	46.6	2/8 22:00	67.9	38.4	38.5	43.3	40.3	41.6
2/6 20:00	70.1	43.7	43.3	47.6	45.3	46.5	2/8 23:00	70.8	39.0	38.2	43.2	40.3	41.5
2/6 21:00	70.4	43.5	43.3	47.4	45.2	46.6	2/9 0:00	67.5	38.9	38.3	45.6	40.2	41.5
2/6 22:00	71.0	43.4	43.2	47.4	45.2	46.5	2/9 1:00	68.2	38.5	38.2	38.6	40.1	41.5
2/6 23:00	70.0	43.8	43.2	49.5	45.1	46.5	2/9 2:00	68.1	38.5	38.1	39.9	40.1	41.4
2/7 0:00	68.8	43.5	43.2	43.4	45.1	46.5	2/9 3:00	68.0	38.4	38.1	43.3	40.0	41.3
2/7 1:00	70.1	43.5	43.1	46.8	45.0	46.4	2/9 4:00	69.5	38.0	38.0	43.0	39.9	41.2
2/7 2:00	70.4	43.5	43.1	47.5	44.9	46.4	2/9 5:00	70.6	38.5	37.9	43.0	39.9	41.1
2/7 3:00	70.4	43.2	43.0	47.1	44.9	46.3	2/9 6:00	67.6	38.5	37.9	45.3	39.8	41.1
2/7 4:00	72.7	43.2	42.9	49.7	44.8	46.2	2/9 7:00	66.7	38.1	37.8	45.0	39.7	41.0
2/7 5:00	70.4	43.2	42.8	47.3	44.7	46.2	2/9 8:00	66.5	38.0	37.7	39.7	39.7	40.8
2/7 6:00	70.1	43.0	42.7	46.9	44.6	46.0	2/9 9:00	66.1	37.9	37.7	43.3	39.6	40.7
2/7 7:00	71.5	42.7	42.6	46.8	44.4	45.7	2/9 10:00	64.6	37.9	37.6	45.0	39.5	40.7
2/7 8:00	71.4	42.9	42.4	49.1	44.3	45.7	2/9 11:00	69.5	38.2	37.5	42.8	39.4	40.6
2/7 9:00	68.6	42.6	42.3	41.9	44.1	45.6	2/9 12:00	67.1	38.2	37.5	45.0	39.4	40.5
2/7 10:00	69.0	42.4	42.1	43.3	43.9	45.4	2/9 13:00	67.4	37.7	37.4	45.0	39.3	40.5
2/7 11:00	70.1	42.2	42.0	46.8	43.8	45.3	2/9 14:00	67.2	37.7	37.3	38.7	39.3	40.4
2/7 12:00	70.0	41.7	41.9	46.3	43.7	45.2	2/9 15:00	66.7	37.6	37.3	42.9	39.2	40.3
2/7 13:00	71.5	41.8	41.6	46.2	43.5	45.0	2/9 16:00	66.3	37.3	37.4	42.5	39.1	40.3
2/7 14:00	69.1	42.1	41.4	48.5	43.3	44.9	2/9 17:00	67.9	37.2	37.1	42.5	39.1	40.1
2/7 15:00	67.6	41.6	41.3	41.5	43.2	44.7	2/9 18:00	66.8	37.7	37.0	42.6	39.1	40.1
2/7 16:00	68.5	41.4	41.2	42.3	43.1	44.5	2/9 19:00	65.9	37.0	37.1	42.9	39.0	40.1
2/7 17:00	67.7	41.6	41.0	48.1	43.0	44.5	2/9 20:00	67.9	36.9	37.0	42.8	38.8	39.9
2/7 18:00	67.3	41.2	40.9	41.1	42.8	44.3	2/9 21:00	67.9	37.5	36.8	42.6	38.7	39.9
2/7 19:00	67.8	41.0	40.8	42.5	42.7	44.2	2/9 22:00	64.8	37.2	36.8	45.1	38.7	39.8
2/7 20:00	67.3	40.9	40.7	45.7	42.6	44.1	2/9 23:00	65.3	37.0	36.8	43.0	38.6	39.8
2/7 21:00	67.6	40.8	40.6	45.6	42.4	43.9	2/10 0:00	66.1	37.0	36.8	38.7	38.5	39.7
2/7 22:00	69.1	40.4	40.4	45.0	42.4	43.8	2/10 1:00	66.8	36.9	36.7	39.1	38.5	39.6
2/7 23:00	69.4	40.5	40.3	45.0	42.2	43.6	2/10 2:00	68.6	36.5	36.7	41.9	38.4	39.5
2/8 0:00	65.4	40.5	40.2	47.0	42.1	43.6	2/10 3:00	68.7	37.1	36.5	42.0	38.4	39.5
2/8 1:00	66.3	40.4	40.1	41.1	42.0	43.5	2/10 4:00	66.2	36.9	36.5	45.0	38.3	39.4
2/8 2:00	65.8	40.3	40.0	45.0	41.9	43.3	2/10 5:00	66.3	36.6	36.4	44.6	38.2	39.3
2/8 3:00	66.2	39.9	39.9	44.4	41.8	43.3	2/10 6:00	67.0	36.5	36.4	37.9	38.2	39.3

\*There is a possibility that the numbers are not the same as the relevant parameters to the plant because the data above are the reference.

location mounting angle	the bottom head			support skirt junction			location mounting angle	the bottom head			support skirt junction		
	0°	135°	270°	0°	135°	270°		0°	135°	270°	0°	135°	270°
serial number	TE-2-3-69H1	TE-2-3-69H2	TE-2-3-69H3	TE-2-3-69F1	TE-2-3-69F2	TE-2-3-69F3	serial number	TE-2-3-69H1	TE-2-3-69H2	TE-2-3-69H3	TE-2-3-69F1	TE-2-3-69F2	TE-2-3-69F3
2/10 7:00	67.4	36.5	36.3	39.0	38.2	39.2	2/12 9:00	77.1	34.4	34.9	41.8	36.4	37.7
2/10 8:00	66.9	36.1	36.3	42.3	38.1	39.1	2/12 10:00	78.3	35.0	34.7	40.6	36.7	37.7
2/10 9:00	68.9	36.0	36.2	41.9	38.1	39.1	2/12 11:00	74.9	35.1	34.7	40.9	36.6	37.7
2/10 10:00	67.2	36.7	36.1	41.7	38.0	39.0	2/12 12:00	79.1	34.9	34.6	40.6	36.6	37.6
2/10 11:00	68.4	35.9	36.1	42.0	37.9	39.0	2/12 13:00	77.6	34.9	34.6	40.7	36.6	37.6
2/10 12:00	69.9	36.6	36.0	41.3	37.9	38.9	2/12 14:00	78.5	34.5	34.6	42.0	36.5	37.5
2/10 13:00	65.9	36.2	36.1	44.2	37.9	38.9	2/12 15:00	79.2	34.4	34.6	43.4	36.5	37.5
2/10 14:00	67.2	36.2	36.0	44.1	37.9	38.9	2/12 16:00	80.1	34.3	34.5	37.0	36.2	37.4
2/10 15:00	67.3	36.1	36.0	38.5	37.9	38.8	2/12 17:00	81.1	33.8	34.4	36.8	36.1	37.4
2/10 16:00	67.8	35.8	36.0	41.3	37.8	38.8	2/12 18:00	83.9	34.4	34.2	41.3	36.0	37.2
2/10 17:00	70.4	35.8	35.8	41.6	37.8	38.8	2/12 19:00	81.4	34.4	34.1	41.2	35.9	37.1
2/10 18:00	68.6	36.1	35.9	36.9	37.8	38.8	2/12 20:00	80.9	33.9	34.1	40.1	35.8	37.0
2/10 19:00	69.0	36.0	35.9	37.6	37.7	38.7	2/12 21:00	82.8	33.8	34.0	43.6	35.8	36.9
2/10 20:00	69.2	35.6	35.9	41.8	37.7	38.7	2/12 22:00	82.7	33.7	33.9	33.9	35.6	36.8
2/10 21:00	71.1	36.3	35.8	41.5	37.7	38.7	2/12 23:00	79.9	33.3	33.8	36.0	35.6	36.7
2/10 22:00	68.4	36.3	35.8	41.8	37.7	38.7	2/13 0:00	88.9	33.5	33.6	41.2	35.5	36.8
2/10 23:00	67.8	35.9	35.8	44.8	37.6	38.7	2/13 1:00	87.6	33.0	33.6	36.9	35.4	36.8
2/11 0:00	69.3	35.9	35.8	36.8	37.6	38.7	2/13 2:00	84.3	33.3	33.5	40.2	35.3	36.7
2/11 1:00	69.8	35.8	35.8	37.4	37.6	38.7	2/13 3:00	86.7	33.1	33.4	43.5	35.2	36.6
2/11 2:00	69.2	35.5	35.8	41.9	37.6	38.6	2/13 4:00	88.4	33.0	33.4	36.3	35.1	36.5
2/11 3:00	71.3	35.8	35.6	41.8	37.5	38.6	2/13 5:00	89.6	32.5	33.3	34.5	35.0	36.3
2/11 4:00	68.5	36.1	35.6	41	37.5	38.5	2/13 6:00	88.0	32.9	33.2	40.2	35.0	36.2
2/11 5:00	67.4	35.7	35.6	44.7	37.5	38.5	2/13 7:00	88.6	32.8	33.1	44.2	34.9	36.1
2/11 6:00	68.3	35.6	35.6	43.9	37.4	38.5	2/13 8:00	89.2	32.8	33.1	32.5	34.8	36.0
2/11 7:00	68.8	35.6	35.6	37.9	37.4	38.5	2/13 9:00	87.2	32.3	33.1	34.0	34.8	35.9
2/11 8:00	69.2	35.2	35.6	41.3	37.4	38.4	2/13 10:00	91.2	33.1	32.9	40.0	34.7	35.8
2/11 9:00	71.3	35.3	35.4	41.4	37.4	38.4	2/13 11:00	91.8	32.2	32.9	33.9	34.6	35.8
2/11 10:00	70.8	35.9	35.4	41.3	37.4	38.4	2/13 12:00	94.9	32.1	32.8	36.0	34.6	35.7
2/11 11:00	71.2	35.1	35.4	41.4	37.3	38.3	2/13 13:00	93.3	32.8	32.7	40.0	34.5	35.6
2/11 12:00	71.2	35.9	35.4	41.2	37.3	38.3	2/13 14:00	91.3	32.4	32.7	39.2	34.4	35.5
2/11 13:00	68.7	35.5	35.4	41.5	37.3	38.3	2/13 15:00	285.4	30.8	32.7	39.0	34.3	35.5
2/11 14:00	69.4	35.4	35.4	43.5	37.2	38.2	2/13 16:00	260.9	32.0	32.6	41.5	34.1	35.4
2/11 15:00	69.6	35.4	35.3	36.4	37.2	38.2	2/13 17:00	275.9	31.4	32.4	33.3	34.2	35.3
2/11 16:00	68.6	35.5	35.4	37.6	37.2	38.3	2/13 18:00	272.8	31.5	32.3	38.4	34.1	35.2
2/11 17:00	69.5	35.0	35.4	41.3	37.2	38.2	2/13 19:00	268.6	31.3	32.2	41.2	34.0	35.1
2/11 18:00	71.2	35.3	35.3	43.9	37.2	38.2	2/13 20:00	264.8	31.3	32.2	41.3	34.0	35.0
2/11 19:00	71.1	35.3	35.3	36.9	37.2	38.2	2/13 21:00	263.0	31.0	32.2	33.1	33.9	34.9
2/11 20:00	70.9	34.9	35.3	39.1	37.2	38.2	2/13 22:00	260.7	31.4	32.1	37.6	33.8	34.9
2/11 21:00	73.3	34.9	35.2	40.9	37.1	38.1	2/13 23:00	258.7	31.4	32.1	38.1	33.8	34.9
2/11 22:00	72.5	35.6	35.2	41.1	37.1	38.1	2/14 0:00	257.1	31.1	32.0	38.1	33.8	34.8
2/11 23:00	71.2	35.2	35.2	41.0	37.1	38.1	2/14 1:00	257.1	31.1	32.0	41.3	33.7	34.8
2/12 0:00	71.1	35.2	35.2	44.6	37.1	38.1	2/14 2:00	256.9	31.1	31.9	40.5	33.7	34.7
2/12 1:00	69.5	35.3	35.2	35.8	37.0	38.1	2/14 3:00	257.5	30.9	31.9	32.0	33.6	34.7
2/12 2:00	71.9	35.2	35.2	37.1	36.9	38.0	2/14 4:00	254.6	31.3	31.8	38.5	33.6	34.6
2/12 3:00	74.1	34.8	35.1	41.4	36.7	37.9	2/14 5:00	254.6	31.3	31.8	37.1	33.6	34.6
2/12 4:00	75.7	35.4	35.0	41.1	36.6	37.9	2/14 6:00	249.2	30.9	31.8	37.6	33.5	34.6
2/12 5:00	74.0	35.4	35.0	41.3	36.6	37.9	2/14 7:00	248.6	30.9	31.7	39.7	33.5	34.5
2/12 6:00	74.4	34.9	35.0	43.4	36.5	37.8	2/14 8:00	248.8	30.8	31.7	40.8	33.4	34.5
2/12 7:00	76.3	34.8	34.9	43.3	36.4	37.9	2/14 9:00	249.4	30.6	31.7	40.0	33.4	34.5
2/12 8:00	74.5	34.8	34.9	37.3	36.4	37.7	2/14 10:00	250.3	31.2	31.6	33.6	33.4	34.4

\*There is a possibility that the numbers are not the same as the relevant parameters to the plant because the data above are the reference.

location mounting angle	the bottom head			support skirt junction			location mounting angle	the bottom head			support skirt junction		
	0°	135°	270°	0°	135°	270°		0°	135°	270°	0°	135°	270°
serial number	TE-2-3-69H1	TE-2-3-69H2	TE-2-3-69H3	TE-2-3-69F1	TE-2-3-69F2	TE-2-3-69F3	serial number	TE-2-3-69H1	TE-2-3-69H2	TE-2-3-69H3	TE-2-3-69F1	TE-2-3-69F2	TE-2-3-69F3
2/14 11:00	250.1	30.4	31.6	38.2	33.3	34.3	2/16 13:00	4.9	31.2	30.8	37.0	32.2	33.9
2/14 12:00	251.9	30.5	31.7	31.8	33.4	34.4	2/16 14:00	3.9	31.2	30.8	37.0	32.2	33.9
2/14 13:00	249.7	31.3	31.6	37.4	33.4	34.4	2/16 15:00	3.0	31.1	30.7	41.2	32.1	33.9
2/14 14:00	248.3	30.7	31.6	37.5	33.3	34.4	2/16 16:00	2.8	31.1	30.7	35.1	32.2	33.9
2/14 15:00	248.4	30.7	31.5	36.3	33.2	34.3	2/16 17:00	2.5	31.1	30.7	29.1	32.1	33.9
2/14 16:00	248.1	30.7	31.5	39.5	33.3	34.3							
2/14 17:00	248.0	30.3	31.5	29.7	33.2	34.3							
2/14 18:00	247.9	30.7	31.4	36.1	33.2	34.3							
2/14 19:00	246.4	30.7	31.4	36.5	33.1	34.2							
2/14 20:00	247.1	30.3	31.5	39.2	33.1	34.3							
2/14 21:00	251.0	30.4	31.4	30.2	33.1	34.2							
2/14 22:00	248.9	31.0	31.4	31.2	33.1	34.2							
2/14 23:00	248.3	31.0	31.4	36.8	33.0	34.2							
2/15 0:00	247.0	30.6	31.4	36.4	33.0	34.2							
2/15 1:00	245.7	30.6	31.4	36.6	33.0	34.1							
2/15 2:00	245.0	30.6	31.3	39.5	33.0	34.1							
2/15 3:00	243.9	30.4	31.3	35.6	32.9	34.1							
2/15 4:00	240.3	30.4	31.3	30.3	32.9	34.0							
2/15 5:00	237.4	30.8	31.2	36.6	32.9	34.1							
2/15 6:00	230.7	30.4	31.2	36.6	32.9	34.1							
2/15 7:00	229.5	30.4	31.3	35.4	32.8	34.0							
2/15 8:00	228.9	30.3	31.2	38.8	32.8	34.0							
2/15 9:00	234.8	30.0	31.2	39.0	32.7	33.9							
2/15 10:00	228.8	30.5	31.1	30.4	32.7	33.9							
2/15 11:00	224.6	30.2	31.2	39.3	32.7	33.9							
2/15 12:00	224.5	29.9	31.1	29.0	32.7	33.9							
2/15 13:00	225.8	30.4	31.1	30.1	32.6	33.9							
2/15 14:00	221.6	30.1	31.1	36.0	32.6	34.1							
2/15 15:00	219.3	30.1	31.1	35.6	32.6	34.0							
2/15 16:00	219.4	30.0	31.1	36.3	32.6	34.0							
2/15 17:00	217.9	29.8	31.1	37.8	32.6	34.0							
2/15 18:00	220.5	30.0	31.1	35.9	32.5	34.1							
2/15 19:00	218.4	30.0	31.0	36.1	32.6	34.1							
2/15 20:00	219.1	30.0	31.0	34.6	32.6	34.0							
2/15 21:00	220.6	29.7	31.0	38.4	32.5	34.0							
2/15 22:00	219.7	29.7	31.0	28.2	32.5	34.0							
2/15 23:00	222.1	30.2	31.0	30.3	32.5	34.0							
2/16 0:00	222.6	30.0	31.0	35.5	32.5	34.0							
2/16 1:00	224.1	29.8	31.0	36.2	32.5	34.0							
2/16 2:00	220.2	29.8	30.9	36.1	32.4	33.9							
2/16 3:00	221.3	29.6	30.9	40.5	32.4	34.0							
2/16 4:00	220.9	29.6	30.9	39.8	32.4	34.0							
2/16 5:00	220.3	30.1	30.9	30.2	32.3	34.0							
2/16 6:00	222.2	29.8	30.9	37.8	32.3	34.0							
2/16 7:00	221.3	29.8	30.9	37.5	32.3	34.0							
2/16 8:00	220.7	29.7	30.8	38.1	32.3	33.9							
2/16 9:00	219.5	29.7	30.8	40.9	32.3	33.9							
2/16 10:00	188.8	29.8	30.8	40.9	32.3	33.9							
2/16 11:00	9.1	31.5	30.8	30.6	32.2	33.9							
2/16 12:00	6.2	31.4	30.8	29.9	32.2	33.9							

\*There is a possibility that the numbers are not the same as the relevant parameters to the plant because the data above are the reference.