

Temperature of the RPV Bottom at Unit 2, Fukushima Daiichi (1F) NPS

Date & Time	Temperature of the RPV bottom (upper bottom head) at Unit 2, Fukushima Daiichi (1F) /		
	TE-2-3-69H1 (0 °)	TE-2-3-69H2 (135 °)	TE-2-3-69H3 (270 °)
2/1 23:00	52.0	44.5	43.9
2/2 5:00	52.4	44.5	43.9
2/2 11:00	52.9	44.6	44.1
2/2 17:00	54.6	44.6	44.2
2/2 23:00	55.7	44.7	44.3
2/3 5:00	57.4	44.8	44.4
2/3 11:00	58.0	44.8	44.5
2/3 17:00	61.0	44.8	44.6
2/3 23:00	62.6	45.0	44.8
2/4 5:00	64.5	45.3	45.0
2/4 11:00	64.8	45.2	45.1
2/4 17:00	65.1	45.7	45.2
2/4 23:00	66.1	45.6	45.3
2/5 5:00	67.4	45.6	45.2
2/5 11:00	68.6	45.6	45.0
2/5 17:00	69.4	45.3	44.8
2/5 23:00	70.3	44.9	44.6
2/6 5:00	70.6	44.7	44.3
2/6 11:00	71.0	44.1	43.9
2/6 17:00	69.2	43.9	43.5
2/6 23:00	69.9	43.6	43.2
2/7 5:00	72.2	43.1	42.8
2/7 11:00	69.6	42.2	42.0
2/7 17:00	68.5	41.3	41.0
2/7 23:00	67.4	40.6	40.3
2/8 5:00	66.7	40.0	39.7
2/8 11:00	66.0	39.5	39.2
2/8 17:00	65.4	39.1	38.7
2/8 23:00	68.1	38.7	38.3

Date & Time	Temperature of the RPV bottom (upper bottom head) at Unit 2, Fukushima Daiichi (1F) /		
	TE-2-3-69H1 (0 °)	TE-2-3-69H2 (135 °)	TE-2-3-69H3 (270 °)
2/9 5:00	67.9	38.2	37.9
2/9 11:00	66.8	37.8	37.6
2/9 17:00	65.6	37.5	37.2
2/9 23:00	65.8	36.9	36.8
2/10 5:00	66.7	36.3	36.5
2/10 11:00	68.0	36.6	36.0
2/10 17:00	67.5	36.5	35.9
2/10 23:00	69.5	36.3	35.7
2/11 5:00	68.5	36.1	35.6
2/11 11:00	70.0	35.9	35.4
2/11 17:00	69.5	35.8	35.3
2/11 23:00	74.9	35.6	35.1
2/12 5:00	75.4	35.4	35.0
2/12 11:00	75.4	34.3	34.8
2/12 17:00	81.5	34.6	34.3
2/12 23:00	81.0	33.8	33.8
2/13 5:00	89.6	33.4	33.2
2/13 11:00	93.7	33.0	32.8
2/13 17:00	276.4 ¹	31.9	32.4
2/13 23:00	259.0 ¹	31.4	32.1
2/14 5:00	255.2 ¹	31.3	31.8
2/14 11:00	251.2 ¹	31.0	31.6
2/14 17:00	248.9 ¹	31.2	31.4
2/14 23:00	248.7 ¹	31.0	31.4
2/15 5:00	237.9 ¹	30.8	31.2
2/15 11:00	225.1 ¹	30.5	31.1
2/15 17:00	218.2 ¹	30.3	31.0
2/15 23:00	222.2 ¹	30.2	31.0
2/16 5:00	220.2 ¹	30.1	30.9
2/16 11:00	9.0 ²	31.0	30.9
2/16 17:00	2.5 ²	31.1	30.7
2/16 23:00	9.3 ²	31.0	30.6
2/17 5:00	-2.1 ²	30.8	30.5

1 Data of TE-2-3-69H1 is being evaluated.

We estimated that the " 2" data of TE-2-3-69H1 is not correct due to the gauge failure.