

Fukushima Daiichi NPS Unit 2

The temperature of the lower part of the reactor pressure vessel (upper part of the bottom head / upper part of support skirt junction) (Reference)

location mounting angle serial number	the bottom head					support skirt junction					location mounting angle serial number	the bottom head					support skirt junction				
	135 °		270 °		0 °	135 °		270 °		0 °		135 °		270 °		0 °	135 °		270 °		
	TE-2-3-69H2	TE-2-3-69H3	TE-2-3-69F1	TE-2-3-69F2	TE-2-3-69F3	TE-2-3-69H2	TE-2-3-69H3	TE-2-3-69F1	TE-2-3-69F2			TE-2-3-69F3	TE-2-3-69H2	TE-2-3-69H3	TE-2-3-69F1		TE-2-3-69F2	TE-2-3-69F3			
2/29 23:00	44.3	41.0	43.4	42.9	51.5	3/2 21:00	45.4	41.7	49.4	43.8	58.0										
3/1 0:00	44.2	41.0	48.4	43.0	51.8	3/2 22:00	45.4	41.8	39.7	43.7	58.4										
3/1 1:00	44.2	41.0	47.6	42.9	51.6	3/2 23:00	45.3	41.8	40.1	43.7	58.5										
3/1 2:00	44.3	40.9	39.0	42.9	51.7	3/3 0:00	45.3	41.7	45.0	43.7	58.3										
3/1 3:00	44.3	41.0	44.5	42.9	51.9	3/3 1:00	45.2	41.7	44.8	43.7	58.2										
3/1 4:00	44.2	41.0	43.9	42.9	51.8	3/3 2:00	45.1	41.7	45.2	43.7	58.3										
3/1 5:00	44.3	41.0	44.2	42.9	52.1	3/3 3:00	45.1	41.7	49.7	43.7	58.2										
3/1 6:00	45.0	41.0	47.7	43.0	51.9	3/3 4:00	45.1	41.7	47.7	43.6	58.3										
3/1 7:00	44.2	41.0	48.2	43.0	51.9	3/3 5:00	44.9	41.7	39.7	43.6	58.2										
3/1 8:00	44.3	41.0	38.1	43.0	51.9	3/3 6:00	44.9	41.7	45.3	43.6	58.1										
3/1 9:00	44.3	41.0	41.0	43.0	52.2	3/3 7:00	44.8	41.6	45.2	43.5	58.1										
3/1 10:00	44.2	41.1	44.6	43.0	52.3	3/3 8:00	44.7	41.5	45.2	43.5	58.1										
3/1 11:00	44.2	41.0	44.5	43.0	52.4	3/3 9:00	44.6	41.5	49.6	43.5	58.1										
3/1 12:00	44.2	41.1	44.7	43.0	52.3	3/3 10:00	44.6	41.5	49.1	43.5	58.0										
3/1 13:00	44.3	41.1	48.4	43.0	52.4	3/3 11:00	44.5	41.5	36.4	43.4	58.1										
3/1 14:00	44.2	41.1	48.3	43.1	52.5	3/3 12:00	44.4	41.5	37.0	43.4	58.1										
3/1 15:00	45.2	41.1	38.5	43.1	52.5	3/3 13:00	44.4	41.4	42.3	43.4	58.3										
3/1 16:00	44.4	41.1	42.9	43.1	52.8	3/3 14:00	44.4	41.4	42.3	43.4	58.3										
3/1 17:00	44.4	41.1	44.2	43.1	54.2	3/3 15:00	44.3	41.3	42.4	43.3	58.1										
3/1 18:00	44.4	41.2	44.3	43.1	54.7	3/3 16:00	44.4	41.4	47.8	43.3	58.6										
3/1 19:00	44.5	41.2	44.3	43.2	55.2	3/3 17:00	44.3	41.4	35.6	43.3	58.6										
3/1 20:00	44.5	41.2	48.8	43.2	55.5																
3/1 21:00	44.6	41.2	38.9	43.2	55.8																
3/1 22:00	44.6	41.2	44.1	43.2	56.0																
3/1 23:00	44.6	41.3	40.6	43.3	56.7																
3/2 0:00	44.6	41.3	45.0	43.3	56.7																
3/2 1:00	44.7	41.3	45.0	43.3	56.7																
3/2 2:00	44.7	41.4	48.8	43.4	57.2																
3/2 3:00	44.7	41.3	48.8	43.4	57.2																
3/2 4:00	44.8	41.4	39.3	43.3	57.4																
3/2 5:00	44.8	41.5	45.3	43.5	56.7																
3/2 6:00	44.8	41.5	44.5	43.5	57.3																
3/2 7:00	44.8	41.5	44.9	43.5	57.4																
3/2 8:00	44.8	41.5	45.3	43.4	57.7																
3/2 9:00	44.8	41.5	48.8	43.6	57.8																
3/2 10:00	44.8	41.5	39.3	43.5	57.9																
3/2 11:00	44.8	41.5	43.4	43.4	57.7																
3/2 12:00	44.9	41.6	45.2	43.6	57.9																
3/2 13:00	45.1	41.6	45.1	43.6	58.0																
3/2 14:00	45.6	41.7	49.5	43.6	58.0																
3/2 15:00	45.5	41.7	48.5	43.6	58.1																
3/2 16:00	45.4	41.7	39.3	43.6	58.2																
3/2 17:00	45.4	41.7	43.0	43.7	58.2																
3/2 18:00	45.4	41.7	45.7	43.7	58.2																
3/2 19:00	45.4	41.8	44.7	43.8	57.7																
3/2 20:00	46.1	41.8	45.0	43.7	58.0																

\*There is a possibility that the numbers are not the same as the relevant parameters to the plant because the data above are the reference.