

# Plant Status of Fukushima Daiichi Nuclear Power Station

May 2, 2012

Tokyo Electric Power Company

## <1. Status of the Nuclear Reactor and the Primary Containment Vessel> (As of May 2 at 11:00 am)

Unit	Status of water injection		Reactor pressure vessel bottom temp.	Pressure of primary containment vessel*1	Hydrogen density of primary containment vessel
Unit 1	Injecting Fresh water	Core Spray System: Approx.2.0 m <sup>3</sup> /h	29.3 °C	107.1 kPa abs	A system:0.00 vol% B system:0.00 vol%
		Feed Water System: Approx.4.3 m <sup>3</sup> /h			
Unit 2	Injecting Fresh water	Core Spray System: Approx.5.8 m <sup>3</sup> /h	47.6 °C	17.05 kPa g	A system:0.54 vol% B system:0.53 vol%
		Feed Water System: Approx.2.9 m <sup>3</sup> /h			
Unit 3	Injecting Fresh water	Core Spray System: Approx.5.0 m <sup>3</sup> /h	59.2 °C	0.28 kPa g	A system:0.18 vol% B system:0.13 vol%
		Feed Water System: Approx.2.0 m <sup>3</sup> /h			

\*1: absolute pressure (kPa abs) = gauge pressure (kPa g) + atmosphere pressure (normal atmosphere pressure 101.3 kPa).

[Unit 3] · May 2: Sampling of charcoal filter and particulate filter of PCV gas control system was conducted.

## <2. Status of the Spent Fuel Pool > (As of May 1 at 11:00 am)

Unit	Cooling type	Status of cooling	Temperature of water in Spent Fuel Pool
Unit 1	Circulating Cooling System	Under operation	20.0 °C
Unit 2	Circulating Cooling System	Under operation	22.7 °C
Unit 3	Circulating Cooling System	Under operation	21.3 °C
Unit 4	Circulating Cooling System	Under operation	30 °C

## <3. Status of Water Transfer from the Basement Floor of the Turbine Building etc.>

Unit	Draining water source	Place transferred	Status
Unit 3	Unit 3 T/B	Central Radioactive Waste Treatment Facility [Miscellaneous Solid Waste Volume Reduction Treatment Building (High Temperature Incinerator Building)]	4/29 9:43 Being transferred

## <4. Status of the Treatment Facility and the Storage Facility > (As of May 1 at 7:00 am)

Facility	Cesium adsorption apparatus	Secondary Cesium adsorption apparatus (SARRY)	Decontamination instruments	Water desalinations (reverse osmosis membrane)	Water desalinations (evaporative concentration)
Operating status	Shutdown	Operation *	Shutdown	Operating intermittently according to the water balance	Operating intermittently according to the water balance

\* Cleaning of filter is in progress.

- From June 8, 2011: Large tanks to store contaminated and decontaminated water are transported and installed.

#### <5. Others>

- October 7, 2011~: Continuously implementing water spray using water after purifying accumulated water of Unit 5 and Unit 6 to prevent spontaneous fire of trimmed trees and diffusion of dust.
- February 23, 2012~: Test of drawing water in the Unit 6 sub drain to the temporary tank through the temporarily storage tank was implemented.
- March 6, 2012~: Test of drawing water in the Unit 5 sub drain to the temporary tank through the temporarily storage tank was implemented.
- March 14, 2012~: In order to prevent the diffusion of ocean soil, we started the full-scale covering work of seafloor by solidification soil (covering material).
- April 25, 2012~: For the purpose of preventing further contamination to the ocean through grounder water, we started a full-scale construction of water shielding wall.
- May 2, 2012: Dust sampling by large crane was conducted at the upper part of the Reactor Building of Unit 3.

END