

## Gas Sampling Results of Unit 2 PCV Gas Control System Conducted at Fukushima Daiichi Nuclear Power Station

May 9, 2012

Tokyo Electric Power Company

【 Sampling place 】 Inlet of Unit 2 PCV Gas Control System

【 Sampling date 】 11:00 AM, May 8, 2012 (Tuesday)

【 Sampling results 】

Nuclides		Radioactive Concentration ( Bq/cm <sup>3</sup> )	Detection Limit ( Bq/cm <sup>3</sup> )	Half-Life Period
Gas Vial Container	I-131	Below Detection Limit	$1.2 \times 10^{-1}$	About 8 Days
	Cs-134	Below Detection Limit	$3.1 \times 10^{-1}$	About 2 Years
	Cs-137	Below Detection Limit	$3.7 \times 10^{-1}$	About 30 Years
	Kr-85	$2.6 \times 10^2$	$2.6 \times 10^1$	About 11 Years
	Xe-131m	Below Detection Limit	$3.4 \times 10^0$	About 12 Days
	Xe-133	Below Detection Limit	$2.6 \times 10^{-1}$	About 5 Days
	Xe-135	Below Detection Limit	$1.0 \times 10^{-1}$	About 9 Hours

All of the short half-life Xe isotopes were below detection limit.

Not exceeding the re-criticality criteria of 1Bq/cm<sup>3</sup> ( Xe-135 )