

Plant Status of Fukushima Daiichi Nuclear Power Station

May 30, 2012

Tokyo Electric Power Company

<1. Status of the Nuclear Reactor and the Primary Containment Vessel> (As of May 30 at 11:00 AM)

| Unit | Status of Water Injection | | Bottom Temperature of Reactor Pressure Vessel | Pressure of Primary Containment Vessel ^{*1} | Hydrogen Density of Primary Containment Vessel |
|--------|---------------------------|--|---|--|--|
| Unit 1 | Injecting Fresh Water | Core Spray System: Approx. 2.0 m ³ /h | 31.1 °C | 107.5 kPa abs | A system:0.00 vol% B system:0.00 vol% |
| | | Feed Water System: Approx. 3.4 m ³ /h | | | |
| Unit 2 | Injecting Fresh Water | Core Spray System: Approx. 6.0 m ³ /h | 46.5 °C | 13.75 kPa g | A system:0.23 vol% B system:0.23 vol% |
| | | Feed Water System: Approx. 2.9 m ³ /h | | | |
| Unit 3 | Injecting Fresh Water | Core Spray System: Approx. 5.0 m ³ /h | 58.1 °C | 0.26 kPa g | A system:0.15 vol% B system:0.14 vol% |
| | | Feed Water System: Approx. 2.9 m ³ /h | | | |

*1: absolute pressure (kPa abs) = gauge pressure (kPa g) + atmosphere pressure (normal atmosphere pressure 101.3 kPa).

<2. Status of the Spent Fuel Pool > (As of May 30 at 11:00 AM)

| Unit | Cooling Type | Status of Cooling | Temperature of Water in Spent Fuel Pool |
|--------|----------------------------|-------------------|---|
| Unit 1 | Circulating Cooling System | Under operation | 22.0 °C |
| Unit 2 | Circulating Cooling System | Under operation | 23.3 °C |
| Unit 3 | Circulating Cooling System | Under operation | 22.5 °C |
| Unit 4 | Circulating Cooling System | Under operation | 32 °C |

<3. Status of Water Transfer from the Basement Floor of the Turbine Building etc.>

| Unit | Draining Water Source | Place Transferred | Status |
|--------|-----------------------|--|-------------------------------------|
| Unit 2 | Unit 2 T/B | Central Radioactive Waste Treatment Facility [Miscellaneous Solid Waste Volume Reduction Treatment Building (High Temperature Incinerator Building)] | 5/27 2:34 PM – Being transferred |
| Unit 3 | Unit 3 T/B | Central Radioactive Waste Treatment Facility [Miscellaneous Solid Waste Volume Reduction Treatment Building (High Temperature Incinerator Building)] | 5/19 9:15 AM – Being transferred |
| Unit 6 | Unit 6 T/B | Temporary Tank | 5/30 10:00 AM – 4:00 PM Transferred |

<4. Status of the Treatment Facility and the Storage Facility > (As of May 30 at 7:00 AM)

| Facility | Cesium Adsorption Apparatus | Secondary Cesium Adsorption Apparatus (SARRY) | Decontamination Instruments | Water Desalinations (Reverse Osmosis Membrane) | Water Desalinations (Evaporative Concentration) |
|------------------|-----------------------------|---|-----------------------------|---|---|
| Operating status | Shutdown | Operation * | Shutdown | Operating intermittently according to the water balance | Operating intermittently according to the water balance |

* Cleaning of filter is in progress.

- June 8, 2011 -: Large tanks to store contaminated and decontaminated water are transported and installed.

<5 . Others>

- October 7, 2011 - : Continuously implementing water spray using water after purifying accumulated water of Unit 5 and Unit 6 to prevent spontaneous fire of trimmed trees and diffusion of dust.
- February 23, 2012 - : Test of drawing water in the Unit 6 sub drain to the temporary tank through the temporarily storage tank was implemented.
- March 6, 2012 - : Test of drawing water in the Unit 5 sub drain to the temporary tank through the temporarily storage tank was implemented.
- March 14, 2012 - : In order to prevent the diffusion of ocean soil, we started the full-scale covering work of seafloor by solidification soil (covering material).
- April 25, 2012 - : For the purpose of preventing further contamination to the ocean through grounder water, we started a full-scale construction of water shielding wall.
- Around 12:30 PM on May 29: Data reading was failing on the Main Anti-Earthquake Building monitoring panel of the portable monitoring post at the west entrance. The same issue was occurring on the Main Anti-Earthquake Building monitoring panel of the wireless monitoring post used for alternative monitoring. There is no problem with data monitoring at 12:30 PM and later, as a worker at the site has been measuring data. The data from 12:30 PM to 7:30 PM was acquired by the alternative measurement done by a worker at the site. At 7:39 PM on the same day, the wireless monitoring system was recovered after resetting the equipment which transmits from the receiver to the terminal. As the data after 8:00 PM was acquired by the recovered wireless monitoring system, there is no data missing due to this issue.

END