

< Reference >

May 31, 2012

Tokyo Electric Power Company

Fukushima Daiichi NPS Unit 2 PCV Temperatures (6 hours)

[HP: Plant Related Parameters]

Unit	Return air drywell cooler (TE-16-114A)	Return air drywell cooler (TE-16-114B)	Return air drywell cooler (TE-16-114C)	Return air drywell cooler (TE-16-114D)	Return air drywell cooler (TE-16-114E)	Supply air D/W cooler (TE-16-114F#1)	Supply air D/W cooler (TE-16-114G#1)	Supply air D/W cooler (TE-16- (TE-16-114J#1)	Supply air D/W cooler (TE-16-114J#1)
2012/5/27 5:00	55.7	46.9	47.3	42.5	45.8	43.1	46.4	53.7	46.2
2012/5/27 11:00	55.7	46.8	47.3	42.4	45.7	42.9	46.3	53.6	46.2
2012/5/27 17:00	55.8	46.8	47.2	42.4	45.7	42.8	46.4	53.6	46.2
2012/5/27 23:00	55.7	46.8	47.1	42.5	45.7	42.7	46.4	53.5	46.1
2012/5/28 5:00	55.9	46.8	47.2	42.6	45.7	42.5	46.4	53.3	46.1
2012/5/28 11:00	56.3	46.8	47.2	42.8	45.7	42.6	46.4	53.2	46.2
2012/5/28 17:00	58	46.8	47.1	43.7	45.7	41	46.4	52.1	46.1
2012/5/28 23:00	64.7	46.7	47.1	47.6	45.6	35	46.3	48.2	46
2012/5/29 5:00	65.1	46.7	47.1	47.3	45.5	35	46.3	48.1	46
2012/5/29 11:00	59.1	46.1	47.1	43.9	45.5	39.9	46.2	51.5	45.9
2012/5/29 17:00	57.6	46.5	47	43.2	45.5	41.1	46.2	52.3	46
2012/5/29 23:00	57.1	46.6	47.1	43	45.5	41.3	46.3	52.6	46
2012/5/30 5:00	56.4	46.5	46.8	42.6	45.3	41.8	46.1	52.8	45.9
2012/5/30 11:00	56.2	46.5	46.8	42.6	45.3	42	46.1	52.8	45.9
2012/5/30 17:00	55.8	46.4	46.8	42.5	45.3	42.2	46.1	52.8	45.8
2012/5/30 23:00	55.6	46.4	46.8	42.4	45.3	42.2	46.1	52.8	45.8
2012/5/31 5:00	55.6	46.4	46.8	42.2	45.4	42.6	46.1	52.7	45.8
2012/5/31 11:00	55.4	46.3	46.7	42.1	45.3	42.5	46	52.6	45.7

: Thermometers which showed significant temperature changes