

Jun 7, 2012

Tokyo Electric Power Company

Sampling Result: Radioactivity Density of the Accumulated Water in the Reactor Building

| | | |
|---------------------------------|---------------------------|--|
| Name of Sample | | Unit 2 R/B Underground High-level Contamination Water (Accumulated Water) (Torus Room) |
| Date of Sampling | | 1:00 PM on June 6, 2012 |
| γ Nuclide (Bq/cm ³) | I-131 (Approx. 8 days) | ND |
| | Cs-134 (Approx. 2 years) | 2.7E+04 |
| | Cs-137 (Approx. 30 years) | 4.0E+04 |
| | Mn-54 (Approx. 310 days) | ND |
| | Co-58 (Approx. 71 days) | ND |
| | Co-60 (Approx. 5 years) | ND |
| | Ru-103 (Approx. 40 days) | ND |
| | Ru-106 (Approx. 370 days) | ND |
| | Sb-124 (Approx. 60 days) | ND |
| | Sb-125 (Approx. 3 yrs) | ND |
| | Ba-140 (Approx. 13 days) | ND |
| La-140 (Approx. 40 hrs) | ND | |
| Chloride Concentration (ppm) | | 70 |

* 0.0E±0 is the same as 0.0x10±0.

* When the radioactivity density is below the detection limit, it shows "ND" ("Not Detectable").

* The half-life of each nuclide is provided in parentheses.