

Gas Sampling Results of Unit 2 PCV Gas Control System Conducted at Fukushima Daiichi Nuclear Power Station

(Data summarized on June 11)

Place of Sampling	Exit of Unit 2 PCV Gas Control System			
Type of Sampling	Particulate Filter		Charcoal Filter	
Time of Sampling	Jun 5, 2012 8:51 AM - 9: 01 AM		Jun 5, 2012 9:01 AM - 9:31 AM	
Detected Nuclides (Half-life)	Density of Sample (Bq/cm ³)	Detection Limit Concentration (Bq/cm ³)	Density of Sample (Bq/cm ³)	Detection Limit Concentration (Bq/cm ³)
I-131 (Approx. 8 days)	ND	2.0E-06	ND	1.5E-06
Cs-134 (Approx. 2 years)	ND	5.1E-06	3.0E-06	2.8E-06
Cs-137 (Approx. 30 years)	ND	6.1E-06	ND	3.4E-06

* O.OE - O is the same as O.O x 10-O

* "ND" indicates that the measurement result is below the detection limit.

This sampling is intended for the nuclides analysis results of cesium and iodine.