

Gas Sampling Results of Unit 2 PCV Gas Control System Conducted at Fukushima Daiichi Nuclear Power Station
 (Data summarized on July 10)

Place of Sampling	Exit of Unit 2 PCV Gas Control System			
Type of Sampling	Particulate filter		Charcoal filter	
Time of Sampling	Jul 3, 2012 9:32 AM - 9:42 AM		Jul 3, 2012 9:42 AM - 10:12 AM	
Detected Nuclides (Half-life)	Density of Sample (Bq/cm ³)	Detection limit density (Bq/cm ³)	Density of Sample (Bq/cm ³)	Detection limit density (Bq/cm ³)
I-131 (Approx. 8 days)	ND	2.0E-06	ND	1.3E-06
Cs-134 (Approx. 2 years)	ND	4.5E-06	ND	2.4E-06
Cs-137 (Approx. 30 years)	ND	5.1E-06	ND	3.0E-06

* O.OE - O is the same as O.O x 10⁻⁰

* "ND" indicates that the measurement result is below the detection limit.

* This sampling is intended for obtaining the nuclides analysis results of cesium and iodine.