

Gas Sampling Results of Unit 3 PCV Gas Control System Conducted at Fukushima Daiichi Nuclear Power Station
 (Data summarized on July 10)

Place of Sampling	Exit of Unit 3 PCV Gas Control System			
Type of Sampling	Particulate filter		Charcoal filter	
Time of Sampling	Jul 5, 2012 9:39 AM - 9:49 AM		Jul 5, 2012 9:49 AM - 10:19 AM	
Detected Nuclides (Half-life)	Density of Sample (Bq/cm ³)	Detection limit density (Bq/cm ³)	Density of Sample (Bq/cm ³)	Detection limit density (Bq/cm ³)
I-131 (Approx. 8 days)	ND	2.0E-06	ND	1.5E-06
Cs-134 (Approx. 2 years)	ND	5.3E-06	ND	2.6E-06
Cs-137 (Approx. 30 years)	ND	6.1E-06	ND	3.2E-06

* O.OE - O is the same as O.O x 10^{-O}

* "ND" indicates that the measurement result is below the detection limit.

* This sampling is intended for obtaining the nuclides analysis results of cesium and iodine.