

Gas Sampling Results of Unit 3 PCV Gas Control System Conducted at Fukushima Daiichi Nuclear Power Station

(Data summarized on November 9)

| Place of Sampling | Exit of Unit 3 PCV Gas Control System | | | |
|-------------------------------|---|--|---|--|
| Type of Sampling | Particulate Filter | | Charcoal Filter | |
| Time of Sampling | Nov 5, 2012 9:30 AM - 9:40 AM | | Nov 5, 2012 9:40 AM - 10:10 AM | |
| Detected Nuclides (Half-life) | Density of Sample (Bq/cm ³) | Detection Limit Density (cm ³) | Density of Sample (Bq/cm ³) | Detection Limit Density (cm ³) |
| I-131 (Approx. 8 days) | ND | 1.0E-06 | ND | 6.8E-07 |
| Cs-134 (Approx. 2 years) | ND | 2.4E-06 | ND | 1.4E-06 |
| Cs-137 (Approx. 30 years) | 4.0E-06 | 2.9E-06 | ND | 1.8E-06 |

* O.OE - O is the same as O.O x 10⁻⁰

* "ND" indicates that the measurement result is below the detection limit.

This sampling is intended for the nuclides analysis result of cesium and iodine.