Nov 08, 2011

Nuclide Analysis Results of Sub-drain Water in the Surroundings of "Centralized Radiation Waste Treatment Facility"

I-131(Bq/cm^3)

Sampling point	After transfer																				
	Oct 23	Oct 24	Oct 25	Oct 26	Oct 27	Oct 28	Oct 29	Oct 30	Oct 31	Nov 01	Nov 02	Nov 03	Nov 04	Nov 05	Nov 06	Nov 07					
①	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND					
②	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND					
③	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND					
④	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-					
⑤	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND					
⑥	-	ND	-	-	-	-	-	-	ND	-	-	-	-	-	-	ND					
⑦	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND					
⑧	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND					
⑨	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND					

Cs-134(Bq/cm^3)

Sampling point	After transfer																				
	Oct 23	Oct 24	Oct 25	Oct 26	Oct 27	Oct 28	Oct 29	Oct 30	Oct 31	Nov 01	Nov 02	Nov 03	Nov 04	Nov 05	Nov 06	Nov 07					
①	ND	ND	ND	ND	0.063	0.027	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND					
②	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND					
③	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND					
④	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-					
⑤	ND	ND	0.026	ND	0.03	ND	ND	0.034	ND	ND	0.028	ND	0.032	ND	ND	ND					
⑥	-	ND	-	-	-	-	-	-	ND	-	-	-	-	-	-	ND					
⑦	0.37	0.19	0.27	0.48	0.22	0.35	0.13	0.44	0.19	0.28	0.18	0.25	0.074	0.14	0.32	0.15					
⑧	ND	ND	0.026	ND	ND	ND	ND	ND	0.025	ND	0.027	0.036	0.026	ND	0.027	0.023					
⑨	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND					

Cs-137(Bq/cm^3)

Sampling point	After transfer																				
	Oct 23	Oct 24	Oct 25	Oct 26	Oct 27	Oct 28	Oct 29	Oct 30	Oct 31	Nov 01	Nov 02	Nov 03	Nov 04	Nov 05	Nov 06	Nov 07					
①	ND	ND	ND	ND	0.082	0.042	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND					
②	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND					
③	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND					
④	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-					
⑤	ND	0.028	0.024	ND	0.03	0.032	0.051	0.026	ND	ND	ND	ND	0.05	ND	ND	0.031					
⑥	-	ND	-	-	-	-	-	-	ND	-	-	-	-	-	-	ND					
⑦	0.46	0.25	0.33	0.6	0.23	0.48	0.2	0.52	0.25	0.37	0.24	0.29	0.1	0.15	0.43	0.19					
⑧	ND	ND	ND	ND	0.032	ND	0.04	0.043	0.03	ND	0.052	0.036	0.026	0.036	0.032	0.029					
⑨	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND					

* Hyphen "-" indicates that neither sampling nor measurements were implemented.
* ⑥ was conducted as upstream of the groundwater once a week from April 29 since it was unable to sample at ④.
* We have been sampling at ⑦ since May 26, for it is located downstream of the groundwater.
* We have been sampling at ⑧ since May 30.
* We have been sampling at ⑨ since August 2.
* "ND" means the sampled data is below measurable limit. I-131: approx. 0.01Bq/cm3, Cs-134: approx. 0.03Bq/cm3, Cs-137: approx. 0.03Bq/cm3 (11/7)
  Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

<Place of sampling>
①Southeast part of Unit 4 Turbine Building
②Northeast part of Process Main Building
③Southeast part of Process Main Building
④Southwest part of Process Main Building
⑤South part of Miscellaneous Solid Waste Volume Reduction Treatment Building
⑥Southwest part of On-site Bunker Building
⑦West part of Incineration Workshop Building
⑧North part of Miscellaneous Solid Waste Volume Reduction Treatment Building
⑨Southeast part of On-site Bunker Building