

Nuclide Analysis Results of Sub-drain Water in the Surroundings of "Centralized Radiation Waste Treatment Facility"

I-131(Bq/cm³)

Sampling point	After transfer																			
	Oct 23	Oct 24	Oct 25	Oct 26	Oct 27	Oct 28	Oct 29	Oct 30	Oct 31	Nov 01	Nov 02	Nov 03	Nov 04	Nov 05	Nov 06	Nov 07	Nov 08	Nov 09	Nov 10	Nov 11
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	-	ND	-	-	-	-	-	-	ND	-	-	-	-	-	-	ND	-	-	-	-
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

Cs-134(Bq/cm³)

Sampling point	After transfer																			
	Oct 23	Oct 24	Oct 25	Oct 26	Oct 27	Oct 28	Oct 29	Oct 30	Oct 31	Nov 01	Nov 02	Nov 03	Nov 04	Nov 05	Nov 06	Nov 07	Nov 08	Nov 09	Nov 10	Nov 11
	ND	ND	ND	ND	0.063	0.027	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
	ND	ND	0.026	ND	0.03	ND	ND	0.034	ND	ND	0.028	ND	0.032	ND	ND	ND	ND	0.027	ND	ND
	-	ND	-	-	-	-	-	-	ND	-	-	-	-	-	-	ND	-	-	-	-
	0.37	0.19	0.27	0.48	0.22	0.35	0.13	0.44	0.19	0.28	0.18	0.25	0.074	0.14	0.32	0.15	0.2	0.18	0.16	0.19
	ND	ND	0.026	ND	ND	ND	ND	ND	0.025	ND	0.027	0.036	0.026	ND	0.027	0.023	0.031	0.03	0.026	0.034
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

Cs-137(Bq/cm³)

Sampling point	After transfer																			
	Oct 23	Oct 24	Oct 25	Oct 26	Oct 27	Oct 28	Oct 29	Oct 30	Oct 31	Nov 01	Nov 02	Nov 03	Nov 04	Nov 05	Nov 06	Nov 07	Nov 08	Nov 09	Nov 10	Nov 11
	ND	ND	ND	ND	0.082	0.042	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
	ND	0.028	0.024	ND	0.03	0.032	0.051	0.026	ND	ND	ND	ND	0.05	ND	ND	0.031	ND	0.04	ND	0.035
	-	ND	-	-	-	-	-	-	ND	-	-	-	-	-	-	ND	-	-	-	-
	0.46	0.25	0.33	0.6	0.23	0.48	0.2	0.52	0.25	0.37	0.24	0.29	0.1	0.15	0.43	0.19	0.26	0.28	0.2	0.21
	ND	ND	ND	ND	0.032	ND	0.04	0.043	0.03	ND	0.052	0.036	0.026	0.036	0.032	0.029	0.036	0.03	ND	0.029
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

* Hyphen "-" indicates that neither sampling nor measurements were implemented.
 * was conducted as upstream of the groundwater once a week from April 29 since it was unable to sample at .
 * We have been sampling at since May 26, for it is located downstream of the groundwater.
 * We have been sampling at since May 30.
 * We have been sampling at since August 2.
 * "ND" means the sampled data is below measurable limit. I-131: approx. 0.02Bq/cm3, Cs-134: approx. 0.02Bq/cm3, Cs-137: approx. 0.03Bq/cm3 (11/11)
 Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

<Place of sampling>
 Southeast part of Unit 4 Turbine Building
 Northeast part of Process Main Building
 Southeast part of Process Main Building
 Southwest part of Process Main Building
 South part of Miscellaneous Solid Waste Volume Reduction Treatment Building
 Southwest part of On-site Bunker Building
 West part of Incineration Workshop Building
 North part of Miscellaneous Solid Waste Volume Reduction Treatment Building
 Southeast part of On-site Bunker Building