

Unit 6 of Fukushima Daiichi

福島第一 6号機

Alarm typer

アラーム タイプ

Mar 19, 2011

平成 23年 3月 19日

'11-03-19 SAT. FUKUSHIMA DAIICHI 6

0036 L209 SGTS RAD MON HI B -1.29> -1.30 MS/H
0037 L208 SGTS RAD MON HI A -1.27> -1.30 MS/H
0041 L208 SGTS RAD MON HI A -1.32 MS/H NORMAL RETURN
0042 L209 SGTS RAD MON HI B -1.31 MS/H NORMAL RETURN
0107 L209 SGTS RAD MON HI B -1.25> -1.30 MS/H
0107 L208 SGTS RAD MON HI A -1.28> -1.30 MS/H
0111 L208 SGTS RAD MON HI A -1.32 MS/H NORMAL RETURN
0111 L209 SGTS RAD MON HI B -1.31 MS/H NORMAL RETURN
0114 L209 SGTS RAD MON HI B -1.29> -1.30 MS/H

0107 L208 SGT5 RAD MON HI B -1.28> -1.30 MS/H
 0111 L208 SGT5 RAD MON HI A -1.32 MS/H NORMAL RETURN
 0111 L209 SGT5 RAD MON HI B -1.31 MS/H NORMAL RETURN
 0114 L209 SGT5 RAD MON HI B -1.29> -1.30 MS/H
 0114 L208 SGT5 RAD MON HI A -1.28> -1.30 MS/H
 0119 L208 SGT5 RAD MON HI A -1.31 MS/H NORMAL RETURN
 0119 L209 SGT5 RAD MON HI B -1.32 MS/H NORMAL RETURN
 TRIP SEQUENCE LOG 11-03-19

H	MIN	SEC	MSEC	PID	ABBREVIATION	STATUS
01	48	08	710	D707*	REACTOR WTR LEVEL HI	NORM

END JOB

0153 L625 CAMS A SMPL SEL(D/W) ON
 0155 L625 CAMS A SMPL SEL(D/W) OFF
 0157 L630 CAMS B NO DATA OFF
 0157 L626 CAMS B SMPL SEL(D/W) ON
 0207 L633 CAMS 02 DEN HI (D/W) ON
 0209 L209 SGT5 RAD MON HI B -1.29> -1.30 MS/H
 0209 L208 SGT5 RAD MON HI A -1.29> -1.30 MS/H
 0221 L621 SGT5 B START OFF
 0221 L621 SGT5 B START ON
 0221 L621 SGT5 B START OFF

TRIP SEQUENCE LOG 11-03-19

H	MIN	SEC	MSEC	PID	ABBREVIATION	STATUS
02	25	11	850	D775*	D/G BUS LOSS 6C	OFF
02	25	29	780	D775	D/G BUS LOSS 6C	ON
02	25	35	020	D775	D/G BUS LOSS 6C	OFF
02	25	35	750	A506	MSL A LEAK DETECTION	HIGH
02	25	35	750	D519	REACTOR LO WTR CH A1	TRIP
02	25	35	750	D712	MSL T/B HIGH TEMP A	TRIP
0225	A533	REM CH A	INOOPERATIVE	ALM		
02	25	35	750	D515	REACTOR CH A1 HI PRS	TRIP
0225	A542	REM CH A	BYPASSED	OFF		
02	25	35	750	A507	MSL B LEAK DETECTION	HIGH
02	25	35	750	D505	CONDSR LOW VACM A	TRIP
02	25	35	760	D726	RX LVL(L-2MSIV)LO A2	ON
02	25	35	760	D724	RX LVL(L-2MSIV)LO A1	ON
0225	A024	LPRM	16-17	FLX LV A	LOW RSN	
02	25	35	760	D523	MSL A1 HI RADIATION	TRIP
0225	A034	LPRM	32-17	FLX LV C	LOW RSN	
02	25	35	760	D527	NEUT MON SYSTEM CH A1	TRIP
0225	A040	LPRM	48-17	FLX LV A	LOW RSN	
02	25	35	760	D529	NEUT MON SYSTEM CH A2	TRIP
0225	A082	LPRM	16-33	FLX LV C	LOW RSN	
02	25	35	760	D620	CONDSR LOW VACM C	TRIP
0225	A088	LPRM	32-33	FLX LV A	LOW RSN	
02	25	35	760	A504	MSL C HIGH FLOW	HIGH
0225	A098	LPRM	48-33	FLX LV C	LOW RSN	
02	25	35	760	A502	MSL A HIGH FLOW	HIGH
0225	A136	LPRM	16-49	FLX LV A	LOW RSN	
02	25	35	760	D511	FCV PRES (SCRAM) A1	TRIP
0225	A146	LPRM	32-49	FLX LV C	LOW RSN	
02	25	35	760	D513	FCV PRES (SCRAM) A2	TRIP
0225	A152	LPRM	48-49	FLX LV A	LOW RSN	
02	25	35	760	D521	REACTOR LO WTR CH A2	TRIP
0225	A004	LPRM	24-09	FLX LV A	LOW RSN	
02	25	35	770	D564	SEISMIC MON A1	ALM
0225	A048	LPRM	08-25	FLX LV A	LOW RSN	
02	25	35	770	D517	REACTOR CH A2 HI PRS	TRIP
0225	A064	LPRM	40-25	FLX LV A	LOW RSN	
02	25	35	770	D525	MSL A2 HI RADIATION	TRIP
0225	A112	LPRM	24-41	FLX LV A	LOW RSN	

02	25	35	710	D714	MSL T/B HIGH TEMP C	TRIP
0225	A128	LPRM	56-41	FLX LV A	LOW RSN	
02	25	35	810	D562	RECIRC BREAKER #1	TRIP
0225	A162	LPRM	24-57	FLX LV C	LOW RSN	
02	25	35	820	D563	RECIRC BREAKER #2	TRIP
0225	A168	LPRM	40-57	FLX LV A	LOW RSN	
02	25	36	130	D628	APRM THERMAL LEVEL C	TRIP
0225	A012	LPRM	40-09	FLX LV A	LOW RSN	
02	25	36	130	D548	APRM CINL C UPSCALE	TRIP
0225	A056	LPRM	24-25	FLX LV A	LOW RSN	
02	25	36	130	D550	APRM CINL E UPSCALE	TRIP
0225	A072	LPRM	56-25	FLX LV A	LOW RSN	
02	25	36	140	D630	APRM THERMAL LEVEL E	TRIP
0225	A104	LPRM	08-41	FLX LV A	LOW RSN	
02	25	36	280	D626	APRM THERMAL LEVEL A	TRIP
0225	A120	LPRM	40-41	FLX LV A	LOW RSN	
02	25	36	280	D546	APRM CINL A UPSCALE	TRIP
0225	A160	LPRM	24-57	FLX LV A	LOW RSN	

END JOB

0225	A170	LPRM	40-57	FLX LV C	LOW RSN
0225	A006	LPRM	24-09	FLX LV C	LOW RSN
0225	A050	LPRM	08-25	FLX LV C	LOW RSN
0225	A066	LPRM	40-25	FLX LV C	LOW RSN
0225	A114	LPRM	24-41	FLX LV C	LOW RSN
0225	A130	LPRM	56-41	FLX LV C	LOW RSN
0225	3000	APRM	A	FLUX LEVEL	LOW RSN
0225	3002	APRM	C	FLUX LEVEL	LOW RSN
0225	3004	APRM	E	FLUX LEVEL	LOW RSN
0225	A026	LPRM	16-17	FLX LV C	LOW RSN
0225	A032	LPRM	32-17	FLX LV A	LOW RSN
0225	A042	LPRM	48-17	FLX LV C	LOW RSN
0225	A080	LPRM	16-33	FLX LV A	LOW RSN
0225	A090	LPRM	32-33	FLX LV C	LOW RSN
0225	A096	LPRM	48-33	FLX LV A	LOW RSN
0225	A138	LPRM	16-49	FLX LV C	LOW RSN
0225	A144	LPRM	32-49	FLX LV A	LOW RSN
0225	A154	LPRM	48-49	FLX LV C	LOW RSN
0225	A014	LPRM	40-09	FLX LV C	LOW RSN
0225	A058	LPRM	24-25	FLX LV C	LOW RSN
0225	A074	LPRM	56-25	FLX LV C	LOW RSN
0225	A106	LPRM	08-41	FLX LV C	LOW RSN
0225	A122	LPRM	40-41	FLX LV C	LOW RSN
0225	B037	RECIR	LP A1	DR FLOW	LOW RSN
0225	B039	RECIR	LP B1	DR FLOW	LOW RSN
0225	B024	CLNUP	SYSTEM	FLOW	LOW RSN
0225	A027	LPRM	16-17	FLX LV D	LOW RSN
0225	A033	LPRM	32-17	FLX LV B	LOW RSN
0225	A043	LPRM	48-17	FLX LV D	LOW RSN
0225	A081	LPRM	16-33	FLX LV B	LOW RSN
0225	A091	LPRM	32-33	FLX LV D	LOW RSN
0225	A097	LPRM	48-33	FLX LV B	LOW RSN
0225	A139	LPRM	16-49	FLX LV D	LOW RSN
0225	A145	LPRM	32-49	FLX LV B	LOW RSN
0225	A155	LPRM	48-49	FLX LV D	LOW RSN
0225	A007	LPRM	24-09	FLX LV D	LOW RSN
0225	A013	LPRM	40-09	FLX LV B	LOW RSN
0225	A051	LPRM	08-25	FLX LV D	LOW RSN
0225	A057	LPRM	24-25	FLX LV B	LOW RSN
0225	A067	LPRM	40-25	FLX LV D	LOW RSN
0225	A073	LPRM	56-25	FLX LV B	LOW RSN
0225	A105	LPRM	08-41	FLX LV B	LOW RSN
0225	A115	LPRM	24-41	FLX LV D	LOW RSN
0225	A121	LPRM	40-41	FLX LV B	LOW RSN
0225	A131	LPRM	56-41	FLX LV D	LOW RSN
0225	A161	LPRM	24-57	FLX LV B	LOW RSN

4

```

0225 A171 LPRM 40-57 FLX LV D LOW RSN
0225 A006 LPRM 24-09 FLX LV B LOW RSN
0225 A015 LPRM 40-09 FLX LV D LOW RSN
0225 A049 LPRM 08-25 FLX LV B LOW RSN
0225 A059 LPRM 24-25 FLX LV D LOW RSN
0225 A065 LPRM 40-25 FLX LV B LOW RSN
0225 A075 LPRM 56-25 FLX LV D LOW RSN
0225 A107 LPRM 08-41 FLX LV D LOW RSN
0225 A113 LPRM 24-41 FLX LV B LOW RSN
0225 A123 LPRM 40-41 FLX LV D LOW RSN
0225 A129 LPRM 56-41 FLX LV B LOW RSN
0225 A163 LPRM 24-57 FLX LV D LOW RSN
0225 A169 LPRM 40-57 FLX LV B LOW RSN
0225 A025 LPRM 16-17 FLX LV B LOW RSN
0225 A035 LPRM 32-17 FLX LV D LOW RSN
0225 A041 LPRM 48-17 FLX LV B LOW RSN
0225 A083 LPRM 16-33 FLX LV D LOW RSN
0225 A089 LPRM 32-33 FLX LV B LOW RSN
0225 A099 LPRM 48-33 FLX LV D LOW RSN
0225 A137 LPRM 16-49 FLX LV B LOW RSN
0225 A147 LPRM 32-49 FLX LV D LOW RSN
0225 A153 LPRM 48-49 FLX LV B LOW RSN
0225 A200 TPM CHNL A LOW RSN
0225 A204 TPM CHNL E LOW RSN
0225 A202 TPM CHNL C LOW RSN
0225 D003 REC DRIV FLOW A BV UKN B.V
0225 D004 REC DRIV FLOW B BV UKN B.V
0225 D057 APRM CHAN 1 UKN B.V
0225 D032 RECIRC DRVG FLOW UKN B.V
0225 B204 REM CHNL A LOW RSN
0225 L053 DW FLR DRN SUMP FLW LOW RSN
0226 B204 REM CHNL A 0.3 %PWR NORMAL RETURN
0226 L052 DW EQ DRN SUMP FLW LOW RSN
0229 L208 SGTS RAD MON HI A -1.32 MS/H NORMAL RETURN
TRIP SEQUENCE LOG 11-03-19

```

```

H MIN SEC MSEC PID ABBREVIATION STATUS
02 29 41 350 D775* D/G BUS LOSS 6C ON
0229 L209 SGTS RAD MON HI B -1.32 MS/H NORMAL RETURN
END JOB

```

```

0310 L633 CAMS 02 DEN HI (D/W) OFF
0310 L630 CAMS B NO DATA ON
0310 L626 CAMS B SMPL SEL(D/W) OFF
0311 L630 CAMS B NO DATA OFF
0321 L634 CAMS 02 DEN HI (S/P) ON
0328 L209 SGTS RAD MON HI B -1.28> -1.30 MS/H
0328 L208 SGTS RAD MON HI A -1.28> -1.30 MS/H
0331 L208 SGTS RAD MON HI A -1.32 MS/H NORMAL RETURN
0331 L209 SGTS RAD MON HI B -1.31 MS/H NORMAL RETURN
0412 L621 SGTS B START ON
TRIP SEQUENCE LOG 11-03-19

```

```

H MIN SEC MSEC PID ABBREVIATION STATUS
04 22 20 100 D654* DIESEL GENERATOR 6A ON
04 22 20 210 D775 D/G BUS LOSS 6C OFF
END JOB

```

```

0432 L209 SGTS RAD MON HI B -1.26> -1.30 MS/H
0432 L208 SGTS RAD MON HI A -1.24> -1.30 MS/H
0516 L630 CAMS B NO DATA ON
0516 L634 CAMS 02 DEN HI (S/P) OFF

```

0646 L006 CNDSR A CW INLT WB1 1.2 DEGC NORMAL RETURN
0647 L006 CNDSR A CW INLT WB1 0.9< 1.0 DEGC
0653 L006 CNDSR A CW INLT WB1 1.2 DEGC NORMAL RETURN
0653 L006 CNDSR A CW INLT WB1 0.9< 1.0 DEGC
0654 L006 CNDSR A CW INLT WB1 1.2 DEGC NORMAL RETURN
0654 L006 CNDSR A CW INLT WB1 0.9< 1.0 DEGC
0903 L006 CNDSR A CW INLT WB1 1.2 DEGC NORMAL RETURN
0903 L006 CNDSR A CW INLT WB1 0.9< 1.0 DEGC
0936 L006 CNDSR A CW INLT WB1 2.2 DEGC NORMAL RETURN
0936 L006 CNDSR A CW INLT WB1 0.3< 1.0 DEGC
1129 L006 CNDSR A CW INLT WB1 1.2 DEGC NORMAL RETURN
1129 L006 CNDSR A CW INLT WB1 0.9< 1.0 DEGC
1129 L006 CNDSR A CW INLT WB1 1.4 DEGC NORMAL RETURN
1129 L006 CNDSR A CW INLT WB1 0.9< 1.0 DEGC
1130 L006 CNDSR A CW INLT WB1 1.2 DEGC NORMAL RETURN
1130 L006 CNDSR A CW INLT WB1 0.9< 1.0 DEGC
1130 L006 CNDSR A CW INLT WB1 1.2 DEGC NORMAL RETURN
1131 L006 CNDSR A CW INLT WB1 0.9< 1.0 DEGC
1132 L006 CNDSR A CW INLT WB1 1.2 DEGC NORMAL RETURN
1132 L006 CNDSR A CW INLT WB1 0.8< 1.0 DEGC
1132 L006 CNDSR A CW INLT WB1 1.2 DEGC NORMAL RETURN
1132 L006 CNDSR A CW INLT WB1 0.9< 1.0 DEGC
1133 L006 CNDSR A CW INLT WB1 1.2 DEGC NORMAL RETURN
1133 L006 CNDSR A CW INLT WB1 0.9< 1.0 DEGC
1135 A639 ALL CR ALL IN OFF
1159 W083 TURB ERG 12 TEMP 14.9< 15.0 DEGC
1159 L006 CNDSR A CW INLT WB1 1.2 DEGC NORMAL RETURN
1159 L006 CNDSR A CW INLT WB1 0.9< 1.0 DEGC
1159 W083 TURB ERG 12 TEMP 15.3 DEGC NORMAL RETURN
1201 A639 ALL CR ALL IN ON
1203 L006 CNDSR A CW INLT WB1 1.2 DEGC NORMAL RETURN
1203 L006 CNDSR A CW INLT WB1 0.9< 1.0 DEGC
1203 L006 CNDSR A CW INLT WB1 1.2 DEGC NORMAL RETURN
1203 L006 CNDSR A CW INLT WB1 0.9< 1.0 DEGC
1203 L006 CNDSR A CW INLT WB1 1.2 DEGC NORMAL RETURN
1203 L006 CNDSR A CW INLT WB1 0.9< 1.0 DEGC
1204 L006 CNDSR A CW INLT WB1 1.2 DEGC NORMAL RETURN
1204 L006 CNDSR A CW INLT WB1 0.8< 1.0 DEGC
1204 L006 CNDSR A CW INLT WB1 1.2 DEGC NORMAL RETURN

'11-03-19 SAT. FUKUSHIMA DAIICHI 6

1215 A639 ALL CR ALL IN OFF
1225 A639 ALL CR ALL IN ON
1225 W083 TURB ERG 12 TEMP 14.9< 15.0 DEGC
1225 W083 TURB ERG 12 TEMP 15.3 DEGC NORMAL RETURN
1228 W083 TURB ERG 12 TEMP 14.9< 15.0 DEGC
1229 W083 TURB ERG 12 TEMP 15.3 DEGC NORMAL RETURN
1310 B608 RHIR FW-V A(LPCI) OPN ON
1315 A639 ALL CR ALL IN OFF
TRIP SEQUENCE LOG 11-03-19

H	MIN	SEC	MSEC	PID	ABBREVIATION	STATUS
13	21	26	900	D612*	RLF VLV L ACTUATED	ON

END JOB

1328 W083 TURB ERG 12 TEMP 14.9< 15.0 DEGC
1329 W083 TURB ERG 12 TEMP 15.3 DEGC NORMAL RETURN
TRIP SEQUENCE LOG 11-03-19

H	MIN	SEC	MSEC	PID	ABBREVIATION	STATUS
---	-----	-----	------	-----	--------------	--------

1332 W083 TURB BRG 12 TEMP 14.9< 15.0 DEGC
1332 W083 TURB BRG 12 TEMP 15.3 DEGC NORMAL RETURN
TRIP SEQUENCE LOG 11-03-19

H MIN SEC MSEC FID ABBREVIATION STATUS
13 34 50 300 D707* REACTOR WTR LEVEL HI TRIP
END JOB

1337 B033 REC WTR LVL (N) A UP RSN
1337 B265 REC WTR LVL (N) B UP RSN
1337 B034 REC WTR LVL (N) C UP RSN
1337 B035 REC WTR LVL(N)MIDDLE UP RSN
1344 W083 TURB BRG 12 TEMP 14.9< 15.0 DEGC
1344 W083 TURB BRG 12 TEMP 15.3 DEGC NORMAL RETURN
1348 B608 RHR FW-V A(LFCI) OPN OFF
1402 W083 TURB BRG 12 TEMP 14.9< 15.0 DEGC
1402 W083 TURB BRG 12 TEMP 15.3 DEGC NORMAL RETURN
1402 W083 TURB BRG 12 TEMP 14.9< 15.0 DEGC
1403 W083 TURB BRG 12 TEMP 15.3 DEGC NORMAL RETURN
1403 A639 ALL CR ALL IN ON
1404 A639 ALL CR ALL IN OFF
1417 W083 TURB BRG 12 TEMP 14.9< 15.0 DEGC
1417 W083 TURB BRG 12 TEMP 15.3 DEGC NORMAL RETURN
1418 A639 ALL CR ALL IN ON
1419 A639 ALL CR ALL IN OFF
1456 A639 ALL CR ALL IN ON
1458 A639 ALL CR ALL IN OFF
1509 A639 ALL CR ALL IN ON
1515 W083 TURB BRG 12 TEMP 14.9< 15.0 DEGC
1519 W083 TURB BRG 12 TEMP 15.3 DEGC NORMAL RETURN
1521 A639 ALL CR ALL IN OFF
1523 W083 TURB BRG 12 TEMP 14.9< 15.0 DEGC
1530 W083 TURB BRG 12 TEMP 15.3 DEGC NORMAL RETURN
1533 W083 TURB BRG 12 TEMP 14.9< 15.0 DEGC
1545 W083 TURB BRG 12 TEMP 15.3 DEGC NORMAL RETURN
1545 W083 TURB BRG 12 TEMP 14.9< 15.0 DEGC
1546 W083 TURB BRG 12 TEMP 15.3 DEGC NORMAL RETURN
1618 W083 TURB BRG 12 TEMP 14.9< 15.0 DEGC
1618 W083 TURB BRG 12 TEMP 15.3 DEGC NORMAL RETURN
1623 W083 TURB BRG 12 TEMP 14.9< 15.0 DEGC
1623 W083 TURB BRG 12 TEMP 15.3 DEGC NORMAL RETURN
1633 A639 ALL CR ALL IN ON
1655 W083 TURB BRG 12 TEMP 14.9< 15.0 DEGC
1657 W083 TURB BRG 12 TEMP 15.3 DEGC NORMAL RETURN
1702 W083 TURB BRG 12 TEMP 14.9< 15.0 DEGC
1702 W083 TURB BRG 12 TEMP 15.3 DEGC NORMAL RETURN
1708 W083 TURB BRG 12 TEMP 14.9< 15.0 DEGC
1708 W083 TURB BRG 12 TEMP 15.3 DEGC NORMAL RETURN
1733 W083 TURB BRG 12 TEMP 14.9< 15.0 DEGC
1734 W083 TURB BRG 12 TEMP 15.3 DEGC NORMAL RETURN
1737 W083 TURB BRG 12 TEMP 14.9< 15.0 DEGC
1738 W083 TURB BRG 12 TEMP 15.3 DEGC NORMAL RETURN
1743 W083 TURB BRG 12 TEMP 14.9< 15.0 DEGC
1744 W083 TURB BRG 12 TEMP 15.3 DEGC NORMAL RETURN
1745 W083 TURB BRG 12 TEMP 14.9< 15.0 DEGC
1747 W083 TURB BRG 12 TEMP 15.3 DEGC NORMAL RETURN
1754 W083 TURB BRG 12 TEMP 14.9< 15.0 DEGC
1755 W083 TURB BRG 12 TEMP 15.3 DEGC NORMAL RETURN
1755 W083 TURB BRG 12 TEMP 14.9< 15.0 DEGC
1757 W083 TURB BRG 12 TEMP 15.3 DEGC NORMAL RETURN
1758 W083 TURB BRG 12 TEMP 14.9< 15.0 DEGC
1801 W083 TURB BRG 12 TEMP 15.3 DEGC NORMAL RETURN

1814	W083	TURB	BRG	12	TEMP	14.9<	15.0	DEGC	
1812	W083	TURB	BRG	12	TEMP	15.3	DEGC	NORMAL	RETURN
1818	W083	TURB	BRG	12	TEMP	14.9<	15.0	DEGC	
1820	W083	TURB	BRG	12	TEMP	15.3	DEGC	NORMAL	RETURN
1823	W083	TURB	BRG	12	TEMP	14.9<	15.0	DEGC	
1829	W083	TURB	BRG	12	TEMP	15.3	DEGC	NORMAL	RETURN
1833	W083	TURB	BRG	12	TEMP	14.9<	15.0	DEGC	
1834	W083	TURB	BRG	12	TEMP	15.3	DEGC	NORMAL	RETURN
1835	W083	TURB	BRG	12	TEMP	14.9<	15.0	DEGC	
1838	W083	TURB	BRG	12	TEMP	15.3	DEGC	NORMAL	RETURN
1843	W083	TURB	BRG	12	TEMP	14.9<	15.0	DEGC	
1845	W083	TURB	BRG	12	TEMP	15.3	DEGC	NORMAL	RETURN
1846	W083	TURB	BRG	12	TEMP	14.9<	15.0	DEGC	
1847	W083	TURB	BRG	12	TEMP	15.3	DEGC	NORMAL	RETURN
1847	W083	TURB	BRG	12	TEMP	14.9<	15.0	DEGC	
1847	W083	TURB	BRG	12	TEMP	15.3	DEGC	NORMAL	RETURN
1847	W083	TURB	BRG	12	TEMP	14.9<	15.0	DEGC	
1848	W083	TURB	BRG	12	TEMP	15.3	DEGC	NORMAL	RETURN
1855	W083	TURB	BRG	12	TEMP	14.9<	15.0	DEGC	
1859	W083	TURB	BRG	12	TEMP	15.3	DEGC	NORMAL	RETURN
1859	W083	TURB	BRG	12	TEMP	14.9<	15.0	DEGC	
1902	W083	TURB	BRG	12	TEMP	15.3	DEGC	NORMAL	RETURN
1902	W083	TURB	BRG	12	TEMP	14.9<	15.0	DEGC	
1904	W083	TURB	BRG	12	TEMP	15.3	DEGC	NORMAL	RETURN
1904	W083	TURB	BRG	12	TEMP	14.9<	15.0	DEGC	
1907	W083	TURB	BRG	12	TEMP	15.3	DEGC	NORMAL	RETURN
1907	W083	TURB	BRG	12	TEMP	14.9<	15.0	DEGC	
1908	W083	TURB	BRG	12	TEMP	15.4	DEGC	NORMAL	RETURN
1910	W083	TURB	BRG	12	TEMP	14.9<	15.0	DEGC	
1919	W083	TURB	BRG	12	TEMP	15.3	DEGC	NORMAL	RETURN
1919	W083	TURB	BRG	12	TEMP	14.9<	15.0	DEGC	
1919	W083	TURB	BRG	12	TEMP	15.3	DEGC	NORMAL	RETURN
1920	W083	TURB	BRG	12	TEMP	14.9<	15.0	DEGC	
1921	W083	TURB	BRG	12	TEMP	15.3	DEGC	NORMAL	RETURN
1921	W083	TURB	BRG	12	TEMP	14.9<	15.0	DEGC	
1921	W083	TURB	BRG	12	TEMP	15.3	DEGC	NORMAL	RETURN
1950	W083	TURB	BRG	12	TEMP	14.9<	15.0	DEGC	
1953	W083	TURB	BRG	12	TEMP	15.3	DEGC	NORMAL	RETURN
2000	W083	TURB	BRG	12	TEMP	14.9<	15.0	DEGC	
2008	W083	TURB	BRG	12	TEMP	15.3	DEGC	NORMAL	RETURN
2009	W083	TURB	BRG	12	TEMP	14.9<	15.0	DEGC	
2015	W083	TURB	BRG	12	TEMP	15.3	DEGC	NORMAL	RETURN
2016	W083	TURB	BRG	12	TEMP	14.9<	15.0	DEGC	
2017	W083	TURB	BRG	12	TEMP	15.3	DEGC	NORMAL	RETURN
2017	W083	TURB	BRG	12	TEMP	14.9<	15.0	DEGC	
2017	W083	TURB	BRG	12	TEMP	15.3	DEGC	NORMAL	RETURN
2018	W083	TURB	BRG	12	TEMP	14.9<	15.0	DEGC	
2033	W083	TURB	BRG	12	TEMP	15.3	DEGC	NORMAL	RETURN
2037	W083	TURB	BRG	12	TEMP	14.9<	15.0	DEGC	
2039	W083	TURB	BRG	12	TEMP	15.3	DEGC	NORMAL	RETURN
2042	W083	TURB	BRG	12	TEMP	14.9<	15.0	DEGC	
2046	W083	TURB	BRG	12	TEMP	15.3	DEGC	NORMAL	RETURN
2048	W083	TURB	BRG	12	TEMP	14.9<	15.0	DEGC	
2054	W083	TURB	BRG	12	TEMP	15.3	DEGC	NORMAL	RETURN
2058	W083	TURB	BRG	12	TEMP	14.9<	15.0	DEGC	
2104	W083	TURB	BRG	12	TEMP	15.3	DEGC	NORMAL	RETURN
2104	W083	TURB	BRG	12	TEMP	14.9<	15.0	DEGC	
2107	W083	TURB	BRG	12	TEMP	15.3	DEGC	NORMAL	RETURN
2107	W083	TURB	BRG	12	TEMP	14.9<	15.0	DEGC	
2113	W083	TURB	BRG	12	TEMP	15.3	DEGC	NORMAL	RETURN
2113	W083	TURB	BRG	12	TEMP	14.8<	15.0	DEGC	
2126	W083	TURB	BRG	12	TEMP	15.3	DEGC	NORMAL	RETURN

8 END

2127 W083 TURB BRG 12 TEMP 14.9< 15.0 DEGC
2128 W083 TURB BRG 12 TEMP 15.3 DEGC NORMAL RETURN
2129 W083 TURB BRG 12 TEMP 14.9< 15.0 DEGC
2143 W083 TURB BRG 12 TEMP 15.3 DEGC NORMAL RETURN
2143 W083 TURB BRG 12 TEMP 14.9< 15.0 DEGC
2143 W083 TURB BRG 12 TEMP 15.3 DEGC NORMAL RETURN
2143 W083 TURB BRG 12 TEMP 14.9< 15.0 DEGC
2147 W083 TURB BRG 12 TEMP 15.3 DEGC NORMAL RETURN
2147 W083 TURB BRG 12 TEMP 14.9< 15.0 DEGC
2149 W083 TURB BRG 12 TEMP 15.3 DEGC NORMAL RETURN
2149 W083 TURB BRG 12 TEMP 14.9< 15.0 DEGC
2203 W083 TURB BRG 12 TEMP 15.3 DEGC NORMAL RETURN
2203 W083 TURB BRG 12 TEMP 14.9< 15.0 DEGC
TRIP SEQUENCE LOG 11-03-19

H	MIN	SEC	MSEC	PID	ABBREVIATION	STATUS
22	11	01	050	D581*	RHR PUMP BREAKER B	CLSD
22	11	12	520	D589	RHR LOOP B FLOW HIGH	ON

END JOB

2236 W083 TURB BRG 12 TEMP 15.3 DEGC NORMAL RETURN
2236 W083 TURB BRG 12 TEMP 14.9< 15.0 DEGC
2258 W083 TURB BRG 12 TEMP 15.3 DEGC NORMAL RETURN
2302 W083 TURB BRG 12 TEMP 14.9< 15.0 DEGC
2303 W083 TURB BRG 12 TEMP 15.3 DEGC NORMAL RETURN
2312 W083 TURB BRG 12 TEMP 14.9< 15.0 DEGC
2312 W083 TURB BRG 12 TEMP 15.3 DEGC NORMAL RETURN
2315 W083 TURB BRG 12 TEMP 14.9< 15.0 DEGC
2315 W083 TURB BRG 12 TEMP 15.3 DEGC NORMAL RETURN
2347 B101 S/P LEVEL 1-2 -12.0 / -7.0 CM INSERT T.DISPLAY ITEM