

The result of the nuclide analysis of the seawater

(Data collected on March 30th)

Time and date of sample collection	14:10, March 29th, 2011			
Place of collection	Around the discharge canal (north) of Unit 5 and 6 Fukushima Daiichi Nuclear Power Station (approx. 30m north from the discharge canal of Unit 5 and 6)			
Manner of measurement	Measuring 500 ml of the sample with the Germanium semi-conductor detector			
Measurement time	1,000 seconds			
Nuclide of detection (half-life)	Density of sample (Bq/cm ³)	Detection limit density (Bq/cm ³)	Statutory reactor density limit Bq/cm ³	Scaling factor (/)
Tc-99m (About 6hours)	6.4E-02	4.9E-02	4.0E+01	0.0
I-131 (About 8 days)	5.1E+01	5.2E-02	4.0E-02	1262.5
Cs-134 (About 2 years)	1.2E+01	4.6E-02	6.0E-02	202.2
Cs-136 (About 13 days)	1.1E+00	4.3E-02	3.0E-01	3.6
Cs-137 (About 30 years)	1.2E+01	3.9E-02	9.0E-02	137.0
Ba-140 (About 13 days)	2.0E+00	1.8E-01	3.0E-01	6.7
La-140 (About 2 days)	6.9E-01	1.3E-02	4.0E-01	1.7

. E - means . × 1 0 - .