

The result of the nuclide analysis of the seawater for reference

(Data collected on April 5th)

Time and date of sample collection	11:55, April 4th, 2011			
Place of collection	Around 15km off shore of Iwasawa Sea Shore			
Manner of measurement	Measuring 500 ml of the sample with the Germanium semi-conductor detector			
Measurement time	1,000 seconds			
Nuclide of detection (half-life)	Density of sample (Bq/cm ³)	Detection limit density (Bq/cm ³)	Statutory reactor density limit Bq/cm ³	scaling factor (/)
I-131 (About 8days)	4.7E-02	1.4E-02	4E-02	1.2

. E - means . x 1 0 - .