

Fukushima Daiichi: The result of the nuclide analysis of the groundwater in the sub drainage Reference

(Date collected on April 8th)

Time and date of sample collection	11:30, April 6th	11:40, April 6th	11:05, April 6th	10:55, April 6th	11:50, April 6th	12:05, April 6th	10:30, April 7th
Place of collection	Sub drainage of Unit 1 of Fukushima Daiichi	Sub drainage of Unit 2 of Fukushima Daiichi	Sub drainage of Unit 3 of Fukushima Daiichi	Sub drainage of Unit 4 of Fukushima Daiichi	Sub drainage of Unit 5 of Fukushima Daiichi	Sub drainage of Unit 6 of Fukushima Daiichi	Deep well at the site of Fukushima Daiichi
Nuclide of detection (half-life)	Density of sample (Bq/cm <sup>3</sup> )						
I-131 (About 8 days)	7.2E+01	3.6E+01	7.1E+00	2.4E+01	1.4E+00	6.9E-01	7.9E-02
Cs-134 (About 2 years)	1.4E+00	9.4E-01	2.0E+00	1.8E+00	8.5E-01	4.6E-01	2.4E-02
Cs-137 (About 30 years)	1.6E+00	1.0E+00	2.1E+00	1.9E+00	9.2E-01	5.0E-01	3.3E-02

. E - means . × 1 0 - .  
 Data of other nuclides is under examination.