

The result of the nuclide analysis of radioactive materials in the air at the site of Fukushima Nuclear Power Station

Reference

(Data collected on April 19th)

Place of sampling		West gate of Fukushima Daiichi		MP-1 of Fukushima Daini (Reference)				Density limit in the air to workers engaged in tasks associated with radiation (Bq/cm ³)	
Date and time of sampling		11:30-11:50 am April 17th, 2011		8:48-8:56 am April 17th, 2011		3:47-3:55 pm April 17th, 2011			
Detected nuclide (half-life)		Radioactivity density (Bq/cm ³)	Scaling factor (/)	Radioactivity density (Bq/cm ³)	Scaling factor (/)	Radioactivity density (Bq/cm ³)	Scaling factor (/)		
Volatile	I-131 (約8日)	7.1E-05	0.07	2.1E-05	0.02	2.2E-05	0.02	1E-03	
	Cs-134 (約2年)	1.6E-05	0.01	1.0E-05	0.01	1.0E-05	0.01	2E-03	
	Cs-137 (約30年)	1.4E-05	0.00	1.3E-05	0.00	7.8E-06	0.00	3E-03	
Particle	I-131 (約8日)	3.2E-05	0.03	1.2E-05	0.01	9.5E-06	0.01	1E-03	
	Cs-134 (約2年)	ND	-	ND	-	7.1E-06	0.00	2E-03	
	Cs-137 (約30年)	6.0E-06	0.00	ND	-	6.6E-06	0.00	3E-03	

Statutory density limit to the 3-month average density of radioactive nuclides contained in the air that humans breathe.

. E - means . x 10 -

Data of other nuclides are under examination.