

TEPCO Plant Status of Fukushima Daini Nuclear Power Station (as of 4:00 pm April 23rd)

Appendix

	Unit 1	Unit 2	Unit 3	Unit 4
Shutdown	Automatic shutdown (at 2:48 pm on March 11th) All control rods are all inserted	Automatic shutdown (at 2:48 pm on March 11th) All control rods are all inserted	Automatic shutdown (at 2:48 pm on March 11th) All control rods are all inserted	Automatic shutdown (at 2:48 pm on March 11th) All control rods are all inserted
Cooling	Residual heat removal system (B) is in operation (From March 14th) Residual heat removal system (A) was disabled due to the tsunami Cold shutdown * (From March 14th)	Residual heat removal system (B) is in operation (From March 14th) Residual heat removal system (A) was disabled due to the tsunami Cold shutdown * (From March 14th)	Residual heat removal system (B) is in operation (From March 12th) Residual heat removal system (A) was disabled due to the tsunami Cold shutdown * (From March 12th)	Residual heat removal system (B) operating (From March 14th) Residual heat removal system (A) was disabled due to the tsunami Cold shutdown * (From March 15th)
Containment	No reactor coolant is leaked in the reactor containment vessel Water temperature in the suppression chamber is stable (generally 30). (On March 14th, achieved below 100) Containment vessel venting (measurement to decrease the pressure in the containment vessel) is not implemented	No reactor coolant is leaked in the reactor containment vessel Water temperature in the suppression chamber is stable (generally 30). (On March 14th, achieved below 100) Containment vessel venting (measurement to decrease the pressure in the containment vessel) is not implemented	No reactor coolant is leaked in the reactor containment vessel Water temperature in the suppression chamber is stable (generally 30). (Maintain below 100 as before the earthquake occurred) Containment vessel venting (measurement to decrease the pressure in the containment vessel) is not implemented	No reactor coolant is leaked in the reactor containment vessel Water temperature in the suppression chamber is stable (generally 30). (On March 14th, achieved below 100) Containment vessel venting (measurement to decrease the pressure in the containment vessel) is not implemented
Offsite power	Functioning	Functioning	Functioning	Functioning
Emergency power source system	Receiving electricity from the bus of an emergency diesel generator (B) or (H) of Unit 2 and from the bus of an emergency diesel generator (B) of Unit 3	Emergency diesel generator (B) (H)	Emergency diesel generator (B) (H)	Emergency diesel generator (B) (H)
Others, any reports regarding abnormal matters	At 5:35 pm on March 11th, Occurrence of a Specific Incident Stipulated in Article 10 of the Act on Special Measures Concerning Nuclear Emergency Preparedness (reactor coolant is leaked (pressure in the reactor containment vessel increased))			
	At 6:33 pm on March 11th, Occurrence of a Specific Incident Stipulated in Article 10 of the Act on Special Measures Concerning Nuclear Emergency Preparedness (function of reactor coolant was lost) At 1:24 am on March 14th, the function of rea	At 6:33 pm on March 11th, Occurrence of a Specific Incident Stipulated in Article 10 of the Act on Special Measures Concerning Nuclear Emergency Preparedness (function of reactor coolant was lost) At 7:13 am on March 14th, the function of rea		At 6:33 pm on March 11th, Occurrence of a Specific Incident Stipulated in Article 10 of the Act on Special Measures Concerning Nuclear Emergency Preparedness (function of reactor coolant was lost) At 3:42 pm on March 14th, the function of rea
	At 5:22 am on March 12th, Occurrence of a Specific Incident Stipulated in Article 15 of the Act on Special Measures Concerning Nuclear Emergency Preparedness (function of the suppression chamber was lost) At 10:15 am on March 14th, the function	At 5:32 am on March 12th, Occurrence of a Specific Incident Stipulated in Article 15 of the Act on Special Measures Concerning Nuclear Emergency Preparedness (function of the suppression chamber was lost) At 3:52 pm on March 14th, the function		At 6:07 am on March 12th, Occurrence of a Specific Incident Stipulated in Article 15, of the Act on Special Measures Concerning Nuclear Emergency Preparedness (function of the suppression chamber was lost) At 7:15 am on March 15th, the function
	Occurrence of a Specific Incident Stipulated in Article 10 of the Act on Special Measures Concerning Nuclear Emergency Preparedness (increase in radioactive material at the boundary of the site [above 5 μSv/h] At 10:07 pm on March 14th at the monitoring			

* : Cold shutdown . . . Achieved shutdown and maintain average water temperature below 100 in the Pressure Suppression Chamber.