

Fukushima Daiichi Nuclear Power Station : Results of Nuclide Analysis of Sub-drain

Reference

(Data summarized on April 26th)

Place of sampling	Sub-drain of Unit1, Fukushima Daiichi	Sub-drain of Unit2, Fukushima Daiichi	Sub-drain of Unit3, Fukushima Daiichi	Sub-drain of Unit4, Fukushima Daiichi	Sub-drain of Unit5, Fukushima Daiichi	Sub-drain of Unit6, Fukushima Daiichi	Deep well, Fukushima Daiichi
Time and Date of sample collection	10:05, April 25th, 2011	10:10, April 25th, 2011	9:55, April 25th, 2011	11:21, April 25th, 2011	10:20, April 25th, 2011	10:24, April 25th, 2011	8:51, April 25th, 2011
Detected Nuclides (Half-life)	Density of Sample (Bq/cm <sup>3</sup> )						
I-131 (about 8 days)	1.3E+02	6.1E+02	2.0E+01	9.3E-02	1.3E-01	3.8E-01	ND
Cs-134 (about 2 years)	5.5E+01	3.3E+01	3.9E+00	1.2E-01	2.5E-01	3.3E-01	ND
Cs-137 (about 30 years)	6.4E+01	3.7E+01	4.2E+00	1.3E-01	3.1E-01	3.9E-01	ND

※ 〇.〇E-〇 means 〇.〇 × 10<sup>-〇</sup>.

※ Data of other nuclides are under evaluation.