

The result of the nuclide analysis of radioactive materials in the air
at the site of Fukushima Nuclear Power Station

Reference

(Data summarized on April 27)

Place of sampling		West gate of Fukushima Daiichi		MP-1 of Fukushima Daini (Reference)				②Density limit in the air to workers engaged in tasks associated with radiation (Bq/cm3) ※	
Date and time of sampling		11:25 am – 11:45 am April 26th, 2011		9:09 am – 9:16 am April 26th, 2011		3:20 pm – 3:27 pm April 26th, 2011			
Detected nuclide (half-life)		①Radioactivity density (Bq/cm3)	Scaling factor (①/②)	①Radioactivity density (Bq/cm3)	Scaling factor (①/②)	①Radioactivity density (Bq/cm3)	Scaling factor (①/②)		
Volatile	I-131 (approx. 8 days)	5.0E-05	0.05	1.1E-05	0.01	1.1E-05	0.01	1E-03	
	Cs-134 (approx. 2 years)	1.2E-05	0.01	9.8E-06	0.00	9.5E-06	0.00	2E-03	
	Cs-137 (approx 30 years)	1.4E-05	0.00	1.1E-05	0.00	1.5E-05	0.01	3E-03	
Particle	I-131 (approx. 8 days)	4.0E-05	0.04	5.6E-06	0.01	9.5E-06	0.01	1E-03	
	Cs-134 (approx. 2 years)	9.7E-06	0.00	3.6E-06	0.00	ND	-	2E-03	
	Cs-137 (approx. 30 years)	1.0E-05	0.00	6.1E-06	0.00	ND	-	3E-03	

※ Statutory density limit to the 3-month average density of radioactive nuclides contained in the air that humans breathe.

※ O.OE–O means O.O x 10–O

※ Data of other nuclides are under examination.