

Result of Nuclide Analyses of Radioactive Materials in the Air
at the Site of Fukushima Nuclear Power Stations

Reference

(Data summarized on May 2)

Place of sampling		West gate of Fukushima Daiichi		MP-1 of Fukushima Daini (Reference)				Density limit in the air to workers engaged in tasks associated with radiation (Bq/cm ³)
Date and time of sampling		11:30 am - 11:50 am May 1, 2011		9:34 am - 9:42 am May 1, 2011		3:57 pm - 4:05 pm May 1, 2011		
Detected nuclide (half-life)		Radioactivity density (Bq/cm ³)	Scaling factor (/)	Radioactivity density (Bq/cm ³)	Scaling factor (/)	Radioactivity density (Bq/cm ³)	Scaling factor (/)	
Volatile	I-131 (approx. 8 days)	2.3E-05	0.02	5.9E-06	0.01	4.1E-06	0.00	1E-03
	Cs-134 (approx. 2 years)	1.7E-05	0.01	8.5E-06	0.00	6.8E-06	0.00	2E-03
	Cs-137 (approx. 30 years)	1.7E-05	0.01	9.0E-06	0.00	1.0E-05	0.00	3E-03
Particle	I-131 (approx. 8 days)	1.2E-05	0.01	4.2E-06	0.00	6.9E-06	0.01	1E-03
	Cs-134 (approx. 2 years)	1.6E-05	0.01	ND	-	ND	-	2E-03
	Cs-137 (approx. 30 years)	2.3E-05	0.01	ND	-	ND	-	3E-03

Statutory density limit to the 3-month average density of radioactive nuclides contained in the air that humans breathe.

. E - means . x 10 -

Data of other nuclides are under examination.