

Results of Nuclide Analyses of Sub-drains

Reference

(Data summarized on May 5)

Place of sampling	Sub-drain of Unit1, Fukushima Daiichi	Sub-drain of Unit2, Fukushima Daiichi	Sub-drain of Unit3, Fukushima Daiichi	Sub-drain of Unit4, Fukushima Daiichi	Sub-drain of Unit5, Fukushima Daiichi	Sub-drain of Unit6, Fukushima Daiichi	Deep well, Fukushima Daiichi
Time and Date of Sample Collection	At 10:53 am May 4, 2011	At 10:59 am May 4, 2011	At 11:03 am May 4, 2011	At 11:14 am May 4, 2011	At 10:43 am May 4, 2011	At 10:36 am May 4, 2011	At 9:20 am May 4, 2011
Detected Nuclides (Half-life)	Radioactivity Density of Sample (Bq/cm3)						
I-131 (about 8 days)	1.5E+01	1.5E+02	1.1E+01	2.2E-02	1.5E-02	6.0E-02	ND
Cs-134 (about 2 years)	2.1E+01	1.6E+01	1.7E+00	9.0E-02	ND	6.5E-02	ND
Cs-137 (about 30 years)	2.4E+01	1.8E+01	1.8E+00	9.2E-02	2.7E-02	6.6E-02	ND

. E - means . × 1 0 .

Data of other nuclides are under evaluation.