Results of Nuclide Analysis of Seawater <Coast>

Reference

(Data s	summarized	on	May	5)	
---------	------------	----	-----	----	--

Place of Sampling			hannel of 5-6u c -6u discharge cl				arge Channel of 1-4u Discharge (Around North Channel o (Around 3,4u Channel (approx. 10 km	f 2F Discharge)	Around Iwasawa Shore of 2F (appox. 7 km south of 1,2u Discharge Channel) (appox. 16 km from 1F)		Density limit by the announcement of Reactor Regulation (Bq/cm3)	
Time and Date of Sample Collection	At 9:10 May 4, 20		At 14:0 May 4, 20		At 8:45 May 4, 20		At 13:30 May 4, 20		At 8:4 May 4, 2		May 4, 2011		(the density limit in the water outside of	
Detected Nuclides (Half-life)	Density of Sample (Bq/cm ³)	Scaling Factor (/)	Density of Sample (Bq/cm ³)	Scaling Factor (/)	Density of Sample (Bq/cm ³)	Scaling Factor (/)	Density of Sample (Bq/cm ³)	Scaling Factor (/)	Density of Sample (Bq/cm ³)	Scaling Factor (/)	Density of Sample (Bq/cm ³)	Scaling Factor (/)	surrounding monitored areas in the section 6 of the appendix 2)	
l-131 (about 8 days)	9.8E-03	0.25	1.1E-02	0.28	8.6E-03	0.22	1.7E-02	0.43	ND	-	ND	-	4E-02	
Cs-134 (about 2 years)	8.5E-02	1.4	8.4E-02	1.4	8.5E-02	1.4	7.8E-02	1.3	3.5E-02	0.58	4.2E-02	0.70	6E-02	
Cs-137 (about 30 years)	9.3E-02	1.0	9.0E-02	1.0	7.6E-02	0.84	8.5E-02	0.94	2.6E-02	0.29	3.3E-02	0.37	9E-02	

. E - means . ×10^{- .}

Data of other nuclides are under evaluation.

In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

Results of Nuclide Analysis of Seawater <Offshore>

(Data summarized on May 5)

											(Data S	uiiiiai i	zeu on may 5)	
Place of Sampling	15 km offshore of MinamiSouma City		15 km offshore of Ukedo-gawa		15 km offshore of Fukushima Daiichi		15 km offshore of Fukushima Daini		15 km offshore of Iwasawa Shore		15 km offshore of Hirono-machi		Density limit by the announcement of	
Time and Date of Sample Collection	At 9:2 May 4, 2		At 9:0 May 4, 2		At 8:4 May 4, 2		At 8:1 May 4, 2		At 7:4 May 4, 2		At 7:15 May 4, 2011		Reactor Regulation (Bq/cm3) (the density limit in the	
Detected Nuclides (Half-life)	Density of Sample (Bq/cm ³)	Scaling Factor (/)	Density of Sample (Bq/cm ³)	Scaling Factor (/)	Density of Sample (Bq/cm ³)	Scaling Factor (/)	Density of Sample (Bq/cm ³)	Scaling Factor (/)	Density of Sample (Bq/cm ³)	Scaling Factor (/)	Density of Sample (Bq/cm ³)	Scaling Factor (/)	water outside of surrounding monitored areas in the section 6 of the appendix 2)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	3.4E-03	0.09	3.6E-03	0.09	4E-02	
Cs-134 (about 2 years)	1.6E-02	0.27	1.7E-02	0.28	ND	-	ND	-	1.1E-02	0.18	9.8E-03	0.16	6E-02	
Cs-137 (about 30 years)	1.5E-02	0.17	2.0E-02	0.22	2.3E-02	0.26	ND	-	1.5E-02	0.17	1.4E-02	0.16	9E-02	

E - means ×10 Data of other nuclides are under evaluation.

In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

Place of Sampling	3 km offshore of Haramachi-ku Odaka-ku		3 km offshore of Iwasawa Shore		3 km offshore of North of Iwaki City		8 km offshore of Odaka-ku		8 km offshore of Iwasawa Shore		Density limit by the announcement of Reactor Regulation		
Time and Date of Sample Collection	At 9:5 May 4, 2		At 10: May 4, 2		At 8:0 May 4, 2		At 7:3 May 4, 2	-	At 9:5 May 4, 2		At 8:3 May 4, 2		(Bq/cm3) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Detected Nuclides (Half-life)	Density of Sample (Bq/cm ³)	Scaling Factor (/)	Density of Sample (Bq/cm ³)	Scaling Factor (/)	Density of Sample (Bq/cm ³)	Scaling Factor (/)	Density of Sample (Bq/cm ³)	Scaling Factor (/)	Density of Sample (Bq/cm ³)	Scaling Factor (/)	Density of Sample (Bq/cm ³)	Scaling Factor (/)	
I-131 (about 8 days)	3.0E-03	0.08	ND	-	ND	-	5.2E-03	0.13	ND	-	3.5E-03	0.09	4E-02
Cs-134 (about 2 years)	7.2E-03	0.12	2.0E-02	0.33	1.9E-02	0.32	1.5E-02	0.25	3.3E-02	0.55	2.2E-02	0.37	6E-02
Cs-137 (about 30 years)	9.3E-03	0.10	ND	-	1.8E-02	0.20	2.0E-02	0.22	2.2E-02	0.24	1.5E-02	0.17	9E-02

. E - means . ×10

Data of other nuclides are under evaluation.

In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

Place of Sampling	3 km offsl Natsui R		3 km offshore of Onahama Port		3 km offshore of Ena		3 km offs Numano		3 km offshore of Toyoma				Density limit by the announcement of Reactor Regulation	
Time and Date of Sample Collection	At 7:0 May 4, 2		At 5:4 May 4, 2		At 6:0 May 4, 2		At 6:4 May 4, 2		At 6:2 May 4, 2				(Bq/cm3) (the density limit	
Detected Nuclides (Half-life)	Density of Sample (Bq/cm ³)	Scaling Factor (/)	Density of Sample (Bq/cm ³)	Scaling Factor (/)	Density of Sample (Bq/cm ³)	Scaling Factor (/)	Density of Sample (Bq/cm ³)	Scaling Factor (/)	Density of Sample (Bq/cm ³)	Scaling Factor (/)	Density of Sample (Bq/cm ³)	Scaling Factor (/)	in the water outside of surrounding monitored areas in the section 6 of the appendix 2)	
I-131 (about 8 days)	ND	-	2.8E-03	0.07	ND	-	ND	-	ND	-			4E-02	
Cs-134 (about 2 years)	ND	-			6E-02									
Cs-137 (about 30 years)	ND	-	ND	-	ND	-	ND	-	5.9E-03	0.07			9E-02	

. E - means . ×10

Data of other nuclides are under evaluation.

In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.