

Results of Nuclide Analyses of Sub-drains

Reference

(Data summarized on May 7)

Place of sampling	Sub-drain of Unit1, Fukushima Daiichi	Sub-drain of Unit2, Fukushima Daiichi	Sub-drain of Unit3, Fukushima Daiichi	Sub-drain of Unit4, Fukushima Daiichi	Sub-drain of Unit5, Fukushima Daiichi	Sub-drain of Unit6, Fukushima Daiichi	Deep well, Fukushima Daiichi
Time and Date of Sample Collection	14:15 May 6, 2011	14:25 May 7, 2011	14:31 May 8, 2011	11:17 May 9, 2011	14:03 May 10, 2011	13:46 May 11, 2011	10:20 May 12, 2011
Detected Nuclides (Half-life)	Radioactivity Density of Sample (Bq/cm3)						
I-131 (about 8 days)	7.1E+00	1.4E+02	5.8E+00	1.6E-02	1.5E-02	4.0E-02	ND
Cs-134 (about 2 years)	1.4E+01	1.5E+01	9.0E-01	6.2E-02	ND	4.9E-02	ND
Cs-137 (about 30 years)	1.7E+01	1.8E+01	9.5E-01	4.9E-02	2.2E-02	6.9E-02	ND

. E - means . x10.

Data of other nuclides are under evaluation.