

【 Definite Report 】 Results of Nuclide Analyses of Sub-drains

Place of sampling	Sub-drain of Unit1, Fukushima Daiichi	Sub-drain of Unit2, Fukushima Daiichi	Sub-drain of Unit3, Fukushima Daiichi	Sub-drain of Unit4, Fukushima Daiichi	Sub-drain of Unit5, Fukushima Daiichi	Sub-drain of Unit6, Fukushima Daiichi	Deep well, Fukushima Daiichi
Time and Date of Sample Collection	At 11:30 April 6, 2011	At 11:40 April 6, 2011	At 11:05 April 6, 2011	At 10:55 April 6, 2011	At 11:50 April 6, 2011	At 12:05 April 6, 2011	At 10:30 April 6, 2011
Detected Nuclides (Half-life)	Radioactivity Density of Sample (Bq/cm ³)						
Nb-95 (about 35 days)	ND	1.3E-02	ND	ND	ND	ND	ND
Ag-110m (about 250 days)	ND	ND	ND	ND	ND	ND	ND
Te-129 (about 70 hours)	ND	ND	ND	ND	ND	ND	ND
Te-129m (about 34 days)	ND	1.9E-02	ND	ND	ND	ND	ND
I-131 (about 8 days)	7.2E+00	3.6E+01	7.1E+00	2.4E+01	1.4E+00	6.9E-01	7.9E-02
I-132 (about 2 hours)	ND	ND	2.3E-01	3.8E-02	4.6E-02	ND	ND
Te-132 (about 78 hours)	ND	6.8E-02	2.7E-02	ND	2.1E-02	2.1E-02	ND
Cs-134 (about 2 years)	1.4E+00	9.4E-01	2.0E+00	1.8E+00	8.5E-01	4.6E-01	2.4E-02
Cs-136 (about 13 days)	6.4E-02	4.6E-02	1.3E-01	1.1E-01	5.5E-02	2.8E-02	ND
Cs-137 (about 30 years)	1.6E+00	1.0E+00	2.1E+00	1.9E+00	9.2E-01	5.0E-01	3.3E-02
Ba-140 (about 13 days)	ND	ND	ND	ND	ND	ND	ND
La-140 (about 40 hours)	ND	1.9E-02	2.5E-02	ND	ND	ND	ND

※ 0.0E-0 means 0.0×10⁻⁰.

【 Definite Report 】 Results of Nuclide Analyses of Sub-drains

Place of sampling	Sub-drain of Unit1, Fukushima Daiichi	Sub-drain of Unit2, Fukushima Daiichi	Sub-drain of Unit3, Fukushima Daiichi	Sub-drain of Unit4, Fukushima Daiichi	Sub-drain of Unit5, Fukushima Daiichi	Sub-drain of Unit6, Fukushima Daiichi	Deep well, Fukushima Daiichi
Time and Date of Sample Collection	At 11:30 April 13, 2011	At 11:50 April 13, 2011	At 11:25 April 13, 2011	At 11:20 April 13, 2011	At 12:00 April 13, 2011	At 12:10 April 13, 2011	At 10:05 April 13, 2011
Detected Nuclides (Half-life)	Radioactivity Density of Sample (Bq/cm ³)						
Nb-95 (about 35 days)	ND	ND	ND	ND	ND	ND	ND
Ag-110m (about 250 days)	ND	ND	ND	ND	ND	ND	ND
Te-129 (about 70 hours)	ND	ND	ND	ND	ND	ND	ND
Te-129m (about 34 days)	2.9E+01	ND	9.6E-01	8.3E-01	ND	ND	ND
I-131 (about 8 days)	4.0E+02	6.1E+02	3.6E+00	1.7E+01	1.6E-01	1.9E-01	ND
I-132 (about 2 hours)	ND	ND	4.0E-02	2.3E-02	ND	ND	ND
Te-132 (about 78 hours)	7.9E-01	ND	ND	ND	ND	ND	ND
Cs-134 (about 2 years)	5.3E+01	7.9E+00	2.4E+00	2.7E+00	2.7E-01	2.6E-01	ND
Cs-136 (about 13 days)	2.1E+00	2.6E-01	1.0E-01	1.1E-01	1.3E-02	1.1E-02	ND
Cs-137 (about 30 years)	6.0E+01	9.1E+00	2.4E+00	2.7E+00	2.8E-01	2.8E-01	ND
Ba-140 (about 13 days)	ND	4.8E-01	ND	ND	ND	ND	ND
La-140 (about 40 hours)	8.5E-01	1.7E-01	2.0E-02	ND	ND	ND	ND

※ 〇.OE-〇 means 〇.O×10-〇.

【 Definite Report 】 Results of Nuclide Analyses of Sub-drains

Place of sampling	Sub-drain of Unit1, Fukushima Daiichi	Sub-drain of Unit2, Fukushima Daiichi	Sub-drain of Unit3, Fukushima Daiichi	Sub-drain of Unit4, Fukushima Daiichi	Sub-drain of Unit5, Fukushima Daiichi	Sub-drain of Unit6, Fukushima Daiichi	Deep well, Fukushima Daiichi
Time and Date of Sample Collection	At 10:18 April 16, 2011	At 10:15 April 16, 2011	At 9:55 April 16, 2011	At 9:50 April 16, 2011	At 10:27 April 16, 2011	At 10:30 April 16, 2011	At 10:25 April 16, 2011
Detected Nuclides (Half-life)	Radioactivity Density of Sample (Bq/cm ³)						
Nb-95 (about 35 days)	ND	ND	ND	ND	ND	ND	ND
Ag-110m (about 250 days)	ND	ND	ND	ND	ND	ND	ND
Te-129 (about 70 hours)	ND	ND	ND	ND	ND	ND	ND
Te-129m (about 34 days)	ND	ND	1.4E+00	ND	ND	5.2E-01	ND
I-131 (about 8 days)	8.4E+01	5.4E+02	4.7E+00	1.3E+01	2.0E-01	2.1E-01	1.5E-02
I-132 (about 2 hours)	ND	ND	3.3E-02	2.4E-02	ND	ND	ND
Te-132 (about 78 hours)	ND	ND	ND	ND	ND	ND	ND
Cs-134 (about 2 years)	1.5E+01	5.8E+00	4.3E+00	2.7E+00	3.4E-01	3.5E-01	ND
Cs-136 (about 13 days)	3.9E-01	ND	1.4E-01	1.1E-01	1.1E-02	9.8E-03	ND
Cs-137 (about 30 years)	1.9E+01	7.1E+00	4.5E+00	2.7E+00	3.7E-01	3.9E-01	ND
Ba-140 (about 13 days)	ND	ND	ND	ND	ND	ND	ND
La-140 (about 40 hours)	ND	ND	ND	ND	ND	ND	ND

※ 0.0E-0 means 0.0×10⁻⁰.

【 Definite Report 】 Results of Nuclide Analyses of Sub-drains

Place of sampling	Sub-drain of Unit1, Fukushima Daiichi	Sub-drain of Unit2, Fukushima Daiichi	Sub-drain of Unit3, Fukushima Daiichi	Sub-drain of Unit4, Fukushima Daiichi	Sub-drain of Unit5, Fukushima Daiichi	Sub-drain of Unit6, Fukushima Daiichi	Deep well, Fukushima Daiichi
Time and Date of Sample Collection	At 10:20 April 18, 2011	At 10:30 April 18, 2011	At 10:10 April 18, 2011	At 9:45 April 18, 2011	At 10:40 April 18, 2011	At 10:45 April 18, 2011	At 9:00 April 18, 2011
Detected Nuclides (Half-life)	Radioactivity Density of Sample (Bq/cm ³)						
Nb-95 (about 35 days)	ND	ND	ND	ND	ND	ND	ND
Ag-110m (about 250 days)	ND	ND	ND	ND	ND	ND	ND
Te-129 (about 70 hours)	ND	ND	ND	ND	ND	ND	ND
Te-129m (about 34 days)	ND	ND	ND	ND	ND	ND	ND
I-131 (about 8 days)	4.3E+01	4.5E+01	2.6E+00	7.9E+00	1.0E-01	5.6E-02	8.3E-03
I-132 (about 2 hours)	ND	ND	ND	ND	ND	ND	ND
Te-132 (about 78 hours)	ND	ND	ND	ND	ND	ND	ND
Cs-134 (about 2 years)	1.1E+01	5.8E+00	2.2E+00	8.6E-01	6.6E-02	7.8E-02	7.9E-03
Cs-136 (about 13 days)	3.1E-01	ND	8.7E-02	2.9E-02	ND	ND	ND
Cs-137 (about 30 years)	1.2E+01	6.7E+00	2.3E+00	9.2E-01	7.1E-02	7.6E-02	ND
Ba-140 (about 13 days)	ND	ND	ND	ND	ND	ND	ND
La-140 (about 40 hours)	7.9E-02	ND	ND	ND	ND	ND	ND

※ 0.0E-0 means 0.0×10⁻⁰.

【 Definite Report 】 Results of Nuclide Analyses of Sub-drains

Place of sampling	Sub-drain of Unit1, Fukushima Daiichi	Sub-drain of Unit2, Fukushima Daiichi	Sub-drain of Unit3, Fukushima Daiichi	Sub-drain of Unit4, Fukushima Daiichi	Sub-drain of Unit5, Fukushima Daiichi	Sub-drain of Unit6, Fukushima Daiichi	Deep well, Fukushima Daiichi
Time and Date of Sample Collection	At 11:00 April 20, 2011	At 11:05 April 20, 2011	At 11:25 April 20, 2011	At 11:20 April 20, 2011	At 10:30 April 20, 2011	At 10:40 April 20, 2011	At 10:10 April 20, 2011
Detected Nuclides (Half-life)	Radioactivity Density of Sample (Bq/cm ³)						
Nb-95 (about 35 days)	ND	ND	ND	ND	ND	ND	ND
Ag-110m (about 250 days)	5.1E+00	ND	ND	ND	ND	ND	ND
Te-129 (about 70 hours)	ND	ND	ND	ND	ND	ND	ND
Te-129m (about 34 days)	3.9E+02	ND	ND	1.8E+00	ND	ND	ND
I-131 (about 8 days)	2.4E+02	4.4E+02	5.9E+00	1.8E+01	4.0E-02	5.7E-01	ND
I-132 (about 2 hours)	ND	ND	ND	ND	ND	ND	ND
Te-132 (about 78 hours)	2.6E+00	ND	ND	ND	ND	ND	ND
Cs-134 (about 2 years)	7.9E+01	5.2E+00	8.5E+00	2.9E+00	9.9E-02	2.5E-01	ND
Cs-136 (about 13 days)	2.6E+00	ND	2.7E-01	7.4E-02	ND	ND	ND
Cs-137 (about 30 years)	9.1E+01	6.2E+00	9.1E+00	3.0E+00	1.1E-01	2.6E-01	ND
Ba-140 (about 13 days)	ND	ND	ND	ND	ND	ND	ND
La-140 (about 40 hours)	1.1E+00	ND	4.9E-02	1.6E-02	ND	ND	ND

※ 0.0E-0 means 0.0×10⁻⁰.

【 Definite Report 】 Results of Nuclide Analyses of Sub-drains

Place of sampling	Sub-drain of Unit1, Fukushima Daiichi	Sub-drain of Unit2, Fukushima Daiichi	Sub-drain of Unit3, Fukushima Daiichi	Sub-drain of Unit4, Fukushima Daiichi	Sub-drain of Unit5, Fukushima Daiichi	Sub-drain of Unit6, Fukushima Daiichi	Deep well, Fukushima Daiichi
Time and Date of Sample Collection	At 11:15 April 22, 2011	At 11:20 April 22, 2011	At 11:00 April 22, 2011	At 10:55 April 22, 2011	At 10:35 April 22, 2011	At 10:45 April 22, 2011	At 10:00 April 22, 2011
Detected Nuclides (Half-life)	Radioactivity Density of Sample (Bq/cm ³)						
Nb-95 (about 35 days)	ND	ND	ND	ND	ND	ND	ND
Ag-110m (about 250 days)	3.0E+00	ND	ND	ND	ND	ND	ND
Te-129 (about 70 hours)	ND	ND	ND	ND	ND	ND	ND
Te-129m (about 34 days)	2.3E+02	ND	1.3E+00	ND	ND	ND	ND
I-131 (about 8 days)	7.1E+01	5.3E+02	8.5E+00	5.3E-01	7.3E-02	3.9E-01	ND
I-132 (about 2 hours)	9.1E-01	ND	ND	ND	ND	ND	ND
Te-132 (about 78 hours)	ND	ND	ND	ND	ND	ND	ND
Cs-134 (about 2 years)	3.9E+01	8.1E+00	1.0E+01	3.7E-01	1.1E-01	2.2E-01	6.9E-03
Cs-136 (about 13 days)	1.3E+00	ND	2.4E-01	1.2E-02	ND	ND	ND
Cs-137 (about 30 years)	4.8E+01	9.3E+00	1.0E+01	4.0E-01	1.2E-01	2.4E-01	ND
Ba-140 (about 13 days)	ND	ND	ND	ND	ND	ND	ND
La-140 (about 40 hours)	1.1E+00	ND	5.9E-02	ND	ND	ND	ND

※ 0.0E-0 means 0.0×10⁻⁰.