

Impact Assessment Results of Ventilating Reactor Building of Unit 1

	Evaluation Items	Evaluation based on the Radiation Density inside of the building on May 7 (Measured at 3:15 pm)
Radiation Density (after the operation)	I-131	9.7E-3 Bq/cm ³
	Cs-134	4.9E-3 Bq/cm ³
	Cs-137	5.1E-3 Bq/cm ³
Release Conditions	Ventilation Volume	3,200 m ³ /h
	Ventilation Time (Ventilation rate is constant during the duration)	8 hours
	Height of release (no consideration of blowing up)	28.7m
Weather Conditions	Wind Direction	E
	Wind Velocity	1.0m/s
	Atmospheric Stability	F
Estimated Results of Radiation Dose (Maximum figures of the land: within the site)	Internal Exposure by Inhalation (effective dose) I-131	3.0E-4 mSv
	Cs-134,137	1.4E-4 mSv
	External Exposure by Air (effective dose) I-131	2.6E-7 mSv
	Cs-134,137	7.7E-7 mSv
	External Exposure by Ground (effective dose) I-131	8.8E-7 mSv
	Cs-134,137	1.4E-6 mSv
	Total (effective dose)	4.4E-4 mSv
	Air Radiation Dose Rate	4.2E-4 μSv/h
Estimated Results of Radiation Density	Radiation Density at Site Boundary I-131	9.6E-7 Bq/cm ³
	Cs-134	5.2E-7 Bq/cm ³
	Cs-137	5.0E-7 Bq/cm ³
	Average of March (proportion to the density limit) I-131	3.6E-9 Bq/cm ³ (0.0007)
	Cs-134	1.9E-9 Bq/cm ³ (0.0001)
	Cs-137	1.9E-9 Bq/cm ³ (0.00006)
	Summation of the Proportion	0.0009