

Results of Nuclide Analyses of Sub-drains

Reference

(Data summarized on May 12)

Place of sampling	Sub-drain of Unit1, Fukushima Daiichi	Sub-drain of Unit2, Fukushima Daiichi	Sub-drain of Unit3, Fukushima Daiichi	Sub-drain of Unit4, Fukushima Daiichi	Sub-drain of Unit5, Fukushima Daiichi	Sub-drain of Unit6, Fukushima Daiichi	Deep well, Fukushima Daiichi
Time and Date of Sample Collection	2011/5/11, 14:03	2011/5/11, 14:08	2011/5/11, 14:16	2011/5/11, 14:25	2011/5/11, 13:35	2011/5/11, 13:23	2011/5/11, 10:10
Detected Nuclides (Half-life)	Radioactivity Density of Sample (Bq/cm ³)						
I-131 (about 8 days)	2.5E+00	8.7E+01	1.4E-01	ND	ND	2.2E-02	ND
Cs-134 (about 2 years)	8.8E+00	1.3E+01	2.8E-01	2.5E-02	ND	4.6E-02	ND
Cs-137 (about 30 years)	1.0E+01	1.5E+01	2.7E-01	4.5E-02	2.2E-02	5.6E-02	ND

. E - means . ×10.

Data of other nuclides are under evaluation.