

Result of Nuclide Analysis of Seawater <Offshore of Ibaraki Prefecture>

Reference

(Data summarized on May 12)

Place of Sampling	3 km offshore of Takadokobama shore		3 km offshore of Kujihama shore		3 km offshore of Oarai shore		3 km offshore of Hirai shore		3 km offshore of Hasaki shore		Density limit by the announcement of Reactor Regulation (Bq/cm ³) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Time and Date of Sample Collection	9:03 am May 11, 2011		8:02 am May 11, 2011		10:53 am May 11, 2011		8:48 am May 11, 2011		7:30 am May 11, 2011		
Detected Nuclides (Half-life)	Density of Sample (Bq/cm ³)	Scaling Factor (/)	Density of Sample (Bq/cm ³)	Scaling Factor (/)	Density of Sample (Bq/cm ³)	Scaling Factor (/)	Density of Sample (Bq/cm ³)	Scaling Factor (/)	Density of Sample (Bq/cm ³)	Scaling Factor (/)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	ND	-	4E-02
Cs-134 (about 2 years)	ND	-	ND	-	ND	-	ND	-	ND	-	6E-02
Cs-137 (about 30 years)	ND	-	ND	-	ND	-	ND	-	ND	-	9E-02

ND - means $< 1.0 \times 10^{-2}$