

## Results of Nuclide Analyses of Sub-drains

Reference
-----------

(Data summarized on May 14)

Place of sampling	Sub-drain of Unit1, Fukushima Daiichi	Sub-drain of Unit2, Fukushima Daiichi	Sub-drain of Unit3, Fukushima Daiichi	Sub-drain of Unit4, Fukushima Daiichi	Sub-drain of Unit5, Fukushima Daiichi	Sub-drain of Unit6, Fukushima Daiichi	Deep well, Fukushima Daiichi
Time and Date of Sample Collection	At 13:05 May 13, 2011	At 13:09 May 13, 2011	At 13:15 May 13, 2011	At 11:24 May 13, 2011	At 12:57 May 13, 2011	At 12:47 May 13, 2011	At 10:00 May 13, 2011
Detected Nuclides (Half-life)	Radioactivity Density of Sample (Bq/cm <sup>3</sup> )						
I-131 (about 8 days)	2.5E+01	5.4E+01	6.3E-02	1.6E-01	ND	1.4E-02	ND
Cs-134 (about 2 years)	4.8E+01	1.8E+01	2.6E-01	1.5E-01	ND	2.8E-02	ND
Cs-137 (about 30 years)	5.7E+01	2.1E+01	2.5E-01	1.7E-01	ND	3.3E-02	ND

※ O.OE—O means O.O×10.

※ Data of other nuclides are under evaluation.