

Results of Nuclide Analyses of Sub-drains

Reference

(Data summarized on May 17)

Place of sampling	Sub-drain of Unit1, Fukushima Daiichi	Sub-drain of Unit2, Fukushima Daiichi	Sub-drain of Unit3, Fukushima Daiichi	Sub-drain of Unit4, Fukushima Daiichi	Sub-drain of Unit5, Fukushima Daiichi	Sub-drain of Unit6, Fukushima Daiichi	Deep well, Fukushima Daiichi
Time and Date of Sample Collection	At 13:44 May 16, 2011	At 13:40 May 16, 2011	At 13:52 May 16, 2011	At 11:44 May 16, 2011	At 13:32 May 16, 2011	At 13:20 May 16, 2011	At 8:09 May 16, 2011
Detected Nuclides (Half-life)	Radioactivity Density of Sample (Bq/cm3)						
I-131 (about 8 days)	3.2E+00	3.8E+01	1.4E-01	3.6E-02	ND	ND	ND
Cs-134 (about 2 years)	1.5E+01	2.8E+01	2.4E-01	8.0E-02	ND	3.0E-02	ND
Cs-137 (about 30 years)	1.7E+01	3.4E+01	2.8E-01	8.5E-02	ND	2.4E-02	ND

. E - means . ×10.

Data of other nuclides are under evaluation.