

Results of Nuclide Analyses of Sub-drains

| |
|-----------|
| Reference |
|-----------|

(Data summarized on May 19)

| Place of sampling | Sub-drain of Unit1, Fukushima Daiichi | Sub-drain of Unit2, Fukushima Daiichi | Sub-drain of Unit3, Fukushima Daiichi | Sub-drain of Unit4, Fukushima Daiichi | Sub-drain of Unit5, Fukushima Daiichi | Sub-drain of Unit6, Fukushima Daiichi | Deep well, Fukushima Daiichi |
|------------------------------------|---|--|--|--|--|--|---------------------------------|
| Time and Date of Sample Collection | At 12:15 May 18, 2011 | At 12:23 May 18, 2011 | At 12:30 May 18, 2011 | At 11:55 May 18, 2011 | At 12:08 May 18, 2011 | At 12:00 May 18, 2011 | At 9:17 May 18, 2011 |
| Detected Nuclides (Half-life) | Radioactivity Density of Sample (Bq/cm3) | | | | | | |
| I-131 (about 8 days) | 1.2E+00 | 3.0E+01 | 4.4E-02 | 1.4E-02 | ND | 6.5E-03 | ND |
| Cs-134 (about 2 years) | 9.8E+00 | 2.3E+01 | 2.0E-01 | 6.2E-02 | 2.3E-02 | 2.9E-02 | ND |
| Cs-137 (about 30 years) | 1.2E+01 | 2.8E+01 | 2.2E-01 | 4.9E-02 | ND | 3.0E-02 | ND |

. E - means . ×10.

Data of other nuclides are under evaluation.