

Results of Nuclide Analyses of Sub-drains

Reference

(Data summarized on May 21)

Place of sampling	Sub-drain of Unit1, Fukushima Daiichi	Sub-drain of Unit2, Fukushima Daiichi	Sub-drain of Unit3, Fukushima Daiichi	Sub-drain of Unit4, Fukushima Daiichi	Sub-drain of Unit5, Fukushima Daiichi	Sub-drain of Unit6, Fukushima Daiichi	Deep well, Fukushima Daiichi
Time and Date of Sample Collection	At 11:50 May 20, 2011	At 11:55 May 20, 2011	At 12:00 May 20, 2011	At 11:47 May 20, 2011	At 11:45 May 20, 2011	At 11:30 May 20, 2011	At 10:20 May 20, 2011
Detected Nuclides (Half-life)	Radioactivity Density of Sample (Bq/cm ³)						
I-131 (about 8 days)	7.0E-01	2.5E+01	3.0E-02	ND	ND	ND	ND
Cs-134 (about 2 years)	7.9E+00	2.1E+01	2.0E-01	4.6E-02	2.9E-02	2.3E-02	ND
Cs-137 (about 30 years)	9.5E+00	2.5E+01	2.2E-01	6.0E-02	2.2E-02	ND	ND

. E - means . ×10.

Data of other nuclides are under evaluation.