

Our report on "Countermeasures based on a report on records of  
damages to power facilities inside and outside of Fukushima  
Daiichi Nuclear Power Station (instruction)"

May 23, 2011

Tokyo Electric Power Company

## Table of contents

### 1. The root cause analysis result of damages to power facilities inside and outside of Fukushima Daiichi Nuclear Power Station after the earthquake

- (1) The cause of damages and malfunctions to on-site power facilities at Fukushima Daiichi NPS
- (2) The cause of collapse of transmission line tower No. 27, Yonomori Line
- (3) The cause of damages to major Transformer (Tr), Circuit Breaker (C/B), Disconnecting Switch (DS), Potential Transformer (PT) and Current Transformer (CT) at Shin Fukushima Substation

### 2. The root cause analysis of tripping the transmission line by the protective system that would result in power loss at Fukushima Daiichi Nuclear Power Station

- (1) Okuma Line 1L
- (2) Okuma Line 2L
- (3) Okuma Line 3L
- (4) Okuma Line 4L
- (5) Yonomori Line 1L
- (6) Yonomori Line 2L

### 3. Future plans

- (1) The cause of damages and malfunctions to on-site power facilities at Fukushima Daiichi Nuclear Power Station
- (2) The cause of damages to major Tr, C/B, DS, PT and CT at Shin Fukushima Substation

### Appendices

- Exhibit-1: Behaviors of on-site power supply sources according to plant data in Fukushima Daiichi Nuclear Power Station
- Exhibit-2: Damage analyses based on behaviors of on-site power facilities
- Exhibit-3: The root cause analysis result of damages to on-site power facilities at Fukushima Daiichi NPS
- Exhibit-4: Inundation Level & Area and Runup Level of Fukushima Daiichi Nuclear Power Station

Based on the NISA instruction “Countermeasures based on a report on records of damage to power facilities inside and outside of Fukushima Daiichi Nuclear Power Station (NPS) (instruction)” (May 16, 2011 Nuclear No 7) received on May 16, 2011, this reports on the following matters:

- The root cause analysis result of damages to power facilities inside and outside of Fukushima Daiichi Nuclear Power Station after the earthquake. Especially, the analysis of whether the cause was by earthquake or tsunami based on (a) the record of damages to power facilities inside and outside of Fukushima Daiichi NPS reported on May 16, 2011 and (b) per instruction by METI “Regarding Collection of Reports pursuant to the Provisions of Article 67, Paragraph 1 of the Act on Regulation of Nuclear Source Materials, Nuclear Fuel Materials and Reactors (Act No. 167 of 1957)” (dated April 25, 2011, April 24, 2011 Nuclear No. 1), operation records prescribed in Article 7, paragraph 1 of the Rules for Commercial Power Reactors concerning the Installation, Operation, etc. (Ordinance of the Ministry of International Trade and Industry No. 77 of 1978) regarding the current accident (including records immediately following the occurrence of the 2011 Tohoku District - off the Pacific Ocean Earthquake), as well as the accident records of nuclear reactor facilities and others.
- The root cause analysis result of tripping the transmission line by the protective system that resulted in power loss at Fukushima Daiichi NPS

1. The root cause analysis result of damages to power facilities inside and outside of Fukushima Daiichi Nuclear Power Station (NPS) after the earthquake

Tohoku-Chiho Taiheiyō-Oki Earthquake that occurred at 2:46 am, March 11, 2011 and subsequent Tsunami inflicted damages to power facilities at Fukushima Daiichi Nuclear Power Station (“1F”) Shin Fukushima Substation (“SFS”) and transmission facilities.

In order to ascertain the cause of damages to each power facility, through site investigation and interview with persons involved are required.

However, at 1F, we are putting first priority to restoration of power supply in order to stabilize power plants. Also, as power facilities damaged are located in the Turbine Buildings with high radioactive contaminated water, it is impractical to conduct the site investigation.

Therefore, as to on-site power facilities of 1F, we decided to conduct the root cause analysis of damages by using the investigation result of Tsunami indicated in “Results of the investigation regarding tsunami arrived in Fukushima Daiichi Nuclear Power Station and Fukushima Daini Nuclear Power Station” announced on April 9, 2011 and plant data at the time of the earthquake.

(1) The cause of damages and malfunctions to on-site power facilities at Fukushima Daiichi Nuclear Power Station

We conducted the root cause analysis of 1F on-site power facilities by the following steps:

- We sorted out the behavior of on-site power facilities at each unit in chronological order from the plant data at the time of the earthquake (Exhibit-1) and made clear the sequence with the occurrence of Earthquake and Tsunami.
- From the behavior of power facilities, we checked soundness of each power facility when the facility received power or supplied power to loads. When the soundness couldn't be confirmed, we estimated the cause from the situation (Exhibit-2 and 3).

The analytical result per the above is shown as below:

① Unit 1

Damaged facilities at Unit 1 were Receiving C/B for Okuma Line 1L, HV Switch Board (M/C) and Diesel Generators etc.

- Receiving C/B for Okuma Line 1L

This C/B was located at Switchyard, Units 1 and 2. From the investigation result of Tsunami, the location was out of inundated areas. This was believed to be damaged by Earthquake (Exhibit-4).

- HV Switch Board (M/C) and Diesel Generators etc.

Diesel Generators (DG 1A, 1B), Emergency HV Switch Board (M/C 1C, 1D), Emergency Power Center (P/C 1C, 1D) and DC 125V power facilities (1A, 1B) were believed to be damaged by Tsunami.

Regular HV Switch Board and Regular Power Center were also believed to be damaged by Tsunami.

② Unit 2

Damaged facilities at Unit 2 were Receiving C/B and DS for Okuma Line 2L, HV Switch Board (M/C) and Diesel Generators etc.

- Receiving C/B and DS for Okuma Line 2L

These C/B and DS were located at Switchyard, Units 1 and 2. From the investigation result of Tsunami, the location was out of inundated areas. These were believed to be damaged by Earthquake (Exhibit-4).

- HV Switch Board (M/C) and Diesel Generators etc.

Diesel Generators (DG 2A, 2B), Emergency HV Switch Board (M/C 2C, 2D, 2E), Emergency Power Center (P/C 2E) and DC 125V power facilities (2A, 2B) were believed to be damaged by Tsunami.

Regular HV Switch Board and Regular Power Center were also believed to be damaged by Tsunami.

③ Unit 3

Damaged facilities at Unit 3 were HV Switch Board (M/C) and Diesel Generators etc.

Diesel Generators (DG 3A, 3B), Emergency HV Switch Board (M/C 3C, 3D), Emergency Power Center (P/C 3C, 3D) were believed to be damaged by Tsunami.

Regular HV Switch Board and Regular Power Center were also believed to be damaged by Tsunami.

④ Unit 4

Damaged facilities at Unit 4 were HV Switch Board (M/C) and Diesel Generators etc.

Diesel Generators (DG 4A, 4B), HV Switch Board (M/C 4A, 4B, 4C, 4D, 4E), Emergency Power Center (P/C 4E) and DC 125V power facilities (4A, 4B) were believed to be damaged by Tsunami.

⑤ Unit 5

Damaged facilities at Unit 5 were HV Switch Board (M/C) and Diesel Generators etc.

Diesel Generators (DG 5A, 5B), Emergency HV Switch Board (M/C 5C, 5D) and Emergency Power Center (P/C 5C, 5D) were believed to be damaged by Tsunami.

Regular HV Switch Board and Regular Power Center were also believed to be damaged by Tsunami.

As part of Emergency and Regular HV Switch Board, Emergency and Regular Power Center are put back into operation after replacing parts eroded by sea water, these were believed to be damaged by Tsunami.

⑥ Unit 6

Damaged facilities at Unit 6 were part of HV Switch Board (M/C) and Diesel Generators etc.

Diesel Generators (DG 6A, HPCS DG), were believed to be damaged by Tsunami.

Regular HV Switch Board and Regular Power Center were also believed to be damaged by Tsunami.

As part of Regular HV Switch Board and Regular Power Center are put back into operation after replacing parts eroded by seawater, these were believed to be damaged by Tsunami.

⑦ Toden Nuclear Line (Tohoku Electric)

Damaged facilities Toden Nuclear Line were cables that connected to HV Switch Board. We identified malfunction on cables. However, as there is a risk of caving in at the tunnel where those cables are installed, we cannot conduct the site investigation to estimate the cause.

(2) The cause of collapse of transmission line tower No. 27, Yonomori Line

We believe that transmission line tower No. 27, Yonomori Line collapsed because of large scale collapse of embankment at the adjacent site by the seismic motion. The reasons are as follows:

- Tsunami did not reach transmission line tower No. 27, Yonomori Line's location.
- Further to damages to power facilities by The Southern Hyogo prefecture earthquake, Basic Disaster Management Plan (Jul 1995, Central Disaster. Management Council resolved) established "Committee on Countermeasure against Disaster for Electric Equipment (unofficial committee by Director-General, Agency for Natural Resources and Energy)" that evaluated the adequateness of anti-quake standard of each facility. This confirmed, as to the anti-quake evaluation of a transmission line tower, if a tower can withstand Wind-Load (wind velocity 40m/s) as set out in the technical standard for power facilities, that tower can withstand the seismic motion by The Southern Hyogo prefecture earthquake (maximum acceleration 818 gal).

The maximum acceleration in the vicinity of transmission line tower No. 27, Yonomori Line by Tohoku-Chiho Taiheiyo-Oki Earthquake was 699gal, below 818 gal<sup>1</sup>.

Also, we evaluated the acceleration response spectra of each seismic motion. As shown in figure 1, at the natural frequency band of the transmission line tower (0.3-1 sec), the seismic motion in the vicinity of transmission line tower No. 27, Yonomori Line was below that of The Southern Hyogo prefecture earthquake.

- Site investigation revealed that legs of transmission line tower were buried by soil and fallen trees. The upper part of transmission line fell on soil. Also cables were soil and fallen trees (figures 2 and 3). We believe that transmission line tower collapsed after collapse of embankment occurred.

---

<sup>1</sup> This is the maximum acceleration, EW direction, North Point (O.P. +12.2m (GN1)), Free Base as written in Report of Analysis of Observed Seismic Data Collected at Fukushima Daiichi Nuclear Power Station during Tohoku-Chiho Taiheiyo-Oki Earthquake (May 16, 2011)




Figure 1: Acceleration response spectra of seismic motion



Figure 2: the overall transmission line tower



Figure 3: legs of transmission line tower



(3) The cause of damages to major Tr, C/B, DS, PT and CT at Shin Fukushima Substation

As Tsunami did not reach SFS, those were by Earthquake.

Major transformers were designed to have margin against "Guidelines for earthquake-resistant design of electrical equipment in substations (JEAG 5003). As there were damages, detailed analysis will be required to ascertain the cause of damages.

Future plans are set out in section 3.(2).

2. The root cause analysis of tripping the transmission line by the protective system that would result in power loss at Fukushima Daiichi Nuclear Power Station

(1) Okuma Line 1L

C/B tripped: 1F O-1

Protective system activated: Unknown

(presume activation record of protective system was lost because of loss of on-site power at 1F)

Cause of activation: As C/B O-81 at 1F was damaged, we believe this activated protective system at 1F and tripped C/B O-1.

(2) Okuma Line 2L

C/B tripped: SFS O-32

Protective system activated: Okuma Line 2L transmission line protective system at SFS

Cause of activation: As C/B O-82 and DS 82 at 1F were damaged, we believe this activated protective system at SFS and tripped C/B O-32.

(3) Okuma Line 3L

C/B tripped: SFS O-33

Protective system activated: Okuma Line 3L transmission line protective system at SFS

Cause of activation: We confirmed arc spots at transmission line tower No. 7, Okuma Line 3, 4L and cables. We believe that cables contacted with transmission line tower or came close that activated protective system at SFS and tripped C/B O-33.

(4) Okuma Line 4L

C/B tripped: SFS O-34

Protective system activated: Okuma Line 4L transmission line protective system at SFS

Cause of activation: We confirmed arc spots at transmission line tower No. 11, Okuma Line 3, 4L and cables. We believe that cables contacted with transmission line tower or came close that activated protective system at SFS and tripped C/B O-34.

(5) Yonomori Line 1L

C/B tripped: SFS O-93  
Protective system activated: Yonomori Line 1L transmission line protective system at SFS

Cause of activation: At Yonomori Line 1L, we believe that cables contacted with transmission line tower or came close that activated protective system at SFS and tripped C/B O-93. Meantime. transmission line tower No. 27, Yonomori Line collapsed.

(6) Yonomori Line 2L

C/B tripped: SFS O-94  
Protective system activated: Yonomori Line 2L transmission line protective system at SFS

Cause of activation: At Yonomori Line 2L, we believe that cables contacted with transmission line tower or came close that activated protective system at SFS and tripped C/B O-94. Meantime. transmission line tower No. 27, Yonomori Line collapsed.

### 3. Future plans

(1) The cause of damages and malfunctions to on-site power facilities at Fukushima Daiichi Nuclear Power Station

a. the cause of damages to C/B and DS at Switchyard, Units 1 and 2, 1F

As there is no observation data at Switchyard, Units 1 and 2, in order to ascertain the cause of damages to power facilities, we need to estimate the seismic waveform from observation data at close observation points. Based on that seismic waveform we will conduct the seismic resistance analysis simulating the detailed structure of power facilities as necessary.

The schedule is as set out in table 1. As soon as the evaluation result is ready, we will report.

Table 1: preparation schedule

Item	Jun	Jul	Aug	Sep	Oct	Nov	Dec
□ Estimate seismic movement at 1F	■						
□ Preparation of power facilities analytical model	■						
□ Anti-quake analysis				■			
□ Evaluation of cause of damages							■

□ item □□ planning to deliver interim reports at times such as completion of certain items

b. Cause of damages to on-site power facilities at 1F

At 1F, we are putting first priority to restoration of power supply in order to stabilize power plants. Also, as power facilities damaged are located in the Turbine Buildings with high radioactive contaminated water, it is impractical to conduct the site investigation.

From now on, when the above are resolved and we are able to conduct the site investigation, in order to ascertain the cause of damages, we will conduct below as necessary.

- Site investigation
- Identify damaged parts
- Analyze factors
- Evaluate the cause

(2) The cause of damages to major Tr, C/B, DS, PT and CT at Shin Fukushima Substation

As the earthquake recording device at SFS stopped in the middle of Earthquake, we have only part of observation data. In order to ascertain the cause of damages to power facilities, we need to estimate the seismic waveform from observation data at close observation points and ground characteristics. Based on that seismic waveform we will conduct the seismic resistance analysis simulating the detailed structure of power facilities as necessary.

The schedule is as set out in table 2. As soon as the evaluation result is ready, we will report.

Table 2: preparation schedule

Item	May	Jun	Jul	Aug	Sep	Oct	Nov
□ Estimate seismic movement at SFS	■						
□ Preparation of power facilities analytical model	■						
□ Anti-quake analysis				■			
□ Evaluation of cause of damages							■

□ item □□ planning to deliver interim reports at times such as completion of certain items

Behaviors of on-site power supply sources according to plant data  
in Fukushima Daiichi Nuclear Power Station

We will conduct the following analyses on behaviors of on-site power supply sources of each unit on March 11, 2011 according to plant data at the occurrence of the earthquake that we reported on May 16, 2011.

- Unit 1 (Attachment-1)

1. Plant was in operation.
2. The earthquake occurred at 2:46 pm.
3. Reactor scrammed at 2:46 pm.
4. As off-site power was failed due to the earthquake, Diesel Generators (DG 1A, 1B) started at 2:47 pm and was operated in normal conditions. Hence, it was recorded in the data that the voltage of emergency HV Switch Board (M/C 1C, 1D) were normally restored and that they was continuously operated until 3:17 pm.
5. Japan Meteorological Agency issued major tsunami warning at 2:49 pm.
6. "All AC sources are failed at 3:37 pm," according to the shift supervisor task handover journal.

- Unit 2 (Attachment-2)

1. Plant was in operation.
2. The earthquake occurred at 2:46 pm.
3. Reactor scrammed at 2:47 pm due to the earthquake.
4. As off-site power was failed due to the earthquake, Diesel Generators (DG 2A, 2B) started at 2:48 pm and was operated in normal conditions. Hence, the voltage of emergency HV Switch Board (M/C 2C, 2D) was normally restored.
5. Japan Meteorological Agency issued major tsunami warning at 2:49 pm.
6. Electricity went out in the emergency HV Switch Board (M/C 2C) at 3:37 pm and another one (M/C 2D) at 3:40 pm.

- Unit 3 (Attachment-3)

1. Plant was in operation.
2. The earthquake occurred at 2:46 pm.
3. Reactor scrammed at 2:47 pm due to the earthquake.
4. As off-site power was failed due to the earthquake, Diesel Generators (DG 3A, 3B) started at 2:48 pm and was operated in normal conditions. Hence,

the voltage of emergency HV Switch Board (M/C 3C, 3D) was normally restored.

5. Japan Meteorological Agency issued major tsunami warning at 2:49 pm.
6. Diesel Generators (DG 3A, 3B) stopped at 3:38 pm.

- Unit 4 (Attachment-4)

1. Plant remained shut down for a periodical inspection.  
As we were replacing a process computer and a transient recorder during the inspection, these data are not available.
2. Japan Meteorological Agency issued major tsunami warning at 2:49 pm.
3. "On-site power is failed at 3:38 pm," according to the shift supervisor task handover journal.

- Unit 5 (Attachment-5)

1. Plant remained shut down for a periodical inspection.
2. The earthquake occurred at 2:46 pm.
3. As off-site power was failed due to the earthquake, the Diesel Generator (DG 5B) started at 2:48 pm and another one (DG 5A) did at 2:49 pm and they were operated in normal conditions. Hence, the voltage of emergency HV Switch Board (M/C 5C, 5D) was normally restored.
4. Japan Meteorological Agency issued major tsunami warning at 2:49 pm.
5. The Diesel Generator (DG 5A) stopped on 3:39 pm and another one (DG 5B) did at 3:40 pm.

- Unit 6 (Attachment-6)

1. Plant remained shut down for a periodical inspection.
2. The earthquake occurred at 2:46 pm.
3. As off-site power was failed due to the earthquake, the Diesel Generator (DG 6B) started at 2:48 pm and other ones (DG 5A, HPCS DG) did at 2:49 pm and all of them were operated in normal conditions. Hence, the voltage of emergency HV Switch Board (M/C 6C, 6D, HPCS D/G M/C) was normally restored.
4. Japan Meteorological Agency issued major tsunami warning at 2:49 pm.
5. Electricity went out in the emergency HV Switch Board (M/C 6C, HPCS D/G M/C) at 3:40 pm.

## Analysis Result of Plant Data

### Unit 1

Date	Time	Plant Status	Confirmed by	Note
2011/3/11	14:46	Occurrence of Tohoku-Chihou-Taiheiyo-Oki Earthquake		
	14:46	Reactor Automatic Scrum A	Alarm Recorder ①	
		Reactor Automatic Scrum B	Alarm Recorder ②	
	14:47	D/G 1B Operation, C/B Closed	Alarm Recorder ③	
		M/C 1D Voltage Established	Alarm Recorder ④	
		D/G 1A Operation, C/B Closed	Alarm Recorder ⑤	
		M/C 1D Voltage Established	Alarm Recorder ⑥	
	14:49	Issuance of Major Tsunami Warning		
	15:17	D/G 1A, D/G 1B in Operation M/G 1C, M/C 1D Voltage in Establishment	Plant data Analysis & Diagnosis Information System ⑦	Normal condition was confirmed until 3:17 pm while the record of Plant data Analysis & Diagonosis Information System remained
15:37	Station Black Out	Shift Supervisor Task Handover Journal ⑧		

# Unit 1

(in Operation)

# 1号機

(運転中)

内訳  
Breakdown

- ① アラームタイプ  
Alarm recorder
- ② BOP タイパ (BOP=Balance of Plant : バランス・オブ・プラント)  
BOP recorder
- ③ NSS タイパ (NSS=Nuclear Steam Supply : 原子炉蒸気供給系)  
NSS recorder
- ④ OD タイパ他 (OD=On Demand : 任意要求)  
OD recorder and others



0954 A532 APRM BYPS CH-1 ON  
 0954 A536 APRM BYPS CH-5 ON  
 0956 A532 APRM BYPS CH-1 OFF NORMAL RETURN  
 0956 A536 APRM BYPS CH-5 OFF NORMAL RETURN  
 1001 BOP 1H CYCLE DATA XFER START  
 1001 BOP 1H CYCLE DATA XFER COMPLETE  
 1002 A532 APRM BYPS CH-1 ON  
 1002 A536 APRM BYPS CH-5 ON  
 1028 A532 APRM BYPS CH-1 OFF NORMAL RETURN  
 1028 A536 APRM BYPS CH-5 OFF NORMAL RETURN  
 1028 A533 APRM BYPS CH-2 ON  
 1028 A536 APRM BYPS CH-5 ON  
 1028 A536 APRM BYPS CH-5 OFF NORMAL RETURN  
 1028 A537 APRM BYPS CH-6 ON  
 1052 A533 APRM BYPS CH-2 OFF NORMAL RETURN  
 1052 A537 APRM BYPS CH-6 OFF NORMAL RETURN  
 1101 BOP 1H CYCLE DATA XFER START  
 1101 BOP 1H CYCLE DATA XFER COMPLETE  
 1103 A534 APRM BYPS CH-3 ON  
 1103 A535 APRM BYPS CH-4 ON  
 1113 S256 CTP (1M AVE) 1380.0>1380.0 MW  
 1114 S256 CTP (1M AVE) 1377.0 MW NORMAL RETURN  
 1123 F065 SWP DISCHG HDR PRES 0.347< 0.350 MPA  
 1124 F065 SWP DISCHG HDR PRES 0.360 MPA NORMAL RETURN  
 1124 F065 SWP DISCHG HDR PRES 0.347< 0.350 MPA  
 1125 F065 SWP DISCHG HDR PRES 0.351 MPA NORMAL RETURN  
 1125 F065 SWP DISCHG HDR PRES 0.349< 0.350 MPA  
 1126 F065 SWP DISCHG HDR PRES 0.371 MPA NORMAL RETURN  
 1148 A534 APRM BYPS CH-3 OFF NORMAL RETURN  
 1148 A535 APRM BYPS CH-4 OFF NORMAL RETURN  
 1201 BOP 1H CYCLE DATA XFER START  
 1201 BOP 1H CYCLE DATA XFER COMPLETE  
 1201 BOP 6H CYCLE DATA XFER START  
 1201 BOP 6H CYCLE DATA XFER COMPLETE  
 1221 S256 CTP (1M AVE) 1380.0>1380.0 MW  
 1223 S256 CTP (1M AVE) 1379.0 MW NORMAL RETURN  
 1300 BOP 1H CYCLE DATA XFER START  
 1300 BOP 1H CYCLE DATA XFER COMPLETE  
 1401 BOP 1H CYCLE DATA XFER START  
 1401 BOP 1H CYCLE DATA XFER COMPLETE  
 TRIP SEQUENCE LOG 11-03-11

H	MIN	SEC	MSEC	PID	ABBREVIATION	STATUS
14	46	46	400	D564*	SEISMIC TRIP C	TRIP
14	46	46	410	D534	REACTOR SCRM A	TRIP
14	46	58	420	D563	SEISMIC TRIP B	TRIP
14	46	58	430	D535	REACTOR SCRM B	TRIP
1446	A538	REM	BYPS		ON	
1446	B500	CONT ROD DRFT	ALRM		ON	
14	47	00	020	D562	SEISMIC TRIP A	TRIP
14	47	00	030	D565	SEISMIC TRIP D	TRIP
1447	C020	SUPPRESSION	LEVEL	-40.8<	-20.0 MM	
1447	A523	APRM	DOWN SCAL		TREB	
1447	A539	RWM	ROD BLOK		ON	
1447	A553	ALL CR	FULL IN		ON	
1447	G002	GENERATR	VOLT	18.56>	18.50 KV	
1447	C000	CONT ROD SYST	FLOW		OVR FLW	
1447	C020	SUPPRESSION	LEVEL	16.0 MM	NORMAL RETURN	
14	47	09	140	D520	REAC WTR LEVEL A	LOW
1447	C004	REACTOR	WATR LEVEL	516<	800 MM	
14	47	09	150	D521	REAC WTR LEVEL B	LOW
1447	E004	SWCHGEAR	BUS 1A	7217>	7200 V	
14	47	10	910	D523	REAC WTR LEVEL D	LOW
1447	C020	SUPPRESSION	LEVEL	21.6>	20.0 MM	
14	47	10	910	D522	REAC WTR LEVEL C	LOW
1447	A549	LOW POWER	ALRM POINT		UNDER	
14	47	20	620	D522	REAC WTR LEVEL C	NORM
1447	D622	PCIS	ISO IN		TRIP	
14	47	20	620	D523	REAC WTR LEVEL D	NORM

1081 11-03 7 236

← CR 全停

加電

11-03 11:00  
PCIS 9.11

1447	A570	#1	MSIV	A	OPN	OFF		
14	47	52	080		D680	6.9KV BUS VLT 1C LOS		ON
1447	A581	#2	MSIV	D	OPN	OFF		
14	47	52	090		D588	AUX POWR LOSS		TRIP
1447	A571	#1	MSIV	B	OPN	OFF		
14	47	52	120		D651	CWP B TRIP		ON
1447	A573	#1	MSIV	D	OPN	OFF		
14	47	52	130		D657	RFP C TRIP		ON
1447	A579	#2	MSIV	B	OPN	OFF		
14	47	52	140		D654	CP C TRIP		ON
1447	A580	#2	MSIV	C	OPN	OFF		
14	47	52	250		D653	CP B TRIP		ON
1447	B031	CAMS	H2	MONI	D/W	LOW RSN		
14	47	52	250		D650	CWP A TRIP		ON
1447	B032	CAMS	O2	MONI	D/W	LOW RSN		
14	47	52	270		D655	RFP A TRIP		ON
1447	B033	CAMS	H2	MONI	S/C	LOW RSN		
14	47	57	070		D590	DIES GEN CB 1D-1		ON
1447	B034	CAMS	O2	MONI	S/C	LOW RSN		
14	47	57	140		D681	6.9KV BUS VLT 1D LOS		OFF
1447	G000	GENERATR	GROS	LOAD		383.0 MW	NORMAL RETURN	
14	47	58	920		D589	DIES GEN CB 1C-1		ON
1447	G001	GENERATR	GROS	VARS		9.0< 10.0	MVAR	
14	47	58	970		D680	6.9KV BUS VLT 1C LOS		OFF
1447	G002	GENERATR	VOLT			LOW RSN		
14	48	00	220		D660	PLR A LOCOUT RY ACT		ON
1447	C007	REAC	FMP	TOTL	FLOW	LOW RSN		
14	48	13	280		D576	TURBINE VIB OVER		NORM
1447	C037	RECIRC2A	DRVG	FLOW		LOW RSN		
14	48	14	980		D661	PLR B LOCOUT RY ACT		ON
1447	C029	EMERCON	LEVL	B		LOW RSN		
14	48	20	670		D576	TURBINE VIB OVER		TRIP
1447	C039	RECIRC2B	DRVG	FLOW		LOW RSN		
14	48	24	340		D576	TURBINE VIB OVER		NORM
1447	C013	RE	CLNUP	FLOW	A	LOW RSN		
END JOB								

1447 C006 REACTOR CORE DIFF LOW RSN  
TRIP SEQUENCE LOG 11-03-11

H	MIN	SEC	MSEC	PID	ABBREVIATION	STATUS
1447	E014	COND	FMP	PRES	B	LOW RSN
14	48	59	850	D568*	GEN STAT COOL LOSS	TRIP
1447	A100	TPM(MVG)			LOW RSN	

END JOB

1447 B003 REAC POWER LMT LOW RSN  
TRIP SEQUENCE LOG 11-03-11


H	MIN	SEC	MSEC	PID	ABBREVIATION	STATUS
1447	C025	MAIN	STM	PRES	A	LOW RSN
14	52	18	950	D649*	IC LINE B INIT	ON
1447	T000	CONDENSER	PRES	A	LOW RSN	
14	52	18	980	D648	IC LINE A INIT	ON
1447	F015	CONDSTATE	FLOW		LOW RSN	
1447	F051	HOTWELL	LEVL	A	LOW RSN	
1447	F052	HOTWELL	LEVL	B	LOW RSN	
1447	S266	REAC	CORE	FLOW (T/H)	UKN B.V	
1447	S267	REAC	CORE	FLOW (%)	UKN B.V	
1447	B519	SGTS	B	START		ON

END JOB

1447	S209	CLEANUP	OUTL			UKN B.V
1447	S211	CONDENSER	PRES			UKN B.V
1447	S236	HOTWELL	LEVEL			UKN B.V
1447	B533	CAMS	H2	DNS	HI (D/W)	ON
1447	B534	CAMS	H2	DNS	HI (S/C)	ON
1447	B535	CAMS	O2	DNS	HI (D/W)	ON


1. D/G\_1A\_起動

0.000 digital




2. D/G\_1B\_起動

0.000 digital




3. D/G\_1A\_受電遮断器投入信号(使用不可)

1.000 digital



4. D/G\_1B\_受電遮断器投入信号(使用不可)

1.000 digital



福島第一原子力発電所 1号機  
データ表示期間 2011年03月11日14時42分03秒~2011年03月11日15時17分02秒  
グループ名称: 1F-1 その他  
Group name: 1F-1 Others

イベントデータ 時系列データ表示


ファイル名 1F1\_Cy24\_EVF\_DET\_2011\_03\_11\_Fri\_14\_47\_04.dat

データ周期 0.01秒


(1-

イベント検出時刻 2011年03月11日14時47分03秒 900 ミリ秒


1. 6.9kV\_1C母線電圧




2. 6.9kV\_1D母線電圧



3. 予備



4. 予備





## Analysis Result of Plant Data

### Unit 2

Date	Time	Plant Status	Confirmed by	Note
2011/3/11	14:46	Occurrence of Tohoku-Chihou-Taiheiyo-Oki Earthquake		
	14:47	Reactor Automatic Scrum B	Alarm Recorder ①	
		Reactor Automatic Scrum A	Alarm Recorder ②	
	14:48	D/G 2A Operation	Alarm Recorder ③	
		D/G 2B Operation	Alarm Recorder ④	
		D/G 2A C/B closed	Alarm Recorder ⑤	
		M/C 2C Voltage Established	Alarm Recorder ⑥	
		D/G 2B C/B closed	Alarm Recorder ⑦	
		M/C 2D Voltage Established	Alarm Recorder ⑧	
	14:49	Issuance of Major Tsunami Warning		
	15:37	D/G 2A C/B Opened	Alarm Recorder ⑨	
		M/C 2C Voltage Lost	Alarm Recorder ⑩	
		D/G 2B C/B Opened	Alarm Recorder ⑪	
	15:40	M/C 2D Voltage Lost	Alarm Recorder ⑫	

# Unit 2

(in Operation)

## 2 号機

(運転中)

内訳

Breakdown

- ① アラームタイプ  
Alarm recorder
- ② BOP タイパ (BOP=Balance of Plant : バランス・オブ・プラント)  
BOP recorder
- ③ NSS タイパ (NSS=Nuclear Steam Supply : 原子炉蒸気供給系)  
NSS recorder
- ④ OD タイパ他 (OD=On Demand : 任意要求)  
OD recorder and others

Output of 1F2 Process computer alarm printer

1F2プロセス計算機アラームプリンタ出力

時間	PID	名称	値	単位	
* 2011/3/11 14:47	P417	PLRポンプA 上部振動	= 178.4924927	μm	不良
* 2011/3/11 14:47	P418	PLRポンプB 上部振動	= 156.4125061	μm	不良
* 2011/3/11 14:47	C028	圧力抑制室 水位	= -31.25	mm	低
2011/3/11 14:47	C028	圧力抑制室 水位	= 18.4375	mm	正常
* 2011/3/11 14:47	C028	圧力抑制室 水位	= -83.125	mm	低
2011/3/11 14:47	C028	圧力抑制室 水位	= 51.25	mm	正常
* 2011/3/11 14:47	C028	圧力抑制室 水位	= 70	mm	高
* 2011/3/11 14:47	C028	圧力抑制室 水位	= -70	mm	低
* 2011/3/11 14:47	C028	圧力抑制室 水位	= 83.4375	mm	高
* 2011/3/11 14:47	C028	圧力抑制室 水位	= -96.875	mm	低
* 2011/3/11 14:47	G004	発電機 励磁 電圧	= 475.875	V	高
2011/3/11 14:47	G004	発電機 励磁 電圧	= 321.46875	V	正常
* 2011/3/11 14:47	A524	APRM 中性子束 高	= 高域		警報
* 2011/3/11 14:47	D535	原子炉 自動スクラム B Reactor Automatic	= トリップ Trip		警報 Alarm
* 2011/3/11 14:47	D565	地震トリップ CH-D Scram	= トリップ		警報
* 2011/3/11 14:47	C028	圧力抑制室 水位	= 80.625	mm	高
* 2011/3/11 14:47	A539	制御棒引抜阻止	= ON		警報
* 2011/3/11 14:47	A551	制御棒 ドリフト	= ON		警報
* 2011/3/11 14:47	D534	原子炉 自動スクラム A	= トリップ		警報
* 2011/3/11 14:47	D562	地震トリップ CH-A	= トリップ		警報
2011/3/11 14:47	R400	A系 原子炉スクラム信号	= スクラム		正常
2011/3/11 14:47	R401	B系 原子炉スクラム信号	= スクラム		正常
* 2011/3/11 14:47	C028	圧力抑制室 水位	= -62.1875	mm	低
2011/3/11 14:47	A524	APRM 中性子束 高	= 正常		正常
* 2011/3/11 14:47	A538	RBM バイパス	= ON		警報
2011/3/11 14:47	A539	制御棒引抜阻止	= OFF		正常
* 2011/3/11 14:47	D563	地震トリップ CH-B	= トリップ		警報
* 2011/3/11 14:47	D564	地震トリップ CH-C	= トリップ		警報
2011/3/11 14:47	R714	ファーストランバック A	= ON		正常
2011/3/11 14:47	R715	ファーストランバック B	= ON		正常
2011/3/11 14:47	Z641	制御棒 ガイド中	= OFF		正常
2011/3/11 14:47	Z650	RWMオンライン	= OFF		正常
* 2011/3/11 14:47	C000	制御棒 駆動水流量	= 17.34468842	t/h	不良
* 2011/3/11 14:47	A523	APRM 下限	= 異常		警報
* 2011/3/11 14:47	A539	制御棒引抜阻止	= ON		警報
2011/3/11 14:47	A554	RWM 動作可能	= OFF		正常
* 2011/3/11 14:47	D531	原子炉 中性子モニタ系 トリップ B2	= トリップ		警報
* 2011/3/11 14:47	G004	発電機 励磁 電圧	= 487.40625	V	高
2011/3/11 14:47	A545	全制御棒 全挿入	= ON		正常



1F2プロセス計算機アラームプリンタ出力

時間	PID	名称	値	単位	
* 2011/3/11 14:48	C081	ジェットポンプ流量-2	= 577.2348022	t/h	不良
* 2011/3/11 14:48	C082	ジェットポンプ流量-3	= 568.6827393	t/h	不良
* 2011/3/11 14:48	C083	ジェットポンプ流量-4	= 570.8327026	t/h	不良
* 2011/3/11 14:48	C084	ジェットポンプ流量-5	= 610.2458496	t/h	不良
* 2011/3/11 14:48	C085	ジェットポンプ流量-6	= 633.8769531	t/h	不良
* 2011/3/11 14:48	C086	ジェットポンプ流量-7	= 579.3530884	t/h	不良
* 2011/3/11 14:48	C087	ジェットポンプ流量-8	= 577.2348022	t/h	不良
* 2011/3/11 14:48	C088	ジェットポンプ流量-9	= 602.1627808	t/h	不良
* 2011/3/11 14:48	C089	ジェットポンプ流量-10	= 605.206604	t/h	不良
* 2011/3/11 14:48	C090	ジェットポンプ流量-11	= 516.7687988	t/h	不良
* 2011/3/11 14:48	C091	ジェットポンプ流量-12	= 523.8320313	t/h	不良
* 2011/3/11 14:48	C092	ジェットポンプ流量-13	= 504.7771606	t/h	不良
* 2011/3/11 14:48	C093	ジェットポンプ流量-14	= 494.9747314	t/h	不良
* 2011/3/11 14:48	C094	ジェットポンプ流量-15	= 521.4882813	t/h	不良
* 2011/3/11 14:48	C095	ジェットポンプ流量-16	= 553.3985596	t/h	不良
* 2011/3/11 14:48	C096	ジェットポンプ流量-17	= 492.4936829	t/h	不良
* 2011/3/11 14:48	C097	ジェットポンプ流量-18	= 514.3928833	t/h	不良
* 2011/3/11 14:48	C098	ジェットポンプ流量-19	= 521.4882813	t/h	不良
* 2011/3/11 14:48	C099	ジェットポンプ流量-20	= 519.1339111	t/h	不良
2011/3/11 14:48	G007	発電機 界磁巻線 温度	= 36.84000015	°C	正常
* 2011/3/11 14:48	P608	EHC負荷要求偏差信号	= 24.95000076	%	不良
* 2011/3/11 14:48	S280	ジェットポンプ流量(A側総量)	= 5162.748535		入力不良
* 2011/3/11 14:48	S281	ジェットポンプ流量(B側総量)	= 5931.047852		入力不良
* 2011/3/11 14:48	S282	ジェットポンプ流量(A+B)	= 11093.79688		入力不良
2011/3/11 14:48	A601	SRNM 中性子束 高	= 正常		正常
2011/3/11 14:48	A603	SRNM ペリオド 短	= 正常		正常
2011/3/11 14:48	D531	原子炉 中性子モニタ系 トリップ B2	= リセット		正常
2011/3/11 14:48	D557	SRNM中性子束 高高 CH-H	= 正常		正常
2011/3/11 14:48	D725	SRNM ペリオド 短短 CH-H	= 正常		正常
2011/3/11 14:48	R716	D/G 2A 起動 D/G 2A Start up	= 起動 Start up		正常
2011/3/11 14:48	Z523	TIP CH-A 案内管番地 1	= ON		正常
2011/3/11 14:48	Z527	TIP CH-B 案内管番地 1	= ON		正常
2011/3/11 14:48	Z531	TIP CH-C 案内管番地 1	= ON		正常
2011/3/11 14:48	Z535	TIP CH-D 案内管番地 1	= ON		正常
2011/3/11 14:48	Z576	TIP検出器A 索引機構前	= ON		正常
2011/3/11 14:48	Z577	TIP検出器B 索引機構前	= ON		正常
2011/3/11 14:48	Z578	TIP検出器C 索引機構前	= ON		正常
2011/3/11 14:48	Z579	TIP検出器D 索引機構前	= ON		正常
2011/3/11 14:48	A132	TPM 中間平均値	= 1.582	%PWR	正常

1F2プロセス計算機アラームプリンタ出力

時間	PID	名称	値	単位	
* 2011/3/11 14:48	F088	RFP 入口圧力	= 4.737500191	MPa	不良
* 2011/3/11 14:48	F089	復水器 A 電導度	= 9.982000351	μ S/cm	不良
* 2011/3/11 14:48	F090	復水器 B 電導度	= 9.995499611	μ S/cm	不良
* 2011/3/11 14:48	F091	復水器 C 電導度	= 9.991000175	μ S/cm	不良
* 2011/3/11 14:48	F093	浄化系 入口電導度	= 0.0625	μ S/cm	不良
* 2011/3/11 14:48	F094	低圧復水ポンプ A 出口圧力	= 0.076875001	MPa	不良
* 2011/3/11 14:48	F096	低圧復水ポンプ C 出口圧力	= 0.975624979	MPa	不良
* 2011/3/11 14:48	F097	復水脱塩塔出口圧力	= 1.073125005	MPa	不良
* 2011/3/11 14:48	F098	復水脱塩塔出口電導度	= 0.0429	μ S/cm	不良
* 2011/3/11 14:48	F136	RFP-T(A)排気室圧力1	= 3.317187548	kPaabs	不良
* 2011/3/11 14:48	F137	RFP-T(A)排気室圧力2	= 3.282812595	kPaabs	不良
* 2011/3/11 14:48	F138	RFP-T(B)排気室圧力1	= 3.1796875	kPaabs	不良
* 2011/3/11 14:48	F139	RFP-T(B)排気室圧力2	= 3.162499905	kPaabs	不良
* 2011/3/11 14:48	G004	発電機 励磁 電圧	= -2.8125	V	不良
* 2011/3/11 14:48	G005	発電機 励磁 電流	= 14.0625	A	不良
* 2011/3/11 14:48	G006	発電機 水素ガス 圧力	= 0.419625014	MPa	不良
* 2011/3/11 14:48	G007	発電機 界磁巻線 温度	= 72.77999878	°C	不良
* 2011/3/11 14:48	S219	原子炉水 浄化系 流量 (TOTAL)	= 1.701562524	t/h	入力不良
* 2011/3/11 14:48	S280	ジェットポンプ流量(A側総量)	= 0		入力不良
* 2011/3/11 14:48	S281	ジェットポンプ流量(B側総量)	= 6608.049805		入力不良
* 2011/3/11 14:48	S282	ジェットポンプ流量(A+B)	= 6608.049805		入力不良
* 2011/3/11 14:48	T003	タービン 加減弁 蒸気室 圧力	= 5.546249866	MPa	RL下限逸脱
* 2011/3/11 14:48	T004	タービン 第1段落 蒸気室 圧力	= 0.174999997	MPa	RL下限逸脱
* 2011/3/11 14:48	T007	タービン 軸受油 ヘッド 圧力	= 0.165281251	MPa	RL下限逸脱
* 2011/3/11 14:48	T008	タービン 潤滑油 レベル	= -159.75	mm	低
2011/3/11 14:48	A603	SRNM ペリオド 短	= 正常		正常
* 2011/3/11 14:48	D574	タービン スラスト軸受 磨耗	= 異常		警報
* 2011/3/11 14:48	D733	PLR-INV B 瞬停処理中	= ON		警報
2011/3/11 14:48	R300	TDRFP A トリップ	= トリップ		正常
2011/3/11 14:48	R301	TDRFP B トリップ	= トリップ		正常
2011/3/11 14:48	R717	D/G 2B 起動	= 起動		正常
* 2011/3/11 14:48	C030	トーラス温度 A	= 16.99907494	°C	不良
* 2011/3/11 14:48	C031	トーラス温度 B	= 15.39888859	°C	不良
* 2011/3/11 14:48	F004	高圧タービン 出口 蒸気圧力 D	= 0.015	MPa	不良
* 2011/3/11 14:48	F066	復水器 ホットウェル レベル A	= -127.40625	mm	不良
* 2011/3/11 14:48	F067	復水器 ホットウェル レベル B	= -120	mm	不良
* 2011/3/11 14:48	F068	復水器 ホットウェル レベル C	= -126.84375	mm	不良
2011/3/11 14:48	P419	PLRポンプA X軸振動	= -126.2099991	μ m	正常
2011/3/11 14:48	P422	PLRポンプB Y軸振動	= -129.3000031	μ m	正常

1F2プロセス計算機アラームプリンタ出力

時間	PID	名称	値	単位	
* 2011/3/11 14:48	S214	湿分分離器 出口 蒸気圧力	= 0.207968742	MPa	不良
* 2011/3/11 14:48	S226	第1給水加熱器 シェル側圧力	= 0.467708319	MPa	不良
* 2011/3/11 14:48	S227	第2給水加熱器 シェル側圧力	= 0.212750003	MPa	不良
* 2011/3/11 14:48	S228	第3給水加熱器 シェル側圧力	= 0.028406251	MPa	不良
* 2011/3/11 14:48	S229	第4給水加熱器 シェル側圧力	= 0.046734378	kPaabs	不良
* 2011/3/11 14:48	S230	第5給水加熱器 シェル側圧力	= 11.90104198	kPaabs	不良
* 2011/3/11 14:48	T008	タービン 潤滑油 レベル	= -159.75	mm	RL下限逸脱
* 2011/3/11 14:48	A556	原子炉 再循環ループ A	= トリップ		警報
* 2011/3/11 14:48	A557	原子炉 再循環ループ B	= トリップ		警報
2011/3/11 14:48	A607	UV リレ27 PLR(B)-A1 動作	= ON		正常
2011/3/11 14:48	A608	UV リレ27 PLR(B)-A2 動作	= ON		正常
2011/3/11 14:48	A611	UV リレ27 PLR(B)-B1 動作	= ON		正常
2011/3/11 14:48	A612	UV リレ27 PLR(B)-B2 動作 Diesel Generator	= ON		正常
* 2011/3/11 14:48	D586	ディーゼル発電機 2A 投入 2A Power-on	= ON		警報
2011/3/11 14:48	D680	6.9KV 母線 2C 電圧喪失 6.9kV Bus 2C	= OFF		正常
* 2011/3/11 14:48	D694	TD-RFP A トリップ Voltage Lost	= ON		警報
2011/3/11 14:48	D708	SGTS A 起動信号	= ON		正常
2011/3/11 14:48	D725	SRNM ペリオド 短短 CH-H	= 正常		正常
* 2011/3/11 14:48	B020	CS 系統流量 A	= 0	l/s	不良
* 2011/3/11 14:48	B022	RHR 系統流量 A	= 0	l/s	不良
* 2011/3/11 14:48	G007	発電機 界磁巻線 温度	= -0.090000004	°C	低
* 2011/3/11 14:48	S213	高圧タービン 出口 蒸気圧力	= 0.015	MPa	不良
* 2011/3/11 14:48	S236	復水器 ホットウェル 水位	= -124.75	mm	不良
* 2011/3/11 14:48	A527	RBM 下限	= 異常		警報
* 2011/3/11 14:48	A528	RBM 中性子束 高	= 高域		警報
* 2011/3/11 14:48	A529	RBM 動作不良	= 異常		警報
* 2011/3/11 14:48	A540	APRM 流量変換器 比較	= 異常		警報
2011/3/11 14:48	A586	主排気筒放射線モニタ 高	= ON		正常
* 2011/3/11 14:48	A603	SRNM ペリオド 短	= 短		警報
2011/3/11 14:48	A605	UV リレ27 PLR(A)-A1 動作	= OFF		正常
2011/3/11 14:48	A606	UV リレ27 PLR(A)-A2 動作	= OFF		正常
* 2011/3/11 14:48	D504	復水器真空度 A	= 低域		警報
* 2011/3/11 14:48	D506	復水器真空度 C	= 低域		警報
* 2011/3/11 14:48	D508	MSIV A1 チャンネル トリップ	= ON		警報
* 2011/3/11 14:48	D510	MSIV A2 チャンネル トリップ	= ON		警報
* 2011/3/11 14:48	D512	一次格納容器 圧力 A	= 高域		警報
* 2011/3/11 14:48	D514	一次格納容器 圧力 C	= 高域		警報
* 2011/3/11 14:48	D516	原子炉 圧力 A	= 高域		警報
* 2011/3/11 14:48	D518	原子炉 圧力 C	= 高域		警報

## 1F2プロセス計算機アラームプリンタ出力

時間	PID	名称	値	単位	
2011/3/11 14:48	S281	ジェットポンプ流量(B側総量)	= 4567.145508		正常
2011/3/11 14:48	S282	ジェットポンプ流量(A+B)	= 4567.145508		正常
* 2011/3/11 14:48	T004	タービン 第1段落 蒸気室 圧力	= 0.140625	MPa	低
* 2011/3/11 14:48	T008	タービン 潤滑油 レベル	= 533	mm	高
2011/3/11 14:48	A603	SRNM ペリオド 短	= 正常		正常
2011/3/11 14:48	D557	SRNM中性子束 高高 CH-H	= 正常		正常
2011/3/11 14:48	R715	ファーストランバック B	= ON		正常
2011/3/11 14:48	R717	D/G 2B 起動	= 停止		正常
2011/3/11 14:48	C013	原子炉水 浄化系 流量 A	= 0.079687499	t/h	正常
2011/3/11 14:48	C014	原子炉水 浄化系 流量 B	= 0.0140625	t/h	正常
2011/3/11 14:48	S219	原子炉水 浄化系 流量 (TOTAL)	= 0.09375	t/h	正常
* 2011/3/11 14:48	S243	TPM A系 中間値	= 1.171875	%	不良
2011/3/11 14:48	T006	タービン グランドシール 蒸気圧力	= 1.803374887	kPa	正常
2011/3/11 14:48	T008	タービン 潤滑油 レベル	= 161	mm	正常
* 2011/3/11 14:48	A601	SRNM 中性子束 高	= 高域		警報
* 2011/3/11 14:48	D531	原子炉 中性子モニタ系 トリップ B2	= トリップ		警報
2011/3/11 14:48	Z576	TIP検出器A 索引機構前	= OFF		正常
2011/3/11 14:48	Z577	TIP検出器B 索引機構前	= OFF		正常
2011/3/11 14:48	Z578	TIP検出器C 索引機構前	= OFF		正常
2011/3/11 14:48	Z579	TIP検出器D 索引機構前	= OFF		正常
* 2011/3/11 14:48	C028	圧力抑制室 水位	= 318.125	mm	高
2011/3/11 14:48	F042	第3給水加熱器 シェル側圧力 A	= 0.031265628	MPa	正常
* 2011/3/11 14:48	F067	復水器 ホットウェル レベル B	= 123.46875	mm	不良
* 2011/3/11 14:48	T006	タービン グランドシール 蒸気圧力	= 1.288124919	kPa	低
* 2011/3/11 14:48	D557	SRNM中性子束 高高 CH-H	= 高高		警報
* 2011/3/11 14:48	D587	ディーゼル発電機 2B 投入	= ON		警報
2011/3/11 14:48	D681	6.9KV 母線 2D 電圧喪失	= OFF		正常
2011/3/11 14:48	R715	ファーストランバック B	= OFF		正常
2011/3/11 14:48	C044	ドライウェル 床 ドレン水位	= -0.65625	cm	正常
2011/3/11 14:48	F067	復水器 ホットウェル レベル B	= 98.34375	mm	正常
* 2011/3/11 14:48	S207	再循環ループ 流量 B	= 1141.937988	t/h	入力不良
* 2011/3/11 14:48	S212	再循環ループ 流量	= 1149.718506	t/h	入力不良
* 2011/3/11 14:48	T006	タービン グランドシール 蒸気圧力	= 1.288124919	kPa	RL下限逸脱
2011/3/11 14:48	A523	APRM 下限	= 正常		正常
2011/3/11 14:48	A538	RBM バイパス	= OFF		正常
2011/3/11 14:48	A586	主排気筒放射線モニタ 高	= OFF		正常
2011/3/11 14:48	A601	SRNM 中性子束 高	= 正常		正常
2011/3/11 14:48	A609	UV リレ27 PLR(A)-B1 動作	= OFF		正常
2011/3/11 14:48	A610	UV リレ27 PLR(A)-B2 動作	= OFF		正常

1F2プロセス計算機アラームプリンタ出力

時間	PID	名称	値	単位	
* 2011/3/11 15:37	G004	発電機 励磁 電圧	= -1.96875	V	不良
* 2011/3/11 15:37	G005	発電機 励磁 電流	= -7.8125	A	不良
* 2011/3/11 15:37	G007	発電機 界磁巻線 温度	= 65.84999847	°C	不良
* 2011/3/11 15:37	S280	ジェットポンプ流量(A側総量)	= 0		入力不良
* 2011/3/11 15:37	S281	ジェットポンプ流量(B側総量)	= 0		入力不良
* 2011/3/11 15:37	S282	ジェットポンプ流量(A+B)	= 0		入力不良
2011/3/11 15:37	R719	D/G 2A 遮断器	= トリップ		正常
2011/3/11 15:37	Z523	TIP CH-A 案内管番地 1	= ON		正常
2011/3/11 15:37	Z527	TIP CH-B 案内管番地 1	= ON		正常
2011/3/11 15:37	Z531	TIP CH-C 案内管番地 1	= ON		正常
2011/3/11 15:37	Z535	TIP CH-D 案内管番地 1	= ON		正常
2011/3/11 15:37	Z576	TIP検出器A 索引機構前	= ON		正常
2011/3/11 15:37	Z577	TIP検出器B 索引機構前	= ON		正常
2011/3/11 15:37	Z578	TIP検出器C 索引機構前	= ON		正常
2011/3/11 15:37	Z579	TIP検出器D 索引機構前	= ON		正常
* 2011/3/11 15:37	A132	TPM 中間平均値	= 0.781	%PWR	不良
2011/3/11 15:37	B017	運転領域制限システム 出力制限値	= 24.53125	%PWR	正常
* 2011/3/11 15:37	B021	CS 系統流量 B	= 0	l/s	不良
* 2011/3/11 15:37	B023	RHR 系統流量 B	= 0	l/s	不良
* 2011/3/11 15:37	C000	制御棒 駆動水流量	= 0.0140625	t/h	不良
* 2011/3/11 15:37	C006	炉心圧力 損失	= -0.375	kPa	不良
2011/3/11 15:37	F089	復水器 A 電導度	= -0.0015	μ S/cm	正常
2011/3/11 15:37	F090	復水器 B 電導度	= 0	μ S/cm	正常
2011/3/11 15:37	F091	復水器 C 電導度	= -0.0005	μ S/cm	正常
* 2011/3/11 15:37	G004	発電機 励磁 電圧	= 0	V	低
* 2011/3/11 15:37	G005	発電機 励磁 電流	= -4.6875	A	低
2011/3/11 15:37	G007	発電機 界磁巻線 温度	= 35.15999985	°C	正常
* 2011/3/11 15:37	T007	タービン 軸受油 ヘッダ 圧力	= 0.09375	MPa	低
2011/3/11 15:37	A132	TPM 中間平均値	= 0.762	%PWR	正常
2011/3/11 15:37	B060	TIP A 炉心外検出器位置	= -0.015625	%	正常
2011/3/11 15:37	B061	TIP B 炉心外検出器位置	= -0.046875	%	正常
2011/3/11 15:37	B062	TIP C 炉心外検出器位置	= 0	%	正常
2011/3/11 15:37	B063	TIP D 炉心外検出器位置	= -0.015625	%	正常
* 2011/3/11 15:37	C028	圧力抑制室 水位	= -121.875	mm	低
* 2011/3/11 15:37	G007	発電機 界磁巻線 温度	= 8.130000114	°C	低
* 2011/3/11 15:37	P419	PLRポンプA X軸振動	= 781.8599854	μ m	不良
* 2011/3/11 15:37	P420	PLRポンプB X軸振動	= 782.0100098	μ m	不良
* 2011/3/11 15:37	P421	PLRポンプA Y軸振動	= 780.3300171	μ m	不良
* 2011/3/11 15:37	P422	PLRポンプB Y軸振動	= 782.4000244	μ m	不良

1F2プロセス計算機アラームプリンタ出力

時間	PID	名称	値	単位	
* 2011/3/11 15:37	A556	原子炉 再循環ループ A	= トリップ		警報
* 2011/3/11 15:37	A557	原子炉 再循環ループ B	= トリップ		警報
* 2011/3/11 15:37	D516	原子炉 圧力 A	= 高域		警報
2011/3/11 15:37	D662	RHR系 A 起動	= OFF		正常
2011/3/11 15:37	D664	RHR系 C 起動	= OFF		正常
* 2011/3/11 15:37	D680	6.9KV 母線 2C 電圧喪失	= ON		警報
2011/3/11 15:37	B021	CS 系統流量 B	= 0	l/s	正常
2011/3/11 15:37	B023	RHR 系統流量 B	= 0	l/s	正常
2011/3/11 15:37	C000	制御棒 駆動水流量	= 0.005625	t/h	正常
2011/3/11 15:37	C006	炉心圧力 損失	= -1.375	kPa	正常
2011/3/11 15:37	C080	ジェットポンプ流量-1	= 0	t/h	正常
2011/3/11 15:37	C081	ジェットポンプ流量-2	= 0	t/h	正常
2011/3/11 15:37	C082	ジェットポンプ流量-3	= 0	t/h	正常
2011/3/11 15:37	C083	ジェットポンプ流量-4	= 0	t/h	正常
2011/3/11 15:37	C084	ジェットポンプ流量-5	= 0	t/h	正常
2011/3/11 15:37	C085	ジェットポンプ流量-6	= 0	t/h	正常
2011/3/11 15:37	C086	ジェットポンプ流量-7	= 0	t/h	正常
2011/3/11 15:37	C087	ジェットポンプ流量-8	= 0	t/h	正常
2011/3/11 15:37	C088	ジェットポンプ流量-9	= 0	t/h	正常
2011/3/11 15:37	C089	ジェットポンプ流量-10	= 0	t/h	正常
2011/3/11 15:37	C090	ジェットポンプ流量-11	= 0	t/h	正常
2011/3/11 15:37	C091	ジェットポンプ流量-12	= 0	t/h	正常
2011/3/11 15:37	C092	ジェットポンプ流量-13	= 0	t/h	正常
2011/3/11 15:37	C093	ジェットポンプ流量-14	= 0	t/h	正常
2011/3/11 15:37	C094	ジェットポンプ流量-15	= 0	t/h	正常
2011/3/11 15:37	C095	ジェットポンプ流量-16	= 0	t/h	正常
2011/3/11 15:37	C096	ジェットポンプ流量-17	= 0	t/h	正常
2011/3/11 15:37	C097	ジェットポンプ流量-18	= 0	t/h	正常
2011/3/11 15:37	C098	ジェットポンプ流量-19	= 0	t/h	正常
2011/3/11 15:37	C099	ジェットポンプ流量-20	= 0	t/h	正常
2011/3/11 15:37	S280	ジェットポンプ流量(A側総量)	= 0		正常
2011/3/11 15:37	S281	ジェットポンプ流量(B側総量)	= 0		正常
2011/3/11 15:37	S282	ジェットポンプ流量(A+B)	= 0		正常
* 2011/3/11 15:37	D519	原子炉 圧力 D	= 高域		警報
2011/3/11 15:37	R701	RHR A ポンプ遮断器	= トリップ		正常
2011/3/11 15:37	R703	RHR C ポンプ遮断器	= トリップ		正常
2011/3/11 15:37	Z576	TIP検出器A 索引機構前	= OFF		正常
2011/3/11 15:37	Z577	TIP検出器B 索引機構前	= OFF		正常
2011/3/11 15:37	Z578	TIP検出器C 索引機構前	= OFF		正常

## 1F2プロセス計算機アラームプリンタ出力

時間	PID	名称	値	単位	
* 2011/3/11 15:40	F043	第3給水加熱器 シェル側圧力 B	= 0.017859375	MPa	不良
* 2011/3/11 15:40	F044	第3給水加熱器 シェル側圧力 C	= 0.011812501	MPa	不良
* 2011/3/11 15:40	F045	第4給水加熱器 シェル側圧力 A	= 0.024468752	MPaabs	不良
* 2011/3/11 15:40	F046	第4給水加熱器 シェル側圧力 B	= 0.037125003	MPaabs	不良
* 2011/3/11 15:40	F047	第4給水加熱器 シェル側圧力 C	= 0.030609377	MPaabs	不良
2011/3/11 15:40	F066	復水器 ホットウエル レベル A	= -139.6875	mm	正常
2011/3/11 15:40	F067	復水器 ホットウエル レベル B	= -136.21875	mm	正常
2011/3/11 15:40	F068	復水器 ホットウエル レベル C	= -142.21875	mm	正常
* 2011/3/11 15:40	F088	RFP 入口圧力	= 0.747500002	MPa	不良
* 2011/3/11 15:40	F089	復水器 A 電導度	= 0.052499998	μ S/cm	不良
* 2011/3/11 15:40	F090	復水器 B 電導度	= 0.059999999	μ S/cm	不良
* 2011/3/11 15:40	F091	復水器 C 電導度	= 0.064000003	μ S/cm	不良
* 2011/3/11 15:40	F094	低圧復水ポンプ A 出口圧力	= 0.016249999	MPa	不良
* 2011/3/11 15:40	F095	低圧復水ポンプ B 出口圧力	= 0.016875001	MPa	不良
* 2011/3/11 15:40	F096	低圧復水ポンプ C 出口圧力	= 0.020625001	MPa	不良
* 2011/3/11 15:40	F097	復水脱塩塔出口圧力	= 0.019375	MPa	不良
* 2011/3/11 15:40	F098	復水脱塩塔出口電導度	= 0.108550005	μ S/cm	不良
* 2011/3/11 15:40	F136	RFP-T(A)排気室圧力1	= 32.94843674	kPaabs	不良
* 2011/3/11 15:40	F137	RFP-T(A)排気室圧力2	= 29.57968712	kPaabs	不良
* 2011/3/11 15:40	F138	RFP-T(B)排気室圧力1	= 32.08906174	kPaabs	不良
* 2011/3/11 15:40	F139	RFP-T(B)排気室圧力2	= 29.63125038	kPaabs	不良
* 2011/3/11 15:40	G004	発電機 励磁 電圧	= -0.28125	V	不良
* 2011/3/11 15:40	G005	発電機 励磁 電流	= -4.6875	A	不良
* 2011/3/11 15:40	G006	発電機 水素ガス 圧力	= 0.413250029	MPa	不良
* 2011/3/11 15:40	P758	D/G 2B電流(R)	= 1266.349976	A	不良
* 2011/3/11 15:40	S219	原子炉水 浄化系 流量 (TOTAL)	= 1.603124976	t/h	入力不良
* 2011/3/11 15:40	S280	ジェットポンプ流量(A側総量)	= 0		入力不良
* 2011/3/11 15:40	S281	ジェットポンプ流量(B側総量)	= 0		入力不良
* 2011/3/11 15:40	S282	ジェットポンプ流量(A+B)	= 0		入力不良
* 2011/3/11 15:40	T003	タービン 加減弁 蒸気室 圧力	= -0.0028125	MPa	RL下限逸脱
* 2011/3/11 15:40	T004	タービン 第1段落 蒸気室 圧力	= -0.009375	MPa	RL下限逸脱
* 2011/3/11 15:40	T006	タービン グランドシール 蒸気圧力	= -0.450843722	kPa	RL下限逸脱
* 2011/3/11 15:40	T007	タービン 軸受油 ヘッド 圧力	= 0.057000004	MPa	RL下限逸脱
* 2011/3/11 15:40	T008	タービン 潤滑油 レベル	= -185.75	mm	低
2011/3/11 15:40	R720	D/G 2B 遮断器	= トリップ		正常
2011/3/11 15:40	B008	TIP チャンネル A	= 0	%PWR	正常
2011/3/11 15:40	B009	TIP チャンネル B	= 0	%PWR	正常
* 2011/3/11 15:40	B021	CS 系統流量 B	= 73.48469543	l/s	不良
* 2011/3/11 15:40	B023	RHR 系統流量 B	= 243.75	l/s	不良

## 1F2プロセス計算機アラームプリンタ出力

時間	PID	名称	値	単位	
* 2011/3/11 15:40	C000	制御棒 駆動水流量	= 0.01125	t/h	不良
* 2011/3/11 15:40	C006	炉心圧力 損失	= -1.375	kPa	不良
* 2011/3/11 15:40	C028	圧力抑制室 水位	= 33.125	mm	不良
* 2011/3/11 15:40	F066	復水器 ホットウエル レベル A	= -139.6875	mm	不良
* 2011/3/11 15:40	F067	復水器 ホットウエル レベル B	= -136.21875	mm	不良
* 2011/3/11 15:40	F068	復水器 ホットウエル レベル C	= -142.21875	mm	不良
* 2011/3/11 15:40	G007	発電機 界磁巻線 温度	= 21.12000084	°C	不良
2011/3/11 15:40	P758	D/G 2B電流(R)	= 7.650000095	A	正常
* 2011/3/11 15:40	S213	高圧タービン 出口 蒸気圧力	= 0.0021875	MPa	不良
* 2011/3/11 15:40	S214	湿分分離器 出口 蒸気圧力	= 0.03078125	MPa	不良
* 2011/3/11 15:40	S215	低圧タービン 入口 蒸気圧力	= -0.002395833	MPa	不良
* 2011/3/11 15:40	S226	第1給水加熱器 シェル側圧力	= 0.014791667	MPa	不良
* 2011/3/11 15:40	S227	第2給水加熱器 シェル側圧力	= 0.0130625	MPa	不良
* 2011/3/11 15:40	S228	第3給水加熱器 シェル側圧力	= 0.014046876	MPa	不良
* 2011/3/11 15:40	S229	第4給水加熱器 シェル側圧力	= 0.100875005	kPaabs	不良
2011/3/11 15:40	S236	復水器 ホットウエル 水位	= -139.375	mm	正常
* 2011/3/11 15:40	S254	低圧タービン 入口 蒸気圧力 A	= -0.0028125	MPa	不良
* 2011/3/11 15:40	S255	低圧タービン 入口 蒸気圧力 B	= -0.0003125	MPa	不良
* 2011/3/11 15:40	S256	低圧タービン 入口 蒸気圧力 C	= -0.0040625	MPa	不良
* 2011/3/11 15:40	T008	タービン 潤滑油 レベル	= -185.75	mm	RL下限逸脱
* 2011/3/11 15:40	D681	6.9KV 母線 2D 電圧喪失	= ON		警報
* 2011/3/11 15:40	B020	CS 系統流量 A	= 0	l/s	不良
* 2011/3/11 15:40	B022	RHR 系統流量 A	= 0	l/s	不良
* 2011/3/11 15:40	G007	発電機 界磁巻線 温度	= -0.150000006	°C	低
* 2011/3/11 15:40	S209	炉心流量(運転領域監視用)	= 0	%	入力不良
* 2011/3/11 15:40	S236	復水器 ホットウエル 水位	= -139.375	mm	不良
2011/3/11 15:40	D599	6.9KV M/C 遮断器 2D-2	= ON		正常
* 2011/3/11 15:40	S300	TPM 中間平均値用可変制限値	= 35	%PWR	入力不良
2011/3/11 15:40	F089	復水器 A 電導度	= -0.013499999	μS/cm	正常
2011/3/11 15:40	F090	復水器 B 電導度	= -0.013499999	μS/cm	正常
2011/3/11 15:40	F091	復水器 C 電導度	= -0.014	μS/cm	正常
2011/3/11 15:40	F098	復水脱塩塔出口電導度	= -0.0017	μS/cm	正常
2011/3/11 15:40	D567	低圧復水ポンプ B トリップ	= OFF		正常
2011/3/11 15:40	D656	MD-RFP B トリップ	= OFF		正常
* 2011/3/11 15:40	D567	低圧復水ポンプ B トリップ	= ON		警報
2011/3/11 15:40	D653	高圧復水ポンプ B トリップ	= OFF		正常
* 2011/3/11 15:40	S266	炉心 流量	= 27.5		入力不良
* 2011/3/11 15:40	S267	炉心 流量	= 0.082582586		入力不良
* 2011/3/11 15:40	D628	逃し安全弁 F 開	= ON		警報



## Analysis Result of Plant Data

### Unit 3

Date	Time	Plant Status	Confirmed by	Note
2011/3/11	14:46	Occurrence of Tohoku-Chihou-Taiheiyo-Oki Earthquake		
	14:47	Reactor Automatic Scrum A	Alarm Recorder ①	
		Reactor Automatic Scrum B	Alarm Recorder ②	
	14:48	D/G 3A C/B Closed	Alarm Recorder ③	
		M/C 3C Voltage Established	Alarm Recorder ④	
		D/G 3B C/B Closed	Alarm Recorder ⑤	
		M/C 3D Voltage Established	Alarm Recorder ⑥	
	14:49	Issuance of Major Tsunami Warning		
	15:38	M/C 3C Voltage Lost	Alarm Recorder ⑦	
		D/G 3A Stop	Alarm Recorder ⑧	
		D/G 3B Stop	Alarm Recorder ⑨	
	15:39	M/C 3D Voltage Lost	Alarm Recorder ⑩	

# Unit3

(in Operation)

## 3号機

(運転中)

内訳

Breakdown

- ① アラームタイプ  
Alarm recorder
- ② BOP タイパ (BOP=Balance of Plant : バランス・オブ・プラント)  
BOP recorder
- ③ NSS タイパ (NSS=Nuclear Steam Supply : 原子炉蒸気供給系)  
NSS recorder
- ④ OD タイパ他 (OD=On Demand : 任意要求)  
OD recorder and others

*0015	F126	樹脂ストレーナ差圧	2	下限	逸脱	0	KPA	正常	復帰
0107	F126	樹脂ストレーナ差圧	2						
11-03-11 金曜日 福島第一原子力発電所 3号機									
*0402	F143	復水器	A	第一水室出口冷却水温度	3	5.4	<	6.0	DEGC
0402	F143	復水器	A	第一水室出口冷却水温度	3	6.7	DEGC	正常	復帰
*0406	F000	補給水流量				0	T/H	正常	復帰
*0410	C138	復水器	C	出口冷却水温度		判定不能			
*0410	C138	復水器	C	冷却水出入口温度差		判定不能			
*0418	C137	復水器	B	出口冷却水温度		判定不能			
*0418	C137	復水器	B	冷却水出入口温度差		判定不能			
*0422	C138	復水器	C	出口冷却水温度		判定不能			
*0422	C138	復水器	C	冷却水出入口温度差		判定不能			
*0430	F143	復水器	A	第一水室出口冷却水温度	3	5.8	<	6.0	DEGC
*0430	F143	復水器	A	第一水室出口冷却水温度	3	7.0	DEGC	正常	復帰
*0431	F143	復水器	A	第一水室出口冷却水温度	3	判定不能			
*0431	F143	復水器	A	第一水室出口冷却水温度	3	判定不能			
*0435	C137	復水器	B	出口冷却水温度		判定不能			
*0435	C137	復水器	B	冷却水出入口温度差		判定不能			
*0438	F068	復水器	B	ホットウエル水位	C	-1.0	<	-1.00	MM
*0438	F068	復水器	B	ホットウエル水位	C	-0.9	MM	正常	復帰
*0439	C138	復水器	C	出口冷却水温度		判定不能			
*0443	C138	復水器	C	冷却水出入口温度差		判定不能			
*0443	C138	復水器	C	出口冷却水温度		判定不能			
*0443	C138	復水器	C	冷却水出入口温度差		判定不能			
*0446	F000	補給水流量	B	出口冷却水温度		判定不能			
*0447	F000	補給水流量	B	出口冷却水温度		判定不能			
*0447	F000	補給水流量	B	出口冷却水温度		判定不能			
*0447	F000	補給水流量	B	出口冷却水温度		判定不能			
*0451	C138	復水器	B	冷却水出入口温度差		判定不能			
*0451	C138	復水器	B	冷却水出入口温度差		判定不能			

11-03-11 金曜日 福島第一原子力発電所 3号機

11-03-11 金曜日 福島第一原子力発電所 3号機

1446	B605	床下	ポンプ	B	運転	オン			
1446	B605	床下	ポンプ	B	運転	オン			
1446	B605	床下	ポンプ	A	運転	オフ			
1447	B605	床下	ポンプ	A	運転	オフ			
トリップ	シケ	11秒	PI D		ポイント名	状態			
*1447	A524	APRM	中性子束高	高		高			
1447	B605	床下	ポンプ	B	運転	オン			
1447	4.7	750	D564	*	トリップ	トリップ			
1447	4.7	760	D534		自動スクラム	A			
1447	A524	APRM	中性子束高	高		正常	正常	復帰	
1447	B605	床下	ポンプ	B	運転	オフ			
*1447	A539	制御棒	挿入	正常		正常		復帰	
1447	A539	制御棒	挿入	正常		正常		復帰	
1447	B605	床下	ポンプ	A	運転	オン			
1447	B605	床下	ポンプ	B	運転	オン			
*1447	A524	APRM	中性子束高	高		正常		復帰	
1447	B605	床下	ポンプ	A	運転	オフ			
1447	B605	床下	ポンプ	B	運転	オフ			
*1447	A524	APRM	中性子束高	高		正常		復帰	
1447	B605	床下	ポンプ	A	運転	オン			
*1447	A539	制御棒	挿入	正常		正常		復帰	
1447	B605	床下	ポンプ	B	運転	オン			







15338	F066	復水器	ホットウェル	位置 A	71	MM	正常	復帰
*15338	TF007	タービン	軸受油	圧力	0.063	< 0.110	正常	MPA 復帰
15338	TF068	復水器	ホットウェル	位置 B	69	MM	正常	復帰
15338	TF067	復水器	ホットウェル	位置 C	71	MM	正常	復帰
15338	38	430	D602	タービンスラスト軸受異常トリップ				オン
15338	L600	SGTSS	A	運転				オン
15338	L600	SGTSS	A	運転				オン
15338	L600	SGTSS	A	運転				オン
15338	38	670	D705	D/G 母線 3C 電圧喪失				オン
15338	A548	RWM	制御棒	挿入許可 エコー				オン
*15338	A515	RWM	制御棒	挿入許可 エコー				オン
15338	G007	発電機	界磁電流	警告	70.1	DEGC	正常	復帰
*15338	C013	原子炉	浄化系	流量 A	下限	逸脱	2.8	< 221.6 CM
*15338	B015	液体	ボイラ	水位	下限	逸脱	2.8	< 221.6 CM
*15338	F134	主入口	電導度		下限	逸脱	100	A 正常 復帰
15338	G005	発電機	界磁電流		判定	不能		
15338	A547	RWM	制御棒	引抜許可 エコー				オン
*15338	C139	原子炉	浄化系	流量 (TOTAL)	判定	不能		
*15338	G007	発電機	界磁電流	警告	0.2	<	25.0	DEGC
*15338	F066	復水器	ホットウェル	位置 A	オーバー	フロー		オン
*15338	F068	復水器	ホットウェル	位置 C	オーバー	フロー		オン
*15338	F067	復水器	ホットウェル	位置 B	オーバー	フロー		オン
15338	A547	RWM	制御棒	引抜許可 エコー				オン
15338	A548	RWM	制御棒	挿入許可 エコー				オン
15338	A515	RWM	制御棒	挿入許可 エコー				オン
*15338	C123	復水器	C	第一水室入口冷却水温度	判定	不能		
*15338	A520	発電機	保護	電圧喪失				オン
15338	G005	発電機	界磁電流	警告	-0	<	-0	A オン
15338	38	730	D625	逃し安全弁 C 開	2	A		正常 復帰
15338	G007	発電機	界磁電流	警告	2	A		正常 復帰
15338	38	255	D602	タービンスラスト軸受異常トリップ				オフ
*15338	G005	発電機	界磁電流	警告	0	<	-0	A
15338	A548	RWM	制御棒	挿入許可 エコー				オン
*15338	A515	RWM	制御棒	挿入許可 エコー				オン
*15338	B013	S/C	水位		7.1	>	7.0	CM
15338	A547	RWM	制御棒	引抜許可 エコー				オン
15338	A547	RWM	制御棒	引抜許可 エコー				オン
15338	B013	S/C	水位		5.9	CM		正常 復帰
15338	A548	RWM	制御棒	挿入許可 エコー				オン
15338	A515	RWM	制御棒	挿入許可 エコー				オン
15338	38	810	D585	原子炉水位高	トリップ			トリップ
15338	38	40	D625	逃し安全弁 C 開				トリップ
15338	38	40	D585	原子炉水位高	トリップ			トリップ
*15338	C168	復水器	C	第一水室冷却水出入口温度差	判定	不能		
*15338	B229	S/C	水温	2系 (7G 付近)	32.3	>	32.0	DEGC
15338	A548	RWM	制御棒	挿入許可 エコー				オン
15338	A515	RWM	制御棒	挿入許可 エコー				オン
15338	L601	SGTSS	B	運転				オン
15338	38	620	D586	ディーゼル発電機 3A				オフ
15338	A547	RWM	制御棒	引抜許可 エコー				オン
15338	A547	RWM	制御棒	引抜許可 エコー				オン
15338	A548	RWM	制御棒	挿入許可 エコー				オン
15338	A515	RWM	制御棒	挿入許可 エコー				オン
15338	G005	発電機	界磁電流	警告	2	A		正常 復帰
*15338	G005	発電機	界磁電流	警告	2	<	-0	A 正常 復帰
15338	38	557	D587	ディーゼル発電機 3B				オフ
15338	L601	SGTSS	B	運転				オン
15338	L607	D/W	H2O2	濃度	測定以外			オン
15338	L611	CAMS	H2	濃度高	(D/W)			オン
15338	L612	CAMS	H2	濃度高	(S/C)			オン
15338	L613	CAMS	O2	濃度高	(D/W)			オン
15338	L614	CAMS	O2	濃度高	(S/C)			オン
15338	L609	S/C	H2O2	濃度	測定以外			オン
15338	L616	CAMS	放射線	濃度高	(S/C)			オン
15338	L615	CAMS	放射線	濃度高	(D/W)			オン
15338	G007	発電機	界磁電流	警告	34.1	DEGC		正常 復帰

*11533388	CC0143	原子炉浄化系流量	A	制限	逸脱
*11533388	CC0076	原子炉浄化系流量	B	制限	逸脱
*11533388	CC0076	CUWポンプ吐出流量	A	制限	逸脱
*11533388	CC0076	CUWポンプ吐出流量	B	制限	逸脱
*11533388	CC2085	ドライウエル床下レベル		制限	逸脱
*11533388	BF0003	液体ポンプ出口蒸気圧力	A	制限	逸脱
*11533388	FF0007	水分離器出口蒸気圧力	A	制限	逸脱
*11533388	FF0036	第1給水加熱器シエル側圧力	A	制限	逸脱
*11533388	FF0440	第2給水加熱器シエル側圧力	A	制限	逸脱
*11533388	FF0444	第3給水加熱器シエル側圧力	A	制限	逸脱
*11533388	FF0448	第5給水加熱器シエル側圧力	A	制限	逸脱
*11533388	FF0666	復水器ホットウエル水位	A	制限	逸脱
*11533388	39 0000	6.40 D706	6.9KV	メタクラ	4 KPAA 正常 復帰 -102 < -100 MM 母線電圧喪失 オン
*11533388	CF0049	原子炉給水ポンプ吐出ヘッド圧力		制限	逸脱
*11533388	FF0004	水分離器出口蒸気圧力	C	制限	逸脱
*11533388	FF0008	水分離器出口蒸気圧力	D	制限	逸脱
*11533388	FF0377	第1給水加熱器シエル側圧力	B	制限	逸脱
*11533388	FF0419	第2給水加熱器シエル側圧力	B	制限	逸脱
*11533388	TF0077	第5タービン軸受油ヘッド圧力	B	制限	逸脱
*11533388	FF0438	第1給水加熱器シエル側圧力	C	制限	逸脱
*11533388	FF0422	第3給水加熱器シエル側圧力	C	制限	逸脱
*11533388	FF0500	第5給水加熱器シエル側圧力	C	制限	逸脱
*11533388	FF0667	復水器ホットウエル水位	C	制限	逸脱
*11533388	BF0144	D/W 圧力 (W/R)		制限	逸脱
*11533388	FF0144	第2タービン入口蒸気圧力	A-2	制限	逸脱
*11533388	FF0139	第2給水加熱器シエル側圧力	A	制限	逸脱
*11533388	FF1366	低圧復水器ポンプ吐出圧力	A	制限	逸脱
*11533388	FF1097	原子炉給水ポンプ入口ヘッド圧力		制限	逸脱
*11533388	FF1055	高圧復水器ポンプ吐出圧力	C	制限	逸脱
*11533388	GG0033	高圧復水器ポンプ吐出圧力	A	制限	逸脱
*11533388	GG0055	発電機界磁電流		制限	逸脱
*11533388	B2218	S/C 圧力		制限	逸脱
*11533388	LL2011	I/A 圧力		制限	逸脱
*11533388	FF1044	高圧復水器ポンプ吐出圧力	B	制限	逸脱
*11533388	TT0066	タービンランドシール蒸気圧力		制限	逸脱
*11533388	CC0066	炉心圧力損失		制限	逸脱
*11533388	CC0002	発電機機軸圧巻線温度		制限	逸脱
*11533388	CC0007	発電機機軸磁巻線温度		制限	逸脱
*11533388	B22066	D/W 圧力 (N/R)		制限	逸脱
*11533388	CC0007	ジェットポンプ総流量		制限	逸脱
*11533388	BE0133	S/C 水位		制限	逸脱
*11533388	FF0668	運転領域制限システム出力制限値		制限	逸脱
*11533388	FF0668	復水器ホットウエル水位	A	制限	逸脱
*11533388	FF0667	復水器ホットウエル水位	B	制限	逸脱
*11533388	FF2333	S/C 水温		制限	逸脱
*11533388	CC1477	第1給水加熱器シエル側圧力		判定	不能
*11533388	CC1480	第2給水加熱器シエル側圧力		判定	不能
*11533388	CC0001	原子炉給水流速	A	制限	逸脱
*11533388	CC0002	原子炉給水流速	B	制限	逸脱
*11533388	CC0003	原子炉給水流速	A	制限	逸脱
*11533388	CC0004	原子炉給水流速	E	制限	逸脱
*11533388	CC0005	原子炉給水流速	J	制限	逸脱
*11533388	CC0006	原子炉給水流速	N	制限	逸脱
*11533388	CC0007	原子炉給水流速	T	制限	逸脱
*11533388	CC0008	原子炉給水流速	B	制限	逸脱
*11533388	CC0009	原子炉給水流速	F	制限	逸脱
*11533388	CC0010	原子炉給水流速	K	制限	逸脱
*11533388	CC0011	原子炉給水流速	P	制限	逸脱
*11533388	CC0012	原子炉給水流速	U	制限	逸脱
*11533388	CC0000	制御棒駆動水流速		制限	逸脱



**Analysis Result of Plant Data****Unit 4**

Date	Time	Plant Status	Confirmed by	Note
2011/3/11	14:46	Occurrence of Tohoku-Chihou-Taiheiyo-Oki Earthquake		
	14:49	Issuance of Major Tsunami Warning		
	15:38	Station Black Out	Shift Supervisor Task Handover Journal ①	

Unit3/4 Shift Supervisor Task  
Handover Journal

3、4号機 当直長引継日誌

Unit3/4, Fukushima Daiichi  
Nuclear Power Station

様式-1

福島第一原子力発電所 3・4号機

平成23年 3月 11日 金曜日(1直) 当直長引継日誌(2/3)

4号機	
1. 運転状況 Operatindg Condition	
(1) 定検停止中 Shut down for Regular Inspection	
(2) 所内電源喪失/原災法10条通報(緊急対策室より) 15:38/15:42	
Lost of In-site power source /Notice of Article 10, Act on Special Measures Concerning Nuclear Emergency Preparednss ( from Emergency Control Office)	
2. 保安規定の遵守状況 Compliance with Operational Safety Provisions	
異常あり、下記の条文が該当 Out of order/ Abnormality/ Malfunction , corresponding the following	
(1) 第17条(地震・火災等発生時の対応) Article 17 (Countermeasures in case of earthquakes, article fires etc.)	
(2) 第113条(通報) Article 113 (Notify)	
(3) 第121条(報告) Article 121 (Report)	
Regular test	
3. 定例試験	
なし	
Work request/ mismatched	
4. 作業依頼・不適合	
なし	
Situation of Waste Treatment Facility	赤文字は、未確定 作成途中で停電となっ ています。
5. 廃棄物処理設備の状況	
特記事項なし no special instruction	
Others (Common)	Red letters are not confirmed Power failed during writing
6. その他(共通)	
なし	

## Analysis Result of Plant Data

### Unit 5

Date	Time	Plant Status	Confirmed by	Note
2011/3/11	14:46	Occurrence of Tohoku-Chihou-Taiheiyo-Oki Earthquake		
	14:48	D/G 5A Operation	Alarm Recorder ①	
		M/C 5D Voltage Established	Alarm Recorder ②	
	14:48	D/G 5A Operation	Alarm Recorder ③	
		M/C 5C Voltage Established	Alarm Recorder ④	
	14:49	Issuance of Major Tsunami Warning		
	15:39	D/G 5A Stop	Alarm Recorder ⑤	
	15:40	M/C 5C Voltage Lost	Alarm Recorder ⑥	
		D/G 5B Stop	Alarm Recorder ⑦	
M/C 5D Voltage Lost		Alarm Recorder ⑧		

# Unit 5

(Under Regular Inspection)

## 5号機

(定期検査中)

内訳  
Breakdown

- ① アラームタイパ  
Alarm recorder

* 2011/03/11 14:48	A529	RBM 動作不良	= 異常	P=01	警報
* 2011/03/11 14:48	A540	APRM バイアス動作不良	= 異常	P=01	警報
2011/03/11 14:48	D545	APRM中性子束 高高 CH B	= 高		
2011/03/11 14:48	D547	APRM中性子束 高高 CH D	= 高		
2011/03/11 14:48	D549	APRM中性子束 高高 CH F	= 高		
* 2011/03/11 14:48	A135	TPM CHNL F	= -1.8	制限値=----	P=01 R L下限逸脱
2011/03/11 14:48	A135	TPM CHNL F	= 8.3		P=01 正常復帰
* 2011/03/11 14:48	C128	TPM B系 中間値	= 0.5	制限値=----	P=01 不良
2011/03/11 14:48	L600	SGTS A 運転	= ON		
2011/03/11 14:48	F108	浄化系脱塩器出口電導度 B	= -0.002		P=01 正常復帰
2011/03/11 14:48	F107	浄化系脱塩器出口電導度 A	= -0.002		P=01 正常復帰
* 2011/03/11 14:48	F108	浄化系脱塩器出口電導度 B	= -0.002	制限値=----	P=01 R L下限逸脱
* 2011/03/11 14:48	C037	再循環ループ流量 A 2	= 2870	制限値=----	P=01 R L下限逸脱
* 2011/03/11 14:48	C039	再循環ループ流量 B 2	= 2007	制限値=----	P=01 R L下限逸脱
* 2011/03/11 14:48	A131	TPM CHNL B	= -3.5	制限値=----	P=01 R L下限逸脱
* 2011/03/11 14:48	A133	TPM CHNL D	= -1.8	制限値=----	P=01 R L下限逸脱
2011/03/11 14:48	B013	S/C 水位	= 6.5		P=01 正常復帰
2011/03/11 14:48	F108	浄化系脱塩器出口電導度 B	= -0.002		P=01 正常復帰
* 2011/03/11 14:48	A135	TPM CHNL F	= -5.5	制限値=----	P=01 R L下限逸脱
* 2011/03/11 14:48	B013	S/C 水位	= 10.7	制限値=7	P=01 高
* 2011/03/11 14:48	G000	発電機電力	= 978.7	制限値=858.4	P=01 高
* 2011/03/11 14:48	A136	TPM 中間平均値	= -1.8	制限値=----	P=01 R L下限逸脱
* 2011/03/11 14:48	E018	福島 原子力幹線電圧	= -17.5	制限値=----	P=01 R L下限逸脱
2011/03/11 14:48	P539	D/G 5B 起動	= 停止		
2011/03/11 14:48	P554	MSIV自動 (内) DC	= ON		
2011/03/11 14:48	P555	MSIV自動 (外) AC	= ON		
2011/03/11 14:48	P197	PLRポンプA X軸振動	= 548.8		P=01 正常復帰
2011/03/11 14:48	P198	PLRポンプB X軸振動	= 544.5		P=01 正常復帰
2011/03/11 14:48	P199	PLRポンプA Y軸振動	= 533.5		P=01 正常復帰
2011/03/11 14:48	P200	PLRポンプB Y軸振動	= 524.0		P=01 正常復帰
* 2011/03/11 14:48	E014	起動変圧器 5SA2 電力	= 36.8	制限値=----	P=01 R L上限逸脱
* 2011/03/11 14:48	E019	福島 原子力幹線電流	= -11	制限値=----	P=01 R L下限逸脱
2011/03/11 14:48	B013	S/C 水位	= -1.2		P=01 正常復帰
2011/03/11 14:48	G000	発電機電力	= 737.0		P=01 正常復帰
* 2011/03/11 14:48	B013	S/C 水位	= -5.8	制限値=-3	P=01 低
2011/03/11 14:48	B016	炉水 電導度	= 0.19		P=01 正常復帰
* 2011/03/11 14:48	B017	原子炉出口 主蒸気温度 A 1	= 189.2	制限値=----	P=01 R L下限逸脱
* 2011/03/11 14:48	B018	原子炉出口 主蒸気温度 A 2	= 188.6	制限値=----	P=01 R L下限逸脱
2011/03/11 14:48	E015	起動変圧器 5SB1 電力	= 36.3		P=01 正常復帰
2011/03/11 14:48	E016	起動変圧器 5SB2 電力	= 35.2		P=01 正常復帰
* 2011/03/11 14:48	E018	福島 原子力幹線電圧	= 63.6	制限値=500	P=01 低
* 2011/03/11 14:48	F107	浄化系脱塩器出口電導度 A	= -0.008	制限値=----	P=01 R L下限逸脱
* 2011/03/11 14:48	F108	浄化系脱塩器出口電導度 B	= -0.008	制限値=----	P=01 R L下限逸脱
2011/03/11 14:48	D587	ディーゼル発電機 5B 運転	Operation = ON		
2011/03/11 14:48	D706	6.9KV ヌタクラ 5D 母線電圧喪失	= OFF		
2011/03/11 14:48	E001	所内変圧器 5B 電力	6.9kV Metal ICad = 22.4		P=01 正常復帰
2011/03/11 14:48	E014	起動変圧器 5SA2 電力	Switch Gear 5D = 32.2		P=01 正常復帰
2011/03/11 14:48	E019	福島 原子力幹線電流	Lost of Bus Voltage = -8		P=01 正常復帰

2011/03/11 14:49	P519	RPT 遮断器 B2	= OFF			
2011/03/11 14:49	P538	D/G 5A 起動	= 停止			
2011/03/11 14:49	P553	MSIV自動(内) AC	= ON			
2011/03/11 14:49	P556	MSIV自動(外) DC	= ON			
2011/03/11 14:49	B013	S/C 水位	= 1.0		P=01	正常復帰
2011/03/11 14:49	E000	所内変圧器 5A 電力	= 35.2		P=01	正常復帰
2011/03/11 14:49	G007	発電機界磁巻線温度	= -0.1		P=01	正常復帰
2011/03/11 14:49	D586	ディーゼル発電機 5A 運転	= ON			
2011/03/11 14:49	L600	SGTS A 運転	= ON			
2011/03/11 14:49	D705	6.9KV メタクラ 5C 母線電圧喪失	= OFF			
* 2011/03/11 14:49	B013	S/C 水位	= -5.5	制限値=-3	P=01	低
2011/03/11 14:49	B266	RHRポンプ C X軸振動	= 165		P=01	正常復帰
2011/03/11 14:49	C202	原子炉水位(広帯域) A	= -3914		P=01	正常復帰
2011/03/11 14:49	C203	原子炉水位(広帯域) B	= -3720		P=01	正常復帰
2011/03/11 14:49	E013	起動変圧器 5SA1 電力	= 24.8		P=01	正常復帰
2011/03/11 14:49	E014	起動変圧器 5SA2 電力	= 25.5		P=01	正常復帰
* 2011/03/11 14:49	F109	NO. 1 復水脱塩塔入口流量	= 268.1	制限値=550.1	P=01	低
* 2011/03/11 14:49	F110	NO. 2 復水脱塩塔入口流量	= 276.6	制限値=550.1	P=01	低
* 2011/03/11 14:49	F111	NO. 3 復水脱塩塔入口流量	= 176.0	制限値=550.1	P=01	低
* 2011/03/11 14:49	F112	NO. 4 復水脱塩塔入口流量	= 218.5	制限値=550.1	P=01	低
* 2011/03/11 14:49	F113	NO. 5 復水脱塩塔入口流量	= 206.2	制限値=550.1	P=01	低
* 2011/03/11 14:49	F114	NO. 6 復水脱塩塔入口流量	= 169.3	制限値=550.1	P=01	低
* 2011/03/11 14:49	F115	NO. 7 復水脱塩塔入口流量	= 141.4	制限値=550.1	P=01	低
* 2011/03/11 14:49	F116	NO. 8 復水脱塩塔入口流量	= 273.1	制限値=550.1	P=01	低
2011/03/11 14:49	F118	NO. 2 復水脱塩塔出口電導度	= -0.002		P=01	正常復帰
2011/03/11 14:49	F122	NO. 6 復水脱塩塔出口電導度	= 0.100		P=01	正常復帰
2011/03/11 14:49	F125	樹脂ストレーナ差圧 1	= 17		P=01	正常復帰
2011/03/11 14:49	F126	樹脂ストレーナ差圧 2	= 6		P=01	正常復帰
2011/03/11 14:49	F127	樹脂ストレーナ差圧 3	= 19		P=01	正常復帰
2011/03/11 14:49	F128	樹脂ストレーナ差圧 4	= 11		P=01	正常復帰
2011/03/11 14:49	F129	樹脂ストレーナ差圧 5	= 12		P=01	正常復帰
2011/03/11 14:49	F130	樹脂ストレーナ差圧 6	= 22		P=01	正常復帰
2011/03/11 14:49	F131	樹脂ストレーナ差圧 7	= 18		P=01	正常復帰
* 2011/03/11 14:49	G008	発電機水素ガス純度	= 89.5	制限値=92	P=01	低
2011/03/11 14:49	F117	NO. 1 復水脱塩塔出口電導度	= 0.022		P=01	正常復帰
2011/03/11 14:49	F119	NO. 3 復水脱塩塔出口電導度	= 0.027		P=01	正常復帰
2011/03/11 14:49	F120	NO. 4 復水脱塩塔出口電導度	= 0.022		P=01	正常復帰
* 2011/03/11 14:49	F122	NO. 6 復水脱塩塔出口電導度	= 0.245	制限値=0.15	P=01	高
2011/03/11 14:49	F123	NO. 7 復水脱塩塔出口電導度	= 0.009		P=01	正常復帰
2011/03/11 14:49	F132	樹脂ストレーナ差圧 8	= 7		P=01	正常復帰
2011/03/11 14:49	F134	主管入口電導度	= 0.005		P=01	正常復帰
2011/03/11 14:49	G008	発電機水素ガス純度	= 95.0		P=01	正常復帰
2011/03/11 14:49	L006	排ガス気水分離器 出口酸素	= 0.894		P=01	正常復帰
* 2011/03/11 14:49	L227	活性炭H/U塔出口放射線モニタ A	= -1.087	制限値=----	P=01	R L下限逸脱
2011/03/11 14:49	F124	NO. 8 復水脱塩塔出口電導度	= -0.000		P=01	正常復帰
2011/03/11 14:49	F133	主管差圧	= 33		P=01	正常復帰
2011/03/11 14:49	F135	主管出口電導度	= 0.003		P=01	正常復帰
* 2011/03/11 14:49	G008	発電機水素ガス純度	= 100.5	制限値=----	P=01	R L上限逸脱

2011/03/11 15:36	Z545	TIP マシン D 準備完了	= ON			
* 2011/03/11 15:37	P277	D/G 5B 電流 (R)	= 1045	制限値=----	P=01	R L 上限逸脱
2011/03/11 15:37	P535	RHR S Bポンプ遮断器	= OFF			
2011/03/11 15:37	P277	D/G 5B 電流 (R)	= 623		P=01	正常復帰
2011/03/11 15:37	P537	RHR S Dポンプ遮断器	= OFF			
2011/03/11 15:39	A694	原子炉建屋 放射能 高	= 正常		P=01	正常復帰
* 2011/03/11 15:39	A694	原子炉建屋 放射能 高	= 高		P=01	警報
2011/03/11 15:39	D586	ディーゼル発電機 5 A 運転	= OFF			
* 2011/03/11 15:39	G007	発電機界磁巻線温度	= 102.8	制限値=90	P=01	高
* 2011/03/11 15:39	B260	RHR ポンプ A 上部振動	= -1.0	制限値=----	P=01	R L 下限逸脱
* 2011/03/11 15:39	B261	RHR ポンプ B 上部振動	= -1.1	制限値=----	P=01	R L 下限逸脱
* 2011/03/11 15:39	B262	RHR ポンプ C 上部振動	= -1.1	制限値=----	P=01	R L 下限逸脱
* 2011/03/11 15:39	B263	RHR ポンプ D 上部振動	= -1.1	制限値=----	P=01	R L 下限逸脱
* 2011/03/11 15:39	B264	RHR ポンプ A X軸振動	= -51	制限値=----	P=01	R L 下限逸脱
* 2011/03/11 15:39	B265	RHR ポンプ B X軸振動	= -47	制限値=----	P=01	R L 下限逸脱
* 2011/03/11 15:39	B266	RHR ポンプ C X軸振動	= -52	制限値=----	P=01	R L 下限逸脱
* 2011/03/11 15:39	B267	RHR ポンプ D X軸振動	= -47	制限値=----	P=01	R L 下限逸脱
* 2011/03/11 15:39	B268	RHR ポンプ A Y軸振動	= -45	制限値=----	P=01	R L 下限逸脱
* 2011/03/11 15:39	B269	RHR ポンプ B Y軸振動	= -47	制限値=----	P=01	R L 下限逸脱
* 2011/03/11 15:39	B270	RHR ポンプ C Y軸振動	= -47	制限値=----	P=01	R L 下限逸脱
* 2011/03/11 15:39	B271	RHR ポンプ D Y軸振動	= -43	制限値=----	P=01	R L 下限逸脱
* 2011/03/11 15:39	G004	発電機界磁電圧	= -27.3	制限値=----	P=01	R L 下限逸脱
* 2011/03/11 15:39	G005	発電機界磁電流	= -208	制限値=----	P=01	R L 下限逸脱
2011/03/11 15:39	L607	D/W H2O2 モニタ 測定以外	= OFF			
2011/03/11 15:39	L611	CAMS H2 濃度高 (D/W)	= ON			
2011/03/11 15:39	L613	CAMS O2 濃度高 (D/W)	= ON			
2011/03/11 15:39	L609	S/C H2O2 モニタ 測定以外	= OFF			
2011/03/11 15:39	L614	CAMS O2 濃度高 (S/C)	= ON			
2011/03/11 15:39	L612	CAMS H2 濃度高 (S/C)	= ON			
2011/03/11 15:39	L600	SGTS A 運転	= OFF			
* 2011/03/11 15:39	F122	NO. 6 復水脱塩塔出口電導度	= 0.356	制限値=0.15	P=01	高
2011/03/11 15:40	L616	CAMS 放射線モニタ高 (S/C)	= ON			
2011/03/11 15:40	L615	CAMS 放射線モニタ高 (D/W)	= ON			
* 2011/03/11 15:40	F135	主管出口電導度	= -0.011	制限値=----	P=01	R L 下限逸脱
* 2011/03/11 15:40	L007	水素注入流量	= -1.5	制限値=----	P=01	R L 下限逸脱
* 2011/03/11 15:40	A695	タービン建屋 放射能 高	= 高		P=01	警報
* 2011/03/11 15:40	A696	コントロール建屋 放射能 高	= 高		P=01	警報
2011/03/11 15:40	DB593	NO. 6 復水脱塩塔処置電導度	= -0.231		P=00	正常復帰
2011/03/11 15:40	F107	浄化系脱塩器出口電導度 A	= 0.064		P=01	正常復帰
2011/03/11 15:40	F108	浄化系脱塩器出口電導度 B	= 0.070		P=01	正常復帰
* 2011/03/11 15:40	F118	NO. 2 復水脱塩塔出口電導度	= -0.009	制限値=----	P=01	R L 下限逸脱
* 2011/03/11 15:40	F134	主管入口電導度	= -0.011	制限値=----	P=01	R L 下限逸脱
* 2011/03/11 15:40	L008	酸素注入流量	= -2.41	制限値=----	P=01	R L 下限逸脱
* 2011/03/11 15:40	L227	活性炭H/U塔出口放射線モニタ A	= -1.221	制限値=----	P=01	R L 下限逸脱
* 2011/03/11 15:40	A697	廃棄物処理建屋H/U装置室 放射能 高	= 高		P=01	警報
* 2011/03/11 15:40	B280	運転領域制限システム 出力制限値	= -3.3	制限値=----	P=01	R L 下限逸脱
* 2011/03/11 15:40	F117	NO. 1 復水脱塩塔出口電導度	= -0.009	制限値=----	P=01	R L 下限逸脱
* 2011/03/11 15:40	F120	NO. 4 復水脱塩塔出口電導度	= -0.009	制限値=----	P=01	R L 下限逸脱



* 2011/03/11 15:40	B280	運転領域制限システム 出力制限値	= -1.6	制限値=----	P=01	R L 下限逸脱
* 2011/03/11 15:40	C107	ジェットポンプ流量 B1 (BV)	= 267	制限値=----	P=01	不良
* 2011/03/11 15:40	C108	ジェットポンプ流量 B2 (BV)	= 269	制限値=----	P=01	不良
* 2011/03/11 15:40	C109	ジェットポンプ流量 B3 (BV)	= 265	制限値=----	P=01	不良
* 2011/03/11 15:40	C110	ジェットポンプ流量 B4 (BV)	= 265	制限値=----	P=01	不良
* 2011/03/11 15:40	C111	ジェットポンプ流量 B5 (BV)	= 260	制限値=----	P=01	不良
* 2011/03/11 15:40	C112	ジェットポンプ流量 A1 (BV)	= 269	制限値=----	P=01	不良
* 2011/03/11 15:40	C113	ジェットポンプ流量 A2 (BV)	= 267	制限値=----	P=01	不良
* 2011/03/11 15:40	C114	ジェットポンプ流量 A3 (BV)	= 265	制限値=----	P=01	不良
* 2011/03/11 15:40	C115	ジェットポンプ流量 A4 (BV)	= 266	制限値=----	P=01	不良
* 2011/03/11 15:40	C116	ジェットポンプ流量 A5 (BV)	= 269	制限値=----	P=01	不良
* 2011/03/11 15:40	C118	ジェットポンプ流量 (B側総量)	= 2650	制限値=----	P=01	不良
* 2011/03/11 15:40	C119	ジェットポンプ流量 (A側総量)	= 2672	制限値=----	P=01	不良
* 2011/03/11 15:40	C120	ジェットポンプ流量 (A+B)	= 5322	制限値=----	P=01	不良
* 2011/03/11 15:40	F110	NO. 2 復水脱塩塔入口流量	= 495.4	制限値=550.1	P=01	低
* 2011/03/11 15:40	F112	NO. 4 復水脱塩塔入口流量	= 0.0	制限値=----	P=01	R L 下限逸脱
* 2011/03/11 15:40	F126	樹脂ストレーナ差圧 2	= -14	制限値=----	P=01	R L 下限逸脱
* 2011/03/11 15:40	F128	樹脂ストレーナ差圧 4	= -14	制限値=----	P=01	R L 下限逸脱
* 2011/03/11 15:40	F130	樹脂ストレーナ差圧 6	= -16	制限値=----	P=01	R L 下限逸脱
* 2011/03/11 15:40	F131	樹脂ストレーナ差圧 7	= -16	制限値=----	P=01	R L 下限逸脱
* 2011/03/11 15:40	G007	発電機界磁巻線温度	= -10.6	制限値=----	P=01	R L 下限逸脱
* 2011/03/11 15:40	L005	排ガスサンドフィルタ 入口流量	= 0.0	制限値=----	P=01	R L 下限逸脱
* 2011/03/11 15:40	F111	NO. 3 復水脱塩塔入口流量	= 0.0	制限値=----	P=01	R L 下限逸脱
* 2011/03/11 15:40	F116	NO. 8 復水脱塩塔入口流量	= 0.0	制限値=----	P=01	R L 下限逸脱
* 2011/03/11 15:40	F125	樹脂ストレーナ差圧 1	= -6	制限値=----	P=01	R L 下限逸脱
* 2011/03/11 15:40	F127	樹脂ストレーナ差圧 3	= 21	制限値=----	P=01	正常復帰
* 2011/03/11 15:40	E008	6.9kV メタクラ 5SA1 母線電圧	= -95	制限値=----	P=01	R L 下限逸脱
* 2011/03/11 15:40	F109	NO. 1 復水脱塩塔入口流量	= 0.0	制限値=----	P=01	R L 下限逸脱
* 2011/03/11 15:40	F127	樹脂ストレーナ差圧 3	= -5	制限値=----	P=01	R L 下限逸脱
* 2011/03/11 15:40	B011	TIP マシン D	= 15.6	制限値=----	P=01	R L 下限逸脱
* 2011/03/11 15:40	C007	ジェット ポンプ総流量	= 12244	制限値=----	P=01	R L 下限逸脱
* 2011/03/11 15:40	F110	NO. 2 復水脱塩塔入口流量	= 0.0	制限値=----	P=01	R L 下限逸脱
2011/03/11 15:40	P540	D/G 5A 遮断器	= トリップ			
2011/03/11 15:40	P542	LOPA D/G 5A 起動	= 停止			
2011/03/11 15:40	P163	原子炉水位 (W/R) A	= 1619		P=01	正常復帰
* 2011/03/11 15:40	C186	炉心流量 (T/H)	= 12244	制限値=----	P=01	不良
* 2011/03/11 15:40	C187	炉心流量 (%)	= 0	制限値=----	P=01	不良
* 2011/03/11 15:40	S316	ジェットポンプ総流量 (%)	= 36.8	制限値=----	P=01	不良
* 2011/03/11 15:40	S317	P-Fマップ 選択炉心流量 (%)	= 36.8	制限値=----	P=01	不良
* 2011/03/11 15:40	S318	P-Fマップ 選択炉心流量	= 12244	制限値=----	P=01	不良
* 2011/03/11 15:40	C203	原子炉水位 (広帯域) B	= -3969	制限値=----	P=01	R L 下限逸脱
* 2011/03/11 15:40	C202	原子炉水位 (広帯域) A	= -4033	制限値=----	P=01	R L 下限逸脱
* 2011/03/11 15:40	L219	CAMS H2 モニタ D/W	= -0.3	制限値=----	P=01	R L 下限逸脱
2011/03/11 15:40	L221	CAMS H2 モニタ S/C	= -0.3	制限値=----	P=01	R L 下限逸脱
2011/03/11 15:40	D705	6.9KV メタクラ 5C 母線電圧喪失	= ON			
2011/03/11 15:40	E008	6.9kV メタクラ 5SA1 母線電圧	= 166		P=01	正常復帰
2011/03/11 15:40	E000	所内変圧器 5A 電力	= 36.1		P=01	正常復帰
2011/03/11 15:40	E013	起動変圧器 5SA1 電力	= 35.5		P=01	正常復帰

2011/03/11 15:40	E014	起動変圧器 5 S A 2 電力	= 36.2		P=01	正常復帰
2011/03/11 15:40	L601	SGTS B 運転	= ON			
2011/03/11 15:40	D587	ディーゼル発電機 5 B 運転	= OFF			
* 2011/03/11 15:40	B014	D/W 圧力 (W/R)	= -24	制限値=----	P=01	R L 下限逸脱
* 2011/03/11 15:40	B218	S/C 圧力	= -34	制限値=----	P=01	R L 下限逸脱
2011/03/11 15:40	L601	SGTS B 運転	= OFF			
* 2011/03/11 15:40	A692	燃料プール区域 放射能 高	= 高		P=01	警報
* 2011/03/11 15:40	A693	燃料交換区域 放射能 高	= 高		P=01	警報
* 2011/03/11 15:40	B206	D/W 圧力 (N/R)	= -16.62	制限値=----	P=01	R L 下限逸脱
* 2011/03/11 15:40	B013	S/C 水位	= -60.5	制限値=----	P=01	R L 下限逸脱
* 2011/03/11 15:40	F107	浄化系脱塩器出口電導度 A	= -0.003	制限値=----	P=01	R L 下限逸脱
* 2011/03/11 15:40	F108	浄化系脱塩器出口電導度 B	= -0.002	制限値=----	P=01	R L 下限逸脱
* 2011/03/11 15:40	C000	制御棒駆動水流量	= 0.0	制限値=----	P=01	R L 下限逸脱
* 2011/03/11 15:40	C006	炉心圧力損失	= 0.1	制限値=----	P=01	R L 下限逸脱
* 2011/03/11 15:40	C011	原子炉水浄化系入口温度	= 86.2	制限値=----	P=01	R L 下限逸脱
* 2011/03/11 15:40	F139	床ドレンサンブ水位	= -9.6	制限値=----	P=01	R L 下限逸脱
* 2011/03/11 15:40	F140	D/W機器ドレンサンブ水位	= -5.6	制限値=----	P=01	R L 下限逸脱
* 2011/03/11 15:40	L224	主蒸気管放射線モニタ A/C	= -2.092	制限値=----	P=01	R L 下限逸脱
* 2011/03/11 15:40	L225	主蒸気管放射線モニタ B/D	= -2.092	制限値=----	P=01	R L 下限逸脱
* 2011/03/11 15:40	L227	活性炭H/U塔出口放射線モニタ A	= -1.116	制限値=----	P=01	R L 下限逸脱
* 2011/03/11 15:40	F048	第5給水加熱器 シェル側圧力 A	= 39.77	制限値=39.23	P=01	高
* 2011/03/11 15:40	F049	第5給水加熱器 シェル側圧力 B	= 39.92	制限値=39.23	P=01	高
* 2011/03/11 15:40	F050	第5給水加熱器 シェル側圧力 C	= 41.08	制限値=39.23	P=01	高
* 2011/03/11 15:40	B016	炉水 電導度	= -0.08	制限値=----	P=01	R L 下限逸脱
2011/03/11 15:40	F048	第5給水加熱器 シェル側圧力 A	= 33.19		P=01	正常復帰
2011/03/11 15:40	F049	第5給水加熱器 シェル側圧力 B	= 32.37		P=01	正常復帰
2011/03/11 15:40	F050	第5給水加熱器 シェル側圧力 C	= 33.69		P=01	正常復帰
2011/03/11 15:40	L224	主蒸気管放射線モニタ A/C	= -1.624		P=01	正常復帰
2011/03/11 15:40	L225	主蒸気管放射線モニタ B/D	= -1.582		P=01	正常復帰
2011/03/11 15:40	L227	活性炭H/U塔出口放射線モニタ A	= -0.544		P=01	正常復帰
2011/03/11 15:40	C020	再循環ポンプ入口温度 A 1	= 199.4		P=01	正常復帰
2011/03/11 15:40	C022	再循環ポンプ入口温度 B 1	= 200.7		P=01	正常復帰
2011/03/11 15:40	C023	再循環ポンプ入口温度 B 2	= 199.4		P=01	正常復帰
2011/03/11 15:40	C040	原子炉給水入口温度 A 1	= 135.1		P=01	正常復帰
2011/03/11 15:40	C041	原子炉給水入口温度 A 2	= 134.3		P=01	正常復帰
2011/03/11 15:40	C042	原子炉給水入口温度 B 1	= 134.2		P=01	正常復帰
2011/03/11 15:40	C043	原子炉給水入口温度 B 2	= 134.3		P=01	正常復帰
2011/03/11 15:40	C101	再循環ポンプ入口温度 A (BV)	= 199.4		P=01	正常復帰
2011/03/11 15:40	C102	再循環ポンプ入口温度 B (BV)	= 200.1		P=01	正常復帰
2011/03/11 15:40	C105	原子炉給水温度 A (BV)	= 134.7		P=01	正常復帰
2011/03/11 15:40	C106	原子炉給水温度 B (BV)	= 134.2		P=01	正常復帰
* 2011/03/11 15:40	C123	機器ドレンサンブ水位変化率	= -164.85	制限値=----	P=01	不良
2011/03/11 15:40	C125	原子炉給水入口温度	= 134.5		P=01	正常復帰
2011/03/11 15:40	C150	第5給水加熱器 シェル側圧力	= 26.22		P=01	正常復帰
* 2011/03/11 15:40	C189	原子炉水浄化系入口温度 変化率	= -19.9	制限値=----	P=01	不良
* 2011/03/11 15:40	E001	所内変圧器 5 B 電力	= 58.2	制限値=----	P=01	R L 上限逸脱
* 2011/03/11 15:40	E015	起動変圧器 5 S B 1 電力	= 58.2	制限値=----	P=01	R L 上限逸脱
* 2011/03/11 15:40	E016	起動変圧器 5 S B 2 電力	= 58.2	制限値=----	P=01	R L 上限逸脱

* 2011/03/11 15:40	P225	発電機無効電力	= -2819	制限値=----	P=01	R L 上限逸脱
* 2011/03/11 15:40	G002	発電機電圧	= -0.2	制限値=16.32	P=01	低
2011/03/11 15:40	E005	6.9kV メタクラ 5B 母線電圧	= -55		P=01	正常復帰
2011/03/11 15:40	D706	6.9KV メタクラ 5D 母線電圧喪失	= ON			
* 2011/03/11 15:40	C156	復水器ホットウェル水位	= -154	制限値=----	P=01	不良
* 2011/03/11 15:40	E018	福島 原子力幹線電圧	= 429.0	制限値=500	P=01	低
2011/03/11 15:40	F108	浄化系脱塩器出口電導度 B	= -0.002		P=01	正常復帰
2011/03/11 15:40	F107	浄化系脱塩器出口電導度 A	= -0.002		P=01	正常復帰
* 2011/03/11 15:40	G000	発電機電力	= 1043.9	制限値=858.4	P=01	高
* 2011/03/11 15:40	E018	福島 原子力幹線電圧	= -16.1	制限値=----	P=01	R L 下限逸脱
* 2011/03/11 15:40	E019	福島 原子力幹線電流	= -11	制限値=----	P=01	R L 下限逸脱
2011/03/11 15:40	G000	発電機電力	= 774.8		P=01	正常復帰
2011/03/11 15:40	P225	発電機無効電力	= -1787		P=01	正常復帰
2011/03/11 15:40	E015	起動変圧器 5SB1 電力	= 35.1		P=01	正常復帰
2011/03/11 15:40	E016	起動変圧器 5SB2 電力	= 35.7		P=01	正常復帰
2011/03/11 15:40	E001	所内変圧器 5B電力	= 35.2		P=01	正常復帰
* 2011/03/11 15:40	L222	CAMS O2 モニタ S/C	= -0.3	制限値=----	P=01	R L 下限逸脱
* 2011/03/11 15:40	G001	発電機無効電力	= -1081	制限値=-250	P=01	低
2011/03/11 15:40	E019	福島 原子力幹線電流	= -10		P=01	正常復帰
* 2011/03/11 15:40	E018	福島 原子力幹線電圧	= -12.2	制限値=500	P=01	低
2011/03/11 15:40	B016	炉水 電導度	= -0.02		P=01	正常復帰
* 2011/03/11 15:40	B016	炉水 電導度	= -0.02	制限値=----	P=01	R L 下限逸脱
2011/03/11 15:40	B016	炉水 電導度	= -0.02		P=01	正常復帰
* 2011/03/11 15:40	L220	CAMS O2 モニタ D/W	= -0.3	制限値=----	P=01	R L 下限逸脱
2011/03/11 15:40	B011	TIP マシン D	= -2.5		P=01	正常復帰
* 2011/03/11 15:40	S918	制御用計算機 機器故障	= ON		P=01	警報
2011/03/11 15:40	S918	制御用計算機 機器故障	= OFF		P=01	正常復帰
* 2011/03/11 15:40	S918	制御用計算機 機器故障	= ON		P=01	警報
2011/03/11 15:40	G001	発電機無効電力	= -141		P=01	正常復帰
2011/03/11 15:40	B009	TIP マシン B	= -2.4		P=01	正常復帰
2011/03/11 15:40	B008	TIP マシン A	= -2.5		P=01	正常復帰
2011/03/11 15:40	B010	TIP マシン C	= -2.5		P=01	正常復帰
2011/03/11 15:40	S918	制御用計算機 機器故障	= OFF		P=01	正常復帰
* 2011/03/11 15:41	C121	床ドレンサンプ水位変化率	= -65.48	制限値=----	P=01	不良
2011/03/11 15:41	D229	再循環ループ 入口平均温度	= 200.0		P=00	正常復帰
* 2011/03/11 15:41	D245	浄化系流量	= 0.0	制限値=----	P=00	不良
* 2011/03/11 15:41	DB107	ジェットポンプ流量 (A+B) (1分値)	= 5322	制限値=----	P=00	不良
* 2011/03/11 15:41	DB108	炉心圧力損失 (1分値)	= 0.0	制限値=----	P=00	不良
* 2011/03/11 15:41	DB114	主蒸気ヘッド圧力 (1分値)	= -0.05	制限値=----	P=00	不良
* 2011/03/11 15:41	DB115	低圧タービン入口蒸気圧力 A1 (1分値)	= 0.000	制限値=----	P=00	不良
* 2011/03/11 15:41	DB116	低圧タービン入口蒸気圧力 B1 (1分値)	= -0.002	制限値=----	P=00	不良
* 2011/03/11 15:41	DB117	低圧タービン入口蒸気圧力 C1 (1分値)	= -0.000	制限値=----	P=00	不良
* 2011/03/11 15:41	DB118	タービングラウンドシール蒸気圧力 (1分値)	= -0.080	制限値=----	P=00	不良
* 2011/03/11 15:41	DB120	タービン軸受油ヘッド 圧力 (1分値)	= 0.003	制限値=----	P=00	不良
* 2011/03/11 15:41	DB128	復水器ホットウェル水位 B (1分値)	= -152	制限値=----	P=00	不良
* 2011/03/11 15:41	DB569	第4給水加熱器A飽和温度 (1分値)	= 99.93	制限値=----	P=00	不良
* 2011/03/11 15:41	DB570	第4給水加熱器B飽和温度 (1分値)	= 99.95	制限値=----	P=00	不良
* 2011/03/11 15:41	DB571	第4給水加熱器C飽和温度 (1分値)	= 99.96	制限値=----	P=00	不良

## Analysis Result of Plant Data

### Unit 6

Date	Time	Plant Status	Confirmed by	Note
2011/3/11	14:46	Occurrence of Tohoku-Chihou-Taiheiyo-Oki Earthquake		
	14:48	M/C 6D Voltage Lost	Alarm Recorder ①	
		D/G 6B Operation	Alarm Recorder ②	
		M/C 6D Voltage Established	Alarm Recorder ③	
	14:49	M/C 6C Voltage Lost	Alarm Recorder ④	
		M/C HPCS Voltage Established	Alarm Recorder ⑤	
		D/G 6A Operation	Alarm Recorder ⑥	
		M/C 6C Voltage Established	Alarm Recorder ⑦	
		D/G HPCS Operation	Alarm Recorder ⑧	
	14:49	Issuance of Major Tsunami Warning		
		15:40	M/C 6C Voltage Lost	Alarm Recorder ⑩
	D/G HPCS Stop		Alarm Recorder ⑪	
	M/C HPCS Voltage Lost		Alarm Recorder ⑫	

# 6号機

(定期検査中)

内訳

- ① アラームタイパ

14	48	38	830	D653	AUX XFMR 6B PRESS	TRIP
1448	3101	S/T LEVEL			LOW RSN	
14	48	38	940	D653	AUX XFMR 6B P	NORM
1448	A513	DISCH LVL ROD BLOK 2			ON	
14	48	39	060	D653	AUX XFMR 6B PRESS	TRIP
1448	F518	DEMI TRANSFER PUMP A			ON	
14	48	39	170	D653	AUX XFMR 6B PRESS	NORM
1448	L519	SERVICE AIR COMP B			OFF	
14	48	39	380	D686	TURB THRST BRG TRIP	OFF
1448	Z609	6.9KV M/C 632-1B			OFF	
14	48	39	440	D653	AUX XFMR 6B PRESS	TRIP
1448	L524	CIRC WTR PUMP 3			OFF	
14	48	39	540	D653	AUX XFMR 6B PRESS	NORM
1448	L517	CRD PUMP B			OFF	
14	48	40	120	D686	TURB THRST BRG TRIP	ON
1448	G501	STATOR COOLING PMP B			OFF	
14	48	40	490	D625	MDRFP AUX OIL PMP B	ON
1448	L507	AUX SEAWATER PUMP B			OFF	
14	48	41	670	D653	AUX XFMR 6B PRESS	TRIP
1448	L510	RHR SEAWATER PUMP B			OFF	
14	48	41	770	D653	AUX XFMR 6B PRESS	NORM
1448	L512	RHR SEAWATER PUMP D			OFF	
14	48	42	300	D653	AUX XFMR 6B PRESS	TRIP
1448	L501	REAC BLDG CCW PUMP B			OFF	
14	48	42	410	D653	AUX XFMR 6B PRESS	NORM
1448	L504	TURB BLDG CCW PUMP B			OFF	
14	48	42	520	D625	MDRFP AUX OIL PMP B	OFF
1448	Z615	6.9KV M/C 6D-8B			OFF	
14	48	42	520	D635	TDRFP MAIN OIL-P B1	OFF
1448	T506	TURB IHC PUMP B			OFF	
14	48	42	760	D636	TDRFP MAIN OIL-P B2	ON
1448	F000	MAKE-UP FLOW			50.6 T/H NORMAL RETURN	
14	48	43	120	D686	TURB THRST BRG TRIP	OFF
1448	L501	REAC BLDG CCW PUMP B			ON	
14	48	43	220	D653	AUX XFMR 6B PRESS	TRIP
1448	3624	UV RY27 PLR A-C1 ACT			OFF	
14	48	43	330	D653	AUX XFMR 6B PRESS	NORM
1448	3625	UV RY27 PLR A-C2 ACT			OFF	
14	48	44	620	D686	TURB THRST BRG TRIP	ON
1448	3626	UV RY27 PLR B-D1 ACT			OFF	
14	48	44	970	D707	REACTOR WTR LEVEL HI	TRIP
1448	3627	UV RY27 PLR B-D2 ACT			OFF	
14	48	45	080	D707	REACTOR WTR LEVEL HI	NORM
1448	A600	PCIS ISOLATE INLET			ON	
14	48	45	480	D671	HP CONDENSATE PUMP C	OFF
1448	Z520	TIP NORMAL			OFF	
14	48	45	540	D776	D/G BUS LOSS 6D	ON
1448	A534	FLO UNIT UPSCALE/INOP			TRIP	
14	48	45	590	D581	RHR PUMP BREAKER B	OPEN
1448	A528	AFTW UPSCALE			ALM	
14	48	45	180	D707	REACTOR WTR LEVEL HI	TRIP
1448	A529	APRM INOPERATIVE			ALM	
14	48	46	690	D655	DIESEL GENERATOR 6B	ON
1448	A532	REM TRIP ON LEVEL			ALM	
14	48	46	700	D625	MDRFP AUX OIL PMP B	ON
1448	A544	ALM ON FLW COMPARATR			ALM	
14	48	46	800	D776	D/G BUS LOSS 6D	OFF
1448	A570	REM CH 1 INOPERATIVE			ALM	
14	48	47	090	D707	REACTOR WTR LEVEL HI	NORM
1448	A571	REM CH 3 BYPASSED			OFF	
14	48	47	590	D514	DCV PRES (SCRAM) B2	TRIP
1448	A531	REM DOWNSCALE			ALM	
14	48	47	590	D516	REACTOR CH B1 HI PYS	TRIP
1448	G504	GEN MAIN SEAL OIL-P			OFF	
14	48	47	590	D528	NEUT MON SYSTEM CH B1	TRIP
1448	A557	RECIRC LP A FLW			ON	
14	48	47	590	D522	REACTOR LO WTR CH B2	TRIP
1448	A558	RECIRC LP B FLW			ON	
14	48	47	590	A505	MSL D HIGH FLOW	HIGH
1448	G506	GEN SEAL OIL VAC-P A			OFF	

14	48	50	720	D624	MDRFP AUX OIL PMP A	ON
1448	A156	LPRM	16-57	FLX LV A	LOW RSN	
14	48	51	720	D653	AUX XFMR 6B PRESS	TRIP
1448	A166	LPRM	32-57	FLX LV C	LOW RSN	
14	48	51	890	D653	AUX XFMR 6B PRESS	NORM
1448	AD36	LPRM	40-17	FLX LV A	LOW RSN	
14	48	58	040	D686	TURB THRST BRG TRIP	OFF
1448	AD20	LPRM	08-17	FLX LV A	LOW RSN	
14	49	00	360	D584	DISCH VOL LVL CHL A2	TRIP
1448	AD90	LPRM	24-17	FLX LV C	LOW RSN	
14	49	00	440	D686	TURB THRST BRG TRIP	ON
1448	AD48	LPRM	56-17	FLX LV C	LOW RSN	
14	49	01	400	D653	AUX XFMR 6B PRESS	TRIP
1448	AD78	LPRM	08-33	FLX LV C	LOW RSN	
14	49	01	500	D653	AUX XFMR 6B PRESS	NORM
1448	AD84	LPRM	24-33	FLX LV A	LOW RSN	
14	49	02	040	D707	REACTOR WTR LEVEL HI	NORM
1448	AD94	LPRM	40-33	FLX LV C	LOW RSN	
14	49	03	450	D707	REACTOR WTR LEVEL HI	TRIP
1448	A100	LPRM	56-33	FLX LV A	LOW RSN	
14	49	03	950	D653	AUX XFMR 6B PRESS	TRIP
1448	A132	LPRM	08-49	FLX LV A	LOW RSN	
14	49	04	050	D653	AUX XFMR 6B PRESS	NORM
1448	A142	LPRM	24-49	FLX LV C	LOW RSN	
14	49	05	100	D622	MDRFP INJ BOOST-P A	OFF
1448	A148	LPRM	40-49	FLX LV A	LOW RSN	
14	49	05	110	D633	TDRFP MAIN OIL-P A1	OFF
1448	AD22	LPRM	08-17	FLX LV C	LOW RSN	
14	49	05	110	D636	TDRFP MAIN OIL-P B2	OFF
1448	AD28	LPRM	24-17	FLX LV A	LOW RSN	
14	49	05	110	D624	MDRFP AUX OIL PMP A	OFF
1448	AD38	LPRM	40-17	FLX LV C	LOW RSN	
14	49	08	230	D775	D/G BUS LOSS 6C	ON
1448	AD44	LPRM	56-17	FLX LV A	LOW RSN	
14	49	08	300	D777	D/G BUS LOSS HPCS	ON
1448	PS18	DEMI	TRANSFER PUMP A	OFF		
14	49	08	460	D672	LP CONDENSATE PUMP A	OFF
1448	AD76	LPRM	08-33	FLX LV A	LOW RSN	
14	49	09	410	D654	DIESEL GENERATOR 6A	ON
1448	AD86	LPRM	24-33	FLX LV C	LOW RSN	
14	49	09	410	D624	MDRFP AUX OIL PMP A	ON
1448	AD92	LPRM	40-33	FLX LV A	LOW RSN	
14	49	09	520	D775	D/G BUS LOSS 6C	OFF
1448	A102	LPRM	56-33	FLX LV C	LOW RSN	
14	49	10	120	A506	MSL A LEAK DETECTION	HIGH
1448	A134	LPRM	08-49	FLX LV C	LOW RSN	
14	49	10	120	D519	REACTOR LD WTR CH A1	TRIP
1448	A140	LPRM	24-49	FLX LV A	LOW RSN	
14	49	10	120	D505	CONDR LOW VACM A	TRIP
1448	A150	LPRM	40-49	FLX LV C	LOW RSN	
14	49	10	120	D515	REACTOR CH A1 HI PRS	TRIP
1448	3050	REAC	FW A1	INLT TEMP	135.0 DEGC NORMAL RETURN	
14	49	10	120	D527	NEUT MON SYSTEM CH A1	TRIP
1448	3052	REAC	FW B1	INLT TEMP	135.3 DEGC NORMAL RETURN	
14	49	10	120	D712	MSL T/B HIGH TEMP A	TRIP
1448	3055	REAC	PMP A1	INLT TEMP	200.5 DEGC NORMAL RETURN	
14	49	10	120	D724	RX LVL(L-2MSIV)LO A1	ON
1448	AD21	LPRM	08-17	FLX LV B	LOW RSN	
14	49	10	120	A507	MSL B LEAK DETECTION	HIGH
1448	AD31	LPRM	24-17	FLX LV D	LOW RSN	
14	49	10	120	D722	MSIV OTR TRIP AC	ON
1448	AD37	LPRM	40-17	FLX LV B	LOW RSN	
14	49	10	120	A504	MSL C HIGH FLOW	HIGH
1448	AD47	LPRM	56-17	FLX LV D	LOW RSN	
14	49	10	120	D511	PCV PRES (SCRAM) A1	TRIP
1448	AD79	LPRM	08-33	FLX LV D	LOW RSN	
14	49	10	120	D521	REACTOR LD WTR CH A2	TRIP
1448	AD85	LPRM	24-33	FLX LV B	LOW RSN	
14	49	10	120	D523	MSL A1 HI RADIATION	TRIP
1448	AD95	LPRM	40-33	FLX LV D	LOW RSN	

1448	A085	LPRM	24-33	FLX LV B	LOW RSN		
14	49	10	120	D523	MSL A1 HI RADIATION	TRIP	
1448	A095	LPRM	40-33	FLX LV D	LOW RSN		
14	49	10	120	D533	MANUAL SCRAM CHNL A	TRIP	
1448	A101	LPRM	56-33	FLX LV B	LOW RSN		
14	49	10	120	D637	DISCH VOL LVL CHL C2	TRIP	
1448	A133	LPRM	08-49	FLX LV B	LOW RSN		
14	49	10	120	D620	CONDSR LOW VACM C	TRIP	
1448	A143	LPRM	24-49	FLX LV D	LOW RSN		
14	49	10	120	A502	MSL A HIGH FLOW	HIGH	
1448	A149	LPRM	40-49	FLX LV B	LOW RSN		
14	49	10	120	D502	DISCH VOL LVL CHL C1	TRIP	
1448	A003	LPRM	16-09	FLX LV D	LOW RSN		
14	49	10	120	D725	RX LVL(L-2MSIV)LO.A2	ON	
1448	A009	LPRM	32-09	FLX LV B	LOW RSN		
14	49	10	120	D500	DISCH VOL LVL CHL A1	TRIP	
1448	A019	LPRM	48-09	FLX LV D	LOW RSN		
14	49	10	120	D525	MSL A2 HI RADIATION	TRIP	
1448	A053	LPRM	16-25	FLX LV B	LOW RSN		
14	49	10	120	D529	NEUT MON SYSTEM CH A2	TRIP	
1448	A001	LPRM	16-09	FLX LV B	LOW RSN		
14	49	10	120	D714	MSL T/B HIGH TEMP C	TRIP	
1448	A011	LPRM	32-09	FLX LV D	LOW RSN		
14	49	10	130	D517	REACTOR CH A2 HI PRS	TRIP	
1448	A017	LPRM	48-09	FLX LV B	LOW RSN		
14	49	10	130	D513	PCV PRES (SCRAM) A2	TRIP	
1448	A055	LPRM	16-25	FLX LV D	LOW RSN		
14	49	10	130	D721	MSIV INNR TRIP DC	ON	
1448	A061	LPRM	32-25	FLX LV B	LOW RSN		
14	49	10	160	D563	RECIRC BREAKER #2	TRIP	
1448	A071	LPRM	48-25	FLX LV D	LOW RSN		
14	49	10	170	D562	RECIRC BREAKER #1	TRIP	
1448	A109	LPRM	16-41	FLX LV B	LOW RSN		
14	49	10	440	D697	TURB VIB OVER TRIP	OFF	
1448	A119	LPRM	32-41	FLX LV D	LOW RSN		
14	49	10	500	D628	APRM THERMAL LEVEL C	TRIP	
1448	A125	LPRM	48-41	FLX LV B	LOW RSN		
14	49	10	500	D548	APRM CHNL C UPSCALE	TRIP	
1448	A159	LPRM	16-57	FLX LV D	LOW RSN		
14	49	10	510	D550	APRM CHNL E UPSCALE	TRIP	
1448	A185	LPRM	32-57	FLX LV B	LOW RSN		
14	49	10	510	D630	APRM THERMAL LEVEL E	TRIP	
1448	A023	LPRM	08-17	FLX LV D	LOW RSN		
14	49	10	540	D686	TURB THRST BRG TRIP	OFF	
1448	A029	LPRM	24-17	FLX LV B	LOW RSN		
14	49	10	660	D546	APRM CHNL A UPSCALE	TRIP	
1448	A039	LPRM	40-17	FLX LV D	LOW RSN		
14	49	10	670	D626	APRM THERMAL LEVEL A	TRIP	
1448	A045	LPRM	56-17	FLX LV B	LOW RSN		
14	49	13	130	D660	HPCS D/G BREAKER	CLSD	
1448	A077	LPRM	08-33	FLX LV B	LOW RSN		
14	49	13	240	D777	D/G BUS LOSS HPCS	OFF	
1448	A087	LPRM	24-33	FLX LV D	LOW RSN		
END JOB							
1448 A093 LPRM 40-33 FLX LV B LOW RSN							
TRIP SEQUENCE LOG 11-03-11							
H MIN SEC MSEC PID ABBREVIATION STATUS							
1448	A103	LPRM	56-33	FLX LV D	LOW RSN		
14	50	18	150	D699*	STAT CW INITPRES TRIP	ON	
1448	A135	LPRM	08-49	FLX LV D	LOW RSN		
END JOB							
1448 A141 LPRM 24-49 FLX LV B LOW RSN							
TRIP SEQUENCE LOG 11-03-11							
H MIN SEC MSEC PID ABBREVIATION STATUS							

福島第一 6号機

2011-03-11

平成23年3月11日



15	39	34	510	D674	LP CONDENSATE PUMP C	ON
15	39	34	540	D683	AUX POWER LOSS 6E-1	TRIP
15	39	34	570	D658	AUX POWER LOSS 6A-2	NORM
15	39	34	610	D674	LP CONDENSATE PUMP C	OFF
15	39	34	680	D658	AUX POWER LOSS 6A-2	TRIP
15	39	34	720	D659	AUX POWER LOSS 6B-2	NORM
15	39	34	790	D683	AUX POWER LOSS 6B-1	NORM
15	39	34	820	D659	AUX POWER LOSS 6B-2	TRIP
15	39	34	900	D683	AUX POWER LOSS 6B-1	TRIP
15	39	34	940	D659	AUX POWER LOSS 6B-2	NORM
15	39	34	960	D658	AUX POWER LOSS 6A-2	NORM
15	39	35	050	D659	AUX POWER LOSS 6B-2	TRIP
15	39	35	070	D672	LP CONDENSATE PUMP A	ON
15	39	35	070	D658	AUX POWER LOSS 6A-2	TRIP
15	39	35	170	D672	LP CONDENSATE PUMP A	OFF
15	39	35	270	D658	AUX POWER LOSS 6A-2	NORM
15	39	35	270	D674	LP CONDENSATE PUMP C	ON
15	39	35	380	D658	AUX POWER LOSS 6A-2	TRIP
15	39	35	380	D674	LP CONDENSATE PUMP C	OFF
15	39	35	390	D683	AUX POWER LOSS 6B-1	NORM
15	39	35	490	D683	AUX POWER LOSS 6B-1	TRIP
15	39	35	550	D659	AUX POWER LOSS 6B-2	NORM
15	39	35	630	D683	AUX POWER LOSS 6B-1	NORM
15	39	35	660	D659	AUX POWER LOSS 6B-2	TRIP
15	39	35	700	D658	AUX POWER LOSS 6A-2	NORM
15	39	35	740	D683	AUX POWER LOSS 6B-1	TRIP
15	39	35	780	D659	AUX POWER LOSS 6B-2	NORM
15	39	35	800	D672	LP CONDENSATE PUMP A	ON
15	39	35	810	D658	AUX POWER LOSS 6A-2	TRIP
15	39	35	890	D659	AUX POWER LOSS 6B-2	TRIP
15	39	35	910	D672	LP CONDENSATE PUMP A	OFF
15	39	35	970	D658	AUX POWER LOSS 6A-2	NORM
15	39	36	030	D674	LP CONDENSATE PUMP C	ON
15	39	36	090	D658	AUX POWER LOSS 6A-2	TRIP
15	39	36	140	D674	LP CONDENSATE PUMP C	OFF
15	39	36	280	D683	AUX POWER LOSS 6B-1	NORM
15	39	36	400	D683	AUX POWER LOSS 6B-1	TRIP
15	39	36	400	D659	AUX POWER LOSS 6B-2	NORM
15	39	36	420	D658	AUX POWER LOSS 6A-2	NORM
15	39	36	510	D659	AUX POWER LOSS 6B-2	TRIP
15	39	36	530	D658	AUX POWER LOSS 6A-2	TRIP
15	39	36	530	D672	LP CONDENSATE PUMP A	ON
15	39	36	620	D659	AUX POWER LOSS 6B-2	NORM
15	39	36	650	D672	LP CONDENSATE PUMP A	OFF
15	39	36	670	D658	AUX POWER LOSS 6A-2	NORM
15	39	36	740	D659	AUX POWER LOSS 6B-2	TRIP
15	39	36	770	D658	AUX POWER LOSS 6A-2	TRIP
15	39	36	790	D674	LP CONDENSATE PUMP C	ON
15	39	36	890	D674	LP CONDENSATE PUMP C	OFF
15	39	37	160	D658	AUX POWER LOSS 6A-2	NORM
15	39	37	220	D659	AUX POWER LOSS 6B-2	NORM
15	39	37	260	D683	AUX POWER LOSS 6B-1	NORM
15	39	38	310	D659	AUX POWER LOSS 6B-2	NORM
15	39	40	620	D674	LP CONDENSATE PUMP C	ON
15	39	42	900	D674	LP CONDENSATE PUMP C	ON
15	39	45	010	D659	AUX POWER LOSS 6B-2	NORM
15	39	47	410	D672	LP CONDENSATE PUMP A	OFF
15	39	49	500	D659	AUX POWER LOSS 6B-2	NORM
15	39	51	760	D672	LP CONDENSATE PUMP A	ON
15	39	54	080	D672	LP CONDENSATE PUMP A	ON
15	39	56	250	D658	AUX POWER LOSS 6A-2	NORM
15	39	58	370	D674	LP CONDENSATE PUMP C	ON
15	40	00	580	D672	LP CONDENSATE PUMP A	ON
15	40	03	070	D672	LP CONDENSATE PUMP A	ON
15	40	07	730	D775	D/G BUS LOSS 6C	ON
15	40	10	280	D672	LP CONDENSATE PUMP A	ON
15	40	18	630	D650	HPCS D/G BREAKER	OPEN
15	40	21	690	D777	D/G BUS LOSS HPCS	ON
15	43	31	630	D686	TURB THRST BRG TRIP	ON

END JOB

### Damage analyses based on behaviors of on-site power facilities

We will conduct the following analyses on causes for each on-site power facility based on its behaviors according to plant data at the occurrence of the earthquake.

We will confirm the soundness of power facility on the ground that it can receive electricity or supply electricity to loads.

#### ① Unit 1

Power supply source of Diesel Generators is received at an emergency HV Switch Board, connected with an emergency Power Center as a power panel at a downstream side and supplied to each load in the plant.

After the earthquake occurred, Diesel Generators (DG 1A, 1B) started due to the failure of off-site power and their power was supplied to emergency HV Switch Boards (M/C 1C, 1D) and the voltage was normally restored. Hence, we can confirm that these power facilities were in sound conditions after the earthquake.

In addition, regarding emergency Power Centers which are power supply sources for surrounding equipments required to continue operating Diesel Generators, we can confirm that the Power Centers were in sound conditions after the earthquake, as Diesel Generators were continuously operated.

Moreover, Containment Spray System (A) and System (B) Pumps started after the earthquake as loads of emergency Power Centers and we found data after the earthquake in the chart of the recorder installed in the control panel of the central operation room. Hence, we can confirm the areas between Diesel Generators and emergency Power Centers were in sound conditions after the earthquake (Attachment-1).

On the other hand, as all AC sources were failed after the tsunami reached, we think Diesel Generators (DG 1A, 1B), emergency HV Switch Boards (M/C 1C, 1D) and emergency Power Centers (P/C 1C, 1D) were damaged by the tsunami.

DC 125 V of power facilities (1A, 1B) whose power source is a battery in case of AC source failure are used for initial excitation for Diesel Generators or for control power supply to emergency HV Switch Boards.

As Diesel Generators and emergency HV Switch Boards were normally operated after the earthquake, we can confirm that DC 125 V of power

facilities (1A, 1B) were in sound conditions. We assume that they were damaged thereafter.

Due to the failure of off-site power, we cannot confirm the soundness of a regular use HV Switch Boards or a regular use Power Center after the failure. However, we assume that they were damaged by the tsunami, as they and an emergency HV Switch Boards are installed in almost the same area.

## ② Unit 2

Power supply source of Diesel Generators is received at an emergency HV Switch Board, connected with an emergency Power Center as a power panel at a downstream side and supplied to each load in the plant.

After the earthquake occurred, Diesel Generators (DG 2A, 2B) started due to the failure of off-site power and their power was supplied to emergency HV Switch Boards (M/C 2C, 2D, 2E) and the voltage was normally restored. Hence, we can confirm that these power facilities were in sound conditions after the earthquake.

In addition, MC 2E and M/C 2D are connected and power source of DG 2B is received at M/C 2E and supplied to M/C 2D. Hence, we can confirm that M/C 2E was also in a sound condition.

Regarding an emergency Power Center (P/C 2E) which is a power supply source for surrounding equipments required to continue operating a Diesel Generator (DG 2B), we can confirm that the Power Center was in a sound condition after the earthquake, as a Diesel Generator was continuously operated.

Moreover, Residual Heat Removal System Pumps (RHR (A) and (C)) started after the earthquake as loads of emergency HV Switch Boards and we found data after the earthquake in the chart of the recorder installed in the control panel of the central operation room as loads of an emergency Power Center. Hence, we can confirm the areas between Diesel Generators and the emergency Power Center were in sound conditions after the earthquake (Attachment-2).

On the other hand, as all AC sources were failed after the tsunami reached, we think Diesel Generators (DG 2A, 2B), emergency HV Switch Boards (M/C 2C, 2D, 2E) and the emergency Power Center (P/C 2E) were damaged by the tsunami.

DC 125 V of power facilities (2A, 2B) whose power source is a battery in

case of AC source failure are used for initial excitation for Diesel Generators or for control power supply to emergency HV Switch Boards.

As Diesel Generators and emergency HV Switch Boards were normally operated after the earthquake, we can confirm that DC 125 V of power facilities (1A, 1B) were in sound conditions. We assume that they were damaged thereafter.

Due to the failure of off-site power, we cannot confirm the soundness of a regular use HV Switch Board or a regular use Power Center after the failure. However, we assume that they were damaged by the tsunami, as they and an emergency HV Switch Board are installed in almost the same area.

### ③ Unit 3

Power supply source of Diesel Generators is received at an emergency HV Switch Board, connected with an emergency Power Center as a power panel at a downstream side and supplied to each load in the plant.

After the earthquake occurred, Diesel Generators (DG 3A, 3B) started due to the failure of off-site power and their power was supplied to emergency HV Switch Boards (M/C 3C, 3D) and the voltage was normally restored. Hence, we can confirm that these power facilities were in sound conditions after the earthquake.

Regarding emergency Power Centers (P/C 3C, 3D) which is a power supply source for surrounding equipments required to continue operating Diesel Generators, we can confirm that the Power Centers were in sound conditions after the earthquake, as Diesel Generators were continuously operated.

Moreover, we found data after the earthquake in the chart of the recorder installed in the control panel of the central operation room as loads of the emergency Power Centers. Hence, we can confirm the areas between Diesel Generators and emergency Power Centers were in sound conditions after the earthquake.

On the other hand, as all AC sources were failed after the tsunami reached, we think Diesel Generators (DG 3A, 3B), emergency HV Switch Boards (M/C 3C, 3D) and emergency Power Centers (P/C 3C, 3D) were damaged by the tsunami.

Due to the failure of off-site power, we cannot confirm the soundness of a regular use HV Switch Board or a regular use Power Center after the failure. However, we assume that they were damaged by the tsunami, as they and an

emergency HV Switch Board are installed in the almost same area.

Due to the failure of off-site power, we cannot confirm the soundness of a regular use HV Switch Board or a regular use Power Center after the failure. However, we assume that they were damaged by the tsunami, as they and an emergency HV Switch Board are installed in almost the same area.

#### ④ Unit 4

Power supply source of Diesel Generators is received at an emergency HV Switch Board, connected with an emergency Power Center as a power panel at a downstream side and supplied to each load in the plant.

Though the on-site power source was failed at 3:38 pm according to the shift supervisor task handover journal, we cannot data regarding operations of Diesel Generators, as we were replacing a process computer and a transient recorder.

However, as all AC sources were failed after the tsunami reached and damaged power facilities are installed in almost the same area (the first basement) as those in other units, we assume that Diesel Generators (DG 4A, 4B), HV Switch Boards (M/C 4A, 4B, 4C, 4D, 4E), an emergency Power Center (P/C 4E) and DC 125V of power facilities (4A, 4B) were damaged by the tsunami.

As we found data after the earthquake in the chart of the recorder installed in the control panel of the central operation room as loads of emergency Power Centers, we can confirm the areas between Diesel Generators and emergency Power Centers were in sound conditions after the earthquake.

#### ⑤ Unit 5

Power supply source of Diesel Generators is received at an emergency HV Switch Board, connected with an emergency Power Center as a power panel at a downstream side and supplied to each load in the plant.

After the earthquake occurred, Diesel Generators (DG 5A, 5B) started due to the failure of off-site power and their power was supplied to emergency HV Switch Boards (M/C 5C, 5D) and the voltage was normally restored. Hence, we can confirm that these power facilities were in sound conditions after the earthquake.

In addition, regarding emergency Power Centers (P/C 5C, 5D) which are power supply sources for surrounding equipments required to continue

operating Diesel Generators, we can confirm that the Power Centers were in sound conditions after the earthquake, as Diesel Generators were continuously operated.

Moreover, Residual Heat Removal Seawater System Pump (RHRS Pump D) started after the earthquake as a load of an emergency HV Switch Board and we found data after the earthquake in the chart of the recorder installed in the control panel of the central operation room as loads of emergency Power Centers. Hence, we can confirm the areas between Diesel Generators and emergency Power Centers were in sound conditions after the earthquake (Attachment-3).

On the other hand, as all AC sources were failed after the tsunami reached, we think Diesel Generators (DG 5A, 5B), emergency HV Switch Boards (M/C 5C, 5D) and emergency Power Centers (P/C 5C, 5D) were damaged by the tsunami.

Due to the failure of off-site power, we cannot confirm the soundness of a regular use HV Switch Board or a regular use Power Center after the failure. However, we assume that they were damaged by the tsunami, as they and an emergency HV Switch Board are installed in almost the same area.

We think emergency and regular use HV Switch Boards and emergency and regular use Power Centers are damaged by the tsunami, as we confirmed part of them at the site in the light of early restoration and their parts where corrosion by seawater was confirmed were replaced and power was received there.

#### ⑥ Unit 6

Power supply source of Diesel Generators is received at an emergency HV Switch Board, connected with an emergency Power Center as a power panel at a downstream side and supplied to each load in the plant.

After the earthquake occurred, Diesel Generators (DG 6A, 6B, HPCS DG) started due to the failure of off-site power and their power was supplied to emergency HV Switch Boards (M/C 6C, 6D, HPCS D/G M/C) and the voltage was normally restored. Hence, we can confirm that these power facilities were in sound conditions after the earthquake.

Moreover, we found data after the earthquake in the chart of the recorder installed in the control panel of the central operation room as loads of the emergency Power Centers. Hence, we can confirm the areas between Diesel

Generators and emergency Power Centers were in sound conditions after the earthquake.

We think that Diesel Generators (DG 6A, HPCS DG) were damaged by the tsunami, as electricity went out in emergency HV Switch Boards (M/C 6C, HPCS D/G) after the tsunami arrived.

Due to the failure of off-site power, we cannot confirm the soundness of a regular use HV Switch Board or a regular use Power Center after the failure. However, we assume that they were damaged by the tsunami, as they are installed in almost the same area as those in other units.


We think emergency and regular use HV Switch Boards and emergency and regular use Power Centers are damaged by the tsunami, as we confirmed part of them at the site in the light of early restoration and their parts where corrosion by seawater was confirmed were replaced and power was received there.

#### ⑦ Toden Genshiryoku Line

We have confirmed flaws in cables, but we cannot estimate their causes when we judge the causes from plant data at the occurrence of the earthquake.


1. CCSポンプA吐出流量

0.000 L/S



2. CCSポンプB吐出流量


格納容器スプレイ系 (A) 系起動



3. 予備


0.000 digital

格納容器スプレイ系 (B) 系起動




4. 予備

0.000 digital





Group name; 1F-2 (1) Emergency  
Core Cooling System Flow rate (5)  
0.000 digital



# Unit 5

( Under Regular Inspection)

## 5号機

(定期検査中)

内訳

Breakdown



- ① アラームタイパ  
Alarm recorder

Alarm recorder message

* 2011/03/11 14:49	F107	浄化系脱塩器出口電導度 A	= 0.383	制限値=0.1	P=01	高
* 2011/03/11 14:49	F108	浄化系脱塩器出口電導度 B	= 0.327	制限値=0.1	P=01	高
2011/03/11 14:49	B060	TIP 炉心外検出器位置 A	= -1.5		P=01	正常復帰
2011/03/11 14:49	B061	TIP 炉心外検出器位置 B	= -1.3		P=01	正常復帰
2011/03/11 14:49	B062	TIP 炉心外検出器位置 C	= -1.5		P=01	正常復帰
2011/03/11 14:49	B063	TIP 炉心外検出器位置 D	= -1.4		P=01	正常復帰
2011/03/11 14:49	P537	RHRS Dポンプ遮断器 RHRS D pump Circuit Breaker	= ON			
* 2011/03/11 14:49	PI63	原子炉水位 (W/R) A	= 2638	制限値=----	P=01	RL上限逸脱
2011/03/11 14:49	F139	床下レンサンプ水位	= -1.1		P=01	正常復帰
2011/03/11 14:49	L008	酸素注入流量	= -0.03		P=01	正常復帰
2011/03/11 14:49	L007	水素注入流量	= -0.5		P=01	正常復帰
2011/03/11 14:49	Z576	TIP 検出器 索引機構前 A	= ON			
2011/03/11 14:49	Z577	TIP 検出器 索引機構前 B	= ON			
2011/03/11 14:49	Z578	TIP 検出器 索引機構前 C	= ON			
2011/03/11 14:49	Z579	TIP 検出器 索引機構前 D	= ON			
2011/03/11 14:49	Z568	TIP 検出器 引抜中 A	= ON			
2011/03/11 14:49	Z569	TIP 検出器 引抜中 B	= ON			
2011/03/11 14:49	Z570	TIP 検出器 引抜中 C	= ON			
2011/03/11 14:49	Z571	TIP 検出器 引抜中 D	= ON			
2011/03/11 14:49	Z576	TIP 検出器 索引機構前 A	= OFF			
2011/03/11 14:49	Z577	TIP 検出器 索引機構前 B	= OFF			
2011/03/11 14:49	Z578	TIP 検出器 索引機構前 C	= OFF			
2011/03/11 14:49	Z579	TIP 検出器 索引機構前 D	= OFF			
2011/03/11 14:49	C007	ジェット ポンプ総流量	= 7370		P=01	正常復帰
2011/03/11 14:49	B013	S/C 水位	= -0.8		P=01	正常復帰
* 2011/03/11 14:49	B013	S/C 水位	= -5.4	制限値=-3	P=01	低
2011/03/11 14:49	C186	炉心流量 (T/H)	= 7370		P=01	正常復帰
2011/03/11 14:49	C187	炉心流量 (%)	= 0		P=01	正常復帰
2011/03/11 14:49	S316	ジェットポンプ総流量 (%)	= 22.1		P=01	正常復帰
2011/03/11 14:49	S317	P-Fマップ 選択炉心流量 (%)	= 22.1		P=01	正常復帰
2011/03/11 14:49	S318	P-Fマップ 選択炉心流量	= 7370		P=01	正常復帰
2011/03/11 14:49	Z551	TIP 隔離弁 閉 A	= ON			
2011/03/11 14:49	Z568	TIP 検出器 引抜中 A	= OFF			
2011/03/11 14:49	Z569	TIP 検出器 引抜中 B	= OFF			
2011/03/11 14:49	Z570	TIP 検出器 引抜中 C	= OFF			
2011/03/11 14:49	Z571	TIP 検出器 引抜中 D	= OFF			
2011/03/11 14:49	B013	S/C 水位	= 3.8			
* 2011/03/11 14:49	B013	S/C 水位	= 7.3	制限値=7	P=01	正常復帰 高
2011/03/11 14:49	Z553	TIP 隔離弁 閉 B	= ON			
2011/03/11 14:49	Z555	TIP 隔離弁 閉 C	= ON			
2011/03/11 14:49	Z557	TIP 隔離弁 閉 D	= ON			
2011/03/11 14:49	Z590	TIP チャンネル操作完了 C	= OFF			
2011/03/11 14:49	Z591	TIP チャンネル操作完了 D	= OFF			
2011/03/11 14:49	Z550	TIP 隔離弁 開 A	= OFF			
2011/03/11 14:49	Z552	TIP 隔離弁 開 B	= OFF			
2011/03/11 14:49	Z556	TIP 隔離弁 開 D	= OFF			
2011/03/11 14:49	L005	排ガスサンドフィルタ 入口流量	= 0.00		P=01	正常復帰
2011/03/11 14:49	Z554	TIP 隔離弁 開 C	= OFF			

The root cause analysis result of damages to on-site power facilities at Fukushima Daiichi Nuclear Power Station



Unit 1,2				Unit 3,4				Unit 5,6																			
	Equipment	Damage	Plant Data 1	Cause	Equipment	Damage	Plant Data 1	Cause	Equipment	Damage	Plant Data 1	Cause	Equipment	Damage	Plant Data 1	Cause	Equipment	Damage	Plant Data 1	Cause	Equipment	Damage	Plant Data 1	Cause			
D G	DG 1A	Yes	Yes	Tsunami	DG 2A	Yes	Yes	Tsunami	DG 3A	Yes	Yes	Tsunami	DG 4A	Yes	No	(Tsunami)	DG 5A	Yes <sub>4</sub>	Yes	Tsunami	DG 6A	Yes <sub>4</sub>	Yes	Tsunami			
	DG 1B	Yes	Yes	Tsunami	DG 2B	Yes <sub>3</sub>	Yes	Tsunami	DG 3B	Yes	Yes	Tsunami	DG 4B	Yes <sub>3</sub>	Yes	(Tsunami)	DG 5B	Yes <sub>4</sub>	Yes	Tsunami	DG 6B	No	-	-			
	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	HPCSD/G	Yes <sub>4</sub>	Yes	Tsunami		
Emergency HV Switch Board (M/C)	M/C 1C	Yes	Yes	Tsunami	M/C 2C	Yes	Yes	Tsunami	M/C 3C	Yes	Yes	Tsunami	M/C 4C	Yes	No	(Tsunami)	M/C 5C <sub>2</sub>	Yes	Yes	Tsunami	M/C 6C	No	-	-			
	M/C 1D	Yes	Yes	Tsunami	M/C 2D	Yes	Yes	Tsunami	M/C 3D	Yes	Yes	Tsunami	M/C 4D	Yes	No	(Tsunami)	M/C 5D <sub>2</sub>	Yes	Yes	Tsunami	M/C 6D	No	-	-			
	-	-	-	-	M/C 2E	Yes	Yes	Tsunami	-	-	-	-	M/C 4E	Yes	No	(Tsunami)	-	-	-	-	HPCS DG M/C	No	-	-			
Regular HV Switch Board (M/C)	M/C 1A	Yes	No	(Tsunami)	M/C 2A	Yes	No	(Tsunami)	M/C 3A	Yes	No	(Tsunami)	M/C 4A	Yes	No	(Tsunami)	M/C 5A <sub>2</sub>	Yes	No	(Tsunami)	M/C 6A-1	Yes	No	(Tsunami)			
																					M/C 6A-2 <sub>2</sub>	Yes	No	(Tsunami)			
	M/C 1B	Yes	No	(Tsunami)	M/C 2B	Yes	No	(Tsunami)	M/C 3B	Yes	No	(Tsunami)	M/C 4B	Yes	No	(Tsunami)	M/C 5B <sub>2</sub>	Yes	No	(Tsunami)	M/C 6B-1	Yes	No	(Tsunami)			
																					M/C 6B-2 <sub>2</sub>	Yes	No	(Tsunami)			
	M/C 1S	Yes	No	(Tsunami)		M/C 2SA	Yes	No	(Tsunami)	M/C 3SA	Yes	No	(Tsunami)	-	-	-	-	M/C 5SA-1 <sub>2</sub>	Yes	No	(Tsunami)	-	-	-	-		
																			M/C 5SA-2 <sub>2</sub>	Yes	No	(Tsunami)	-	-	-	-	
																				M/C 5SB-1 <sub>2</sub>	Yes	No	(Tsunami)	-	-	-	-
																				M/C 5SB-2 <sub>2</sub>	Yes	No	(Tsunami)	-	-	-	-

 : Estimated to be Tsunami according to the plant data at the time of the earthquake occurrence  
 : Assumed to be Tsunami


- 1 : "Yes" means that the start of Diesel Generator and power receive, power supply are confirmed according to the plant data at the time of the earthquake occurrence.
- 2 : From the viewpoint of early restoration of power supply, the power receive was completed after confirmation of site and change the parts damaged and eroded by the sea water
- 3 : Inoperable due to submerging of M/C
- 4 : Relating facilities were received water of submerged

# The root cause analysis result of damages to on-site power facilities at Fukushima Daiichi Nuclear Power Station

Unit 1,2				Unit 3,4				Unit 5,6																	
	Equipment	Damage	Plant Data 1	Cause	Equipment	Damage	Plant Data 1	Cause	Equipment	Damage	Plant Data 1	Cause	Equipment	Damage	Plant Data 1	Cause	Equipment	Damage	Plant Data 1	Cause	Equipment	Damage	Plant Data 1	Cause	
Emergency Power Center (P/C)	P/C 1C	Yes	Yes	Tsunami	P/C 2C	No	-	-	P/C 3C	Yes	Yes	Tsunami	P/C 4C	No	-	-	P/C 5C <sub>2</sub>	Yes	Yes	Tsunami	P/C 6C	No	-	-	
	P/C 1D	Yes	Yes	Tsunami	P/C 2D	No	-	-	P/C 3D	Yes	Yes	Tsunami	P/C 4D	No	-	-	P/C 5D <sub>2</sub>	Yes	Yes	Tsunami	P/C 6D	No	-	-	
	-	-	-	-	P/C 2E	Yes	Yes	Tsunami	-	-	-	-	P/C 4E	Yes	No	(Tsunami)	-	-	-	-	P/C 6E	No	-	-	
Regular Power Center (P/C)	P/C 1A	Yes	No	(Tsunami)	P/C 2A	No	-	-	P/C 3A	Yes	No	(Tsunami)	P/C 4A	No	-	-	P/C 5A <sub>2</sub>	Yes	No	(Tsunami)	P/C 6A-1	Yes	No	(Tsunami)	
					P/C 2A-1	Yes	No	(Tsunami)	-	-	-	-	-	-	-	-	P/C 5A-1	No	-	-	P/C 6A-2	Yes	No	(Tsunami)	
	P/C 1B	Yes	No	(Tsunami)	P/C 2B	No	-	-	P/C 3B	Yes	No	(Tsunami)	P/C 4B	No	-	-	P/C 5B <sub>2</sub>	Yes	No	(Tsunami)	P/C 6B-1	Yes	No	(Tsunami)	
	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	P/C 5B-1	No	-	-	P/C 6B-2 <sub>2</sub>	Yes	No	(Tsunami)
	P/C 1S	Yes	No	(Tsunami)	-	-	-	-	P/C 3SA	Yes	No	(Tsunami)	-	-	-	-	-	P/C 5SA <sub>2</sub>	Yes	No	(Tsunami)	-	-	-	-
	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	P/C 5SA-1	Yes	No	(Tsunami)	-	-	-	-
	-	-	-	-	P/C 2SB	Yes	No	(Tsunami)	P/C 3SB	Yes	No	(Tsunami)	-	-	-	-	-	P/C 5SB <sub>2</sub>	Yes	No	(Tsunami)	-	-	-	-
DC 125V	125V DC BUS-1A	Yes	Yes	Tsunami	125V DC DIST CTR 2A	Yes	Yes	Tsunami	DC125V Main Bus Board 3A	No	-	-	DC125V Main Bus Board 4A	Yes	No	(Tsunami)	DC125V Main Bus Board 5A	No	-	-	125V DC PLANT DISTR CENTER 6A	No	-	-	
	125V DC BUS-1B	Yes	Yes	Tsunami	125V DC DIST CTR 2B	Yes	Yes	Tsunami	DC125V Main Bus Board 3B	No	-	-	DC125V Main Bus Board 4B	Yes	No	(Tsunami)	DC125V Main Bus Board 5B	No	-	-	125V DC PLANT DISTR CENTER 6B	No	-	-	

 : Estimated to be Tsunami according to the plant data at the time of the earthquake occurrence  
 : Assumed to be Tsunami

1 : "Yes" means that the start of Diesel Generator and power receive, power supply are confirmed according to the plant data at the time of the earthquake occurrence.  
 2 : From the viewpoint of early restoration of power supply, the power receive was completed after confirmation of site and change the parts damaged and eroded by the sea water



Inundation Level & Area and Runup Level of Fukushima Daiichi Nuclear Power Station  
 (Extract from "Investigation Results regarding Tsunami at Fukushima Daiichi and Daini Nuclear Power Stations")