

## Results of Nuclide Analyses of Sub-drains

Reference
-----------

(Data summarized on May 24)

Place of sampling	Sub-drain of Unit1, Fukushima Daiichi	Sub-drain of Unit2, Fukushima Daiichi	Sub-drain of Unit3, Fukushima Daiichi	Sub-drain of Unit4, Fukushima Daiichi	Sub-drain of Unit5, Fukushima Daiichi	Sub-drain of Unit6, Fukushima Daiichi	Deep well, Fukushima Daiichi
Time and Date of Sample Collection	11:40 am May 23, 2011	11:45 am May 23, 2011	11:50 am May 23, 2011	11:31 am May 23, 2011	11:30 am May 23, 2011	11:20 am May 23, 2011	10:05 am May 23, 2011
Detected Nuclides (Half-life)	Radioactivity Density of Sample ( Bq/cm <sup>3</sup> )						
I-131 (about 8 days)	4.4E-01	2.0E+01	1.8E-02	ND	ND	ND	ND
Cs-134 (about 2 years)	6.2E+00	1.9E+01	1.6E-01	4.7E-02	ND	1.4E-02	ND
Cs-137 (about 30 years)	7.4E+00	2.2E+01	1.8E-01	5.1E-02	ND	1.5E-02	ND

. E - means . ×10.

Data of other nuclides are under evaluation.