Results of Nuclide Analyses of Sub-drains

Reference

(Data summarized on May 28)

Place of sampling	Sub-drain of Unit1, Fukushima Daiichi	Sub-drain of Unit2, Fukushima Daiichi	Sub-drain of Unit3, Fukushima Daiichi	Sub-drain of Unit4, Fukushima Daiichi	Sub-drain of Unit5, Fukushima Daiichi	Sub-drain of Unit6, Fukushima Daiichi	Deep well, Fukushima Daiichi
Time and Date of Sample Collection	12:02 pm May 27, 2011	12:07 pm May 27, 2011	12:12 pm May 27, 2011	11:51 am May 27, 2011	11:52 pm May 27, 2011	11:42 pm May 27, 2011	11:00 am May 27, 2011
Detected Nuclides (Half-life)	Radioactivity Density of Sample (Bq/cm³)						
I-131 (about 8 days)	1.8E-01	1 . 4E+01	1.1E-02	ND	ND	ND	ND
Cs-134 (about 2 years)	4.9E+00	1.6E+01	1.5E-01	4.3E-02	ND	1.3E-02	ND
Cs-137 (about 30 years)	6.0E+00	2.0E+01	1.6E-01	3.9E-02	ND	1.4E-02	ND

[.] E - means . ×10.

Data of other nuclides are under evaluation.