

Reference

The Results of Nuclide Analyses of Radioactive Materials in the Seawater <1/3>
 Fukushima Daiichi Nuclear Power Station; the shallow draft quay, Unit 1-4 screen, and the water intake canal of Units 1-4

(Data taken on May 30)

Place of Collection	Shallow Draft Quay of 1F		Inside north water intake canal of 1F's Unit 1-4		Screen of 1F's Unit 1 (outside the silt fence)		Screen of 1F's Unit 1 (inside the silt fence)		Screen of 1F's Unit 2 (outside the silt fence)		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Time and date of sample collection	2011/5/29 6:02		2011/5/29 6:13		2011/5/29 6:30		2011/5/29 6:33		2011/5/29 6:21		
Detected nuclide (half-life)	Density of sample (Bq/L)	Scaling factor (/)	Density of sample (Bq/L)	Scaling factor (/)	Density of sample (Bq/L)	Scaling factor (/)	Density of sample (Bq/L)	Scaling factor (/)	Density of sample (Bq/L)	Scaling factor (/)	
I-131 (about 8 days)	22	0.55	660	17.00	710	18.00	440	11.00	700	18.00	40
Cs-134 (about 2 years)	360	6.00	1,500	25.00	1,600	27.00	1,500	25.00	1,500	25.00	60
Cs-137 (about 30 years)	380	4.20	1,500	17.00	1,700	19.00	1,500	17.00	1,700	19.00	90

"Density limit by the announcement of Reactor Regulation" shows the value in "Bq/ L" converted from the value originally in "Bq/ cm³".

Data of other nuclides are under evaluation.

In the case that there are multiple kinds of nuclides, compare the sum of each scaling factor against its density limit with 1

Reference

The Results of Nuclide Analyses of Radioactive Materials in the Seawater <2/3>
 Fukushima Daiichi Nuclear Power Station; the shallow draft quay, Unit 1-4 screen, and the water intake canal of Units 1-4

(Data taken on May 30)

Place of Collection	Screen of 1F's Unit 2 (inside the silt fence)		Screen of 1F's Unit 3 (outside the silt fence)		Screen of 1F's Unit 3 (inside the silt fence)		Screen of 1F's Unit 4 (outside the silt fence)		Screen of 1F's Unit 4 (inside the silt fence)		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Time and date of sample collection	2011/5/29 6:24		2011/5/29 6:39		2011/5/29 6:43		2011/5/29 6:39		2011/5/29 6:43		
Detected nuclide (half-life)	Density of sample (Bq/L)	Scaling factor (/)	Density of sample (Bq/L)	Scaling factor (/)	Density of sample (Bq/L)	Scaling factor (/)	Density of sample (Bq/L)	Scaling factor (/)	Density of sample (Bq/L)	Scaling factor (/)	
I-131 (about 8 days)	21,000	530	620	16	710	18	640	16	260	7	40
Cs-134 (about 2 years)	4,500	75	1,400	23	5,700	95	2,500	42	2,400	40	60
Cs-137 (about 30 years)	4,900	54	1,600	18	6,200	69	2,700	30	2,600	29	90

"Density limit by the announcement of Reactor Regulation" shows the value in "Bq/ L" converted from the value originally in "Bq/ cm³".

Data of other nuclides are under evaluation.

In the case that there are multiple kinds of nuclides, compare the sum of each scaling factor against its density limit with 1

Reference

The Results of Nuclide Analyses of Radioactive Materials in the Seawater <3/3>
 Fukushima Daiichi Nuclear Power Station; the shallow draft quay, Unit 1-4 screen, and the water intake canal of Units 1-4

(Data taken on May 30)

Place of Collection	Inside the south of 1F's Unit 1-4 Water Intake Canal										Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Time and date of sample collection	2011/5/29 6:49										
Detected nuclide (half-life)	Density of sample (Bq/L)	Scaling factor (/)	Density of sample (Bq/L)	Scaling factor (/)	Density of sample (Bq/L)	Scaling factor (/)	Density of sample (Bq/L)	Scaling factor (/)	Density of sample (Bq/L)	Scaling factor (/)	
I-131 (about 8 days)	480	12	/	/	/	/	/	/	/	/	40
Cs-134 (about 2 years)	1,500	25	/	/	/	/	/	/	/	/	60
Cs-137 (about 30 years)	1,600	18	/	/	/	/	/	/	/	/	90

"Density limit by the announcement of Reactor Regulation" shows the value in "Bq/ L" converted from the value originally in "Bq/ cm³".
 Data of other nuclides are under evaluation.
 In the case that there are multiple kinds of nuclides, compare the sum of each scaling factor against its density limit with 1